

Trinity Lx

Model Numbers: Lx150-800

Version Date: 2013-07-16

BONUS
Extra Modbus
Communication
Port

NEW FEATURES
20% Larger Screen
DHW Lead-Lag Capability
Tank Sensor Option
Outdoor Reset Boost
Optional BACnet Gateway



APPENDIX B - BOILER APPLICATIONS: PLUMBING AND WIRING INSTRUCTIONS

Optional Configuration: Refer to "Appendix C – Water Heater Applications"
Companion Storage Products: TRIN & STOR Indirect Water Heaters

TABLE OF CONTENTS

1.0	INTRODUCTION	2
2.0	BOILER AND HEATING SYSTEMS PIPING	3
	Boiler System Preparation	3
	Boiler Water	3
	Near Boiler Plumbing	4
	Boiler System Plumbing	6
	Stand Alone Boiler Applications	8
	Multiple Boiler Applications	11
3.0	FIELD WIRING	14
	Line Voltage Connections	14
	Low Voltage Connections	17




Lx150-200

Lx300-400

Lx500

Lx600-800



HAZARD SYMBOLS AND DEFINITIONS



Danger Sign: Indicates a hazardous situation which, if not avoided, will result in serious injury or death.



Warning Sign: Indicates a hazardous situation which, if not avoided, could result in serious injury or death.



Caution Sign plus Safety Alert Symbol: Indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.

CAUTION

Caution Sign without Safety Alert Symbol: Indicates a hazardous situation which, if not avoided, could result in property damage.

NOTICE

Notice Sign: Indicates a hazardous situation which, if not avoided, could result in property damage.



This Boiler must be installed by a licensed and trained Heating Technician or the **Warranty is Void**. Failure to properly install this unit may result in property damage, serious injury to occupants, or possibly death.

1.0 INTRODUCTION

IMPORTANT

Boiler Applications – These instructions apply to the plumbing and wiring for Trinity Lx150-800 units operating as boilers and covers instructions that are specific to boiler applications. When units Lx200-800 are installed and operated as water heaters, refer to "Appendix C - Water Heater Applications: Plumbing & Wiring Instructions".

Terminology – The following terms in the instruction manuals are used to differentiate between which instructions are common-to-both and which are appliance-specific. The term "**APPLIANCE**" applies to both kinds of applications (boiler and water heater) and is used when conveying instructions which are common-to-both. The term "**BOILER**" or "**WATER HEATER**" is used when conveying instructions which are appliance-specific or specific to one or the other, but not both.

Table 1-1 Instruction Manuals

Appliance	Model No.	Common-to-Both (Trinity Lx Series)		Appliance-Specific (Application Based)	
Boiler	Lx150-800	Installation and Operation Instructions	Appendix A - Controller and Touchscreen Display Instructions	Appendix B - Boiler Applications: Plumbing and Wiring Instructions	n/a
Water Heater	Lx200-800	Installation and Operation Instructions	Appendix A - Controller and Touchscreen Display Instructions	n/a	Appendix C - Water Heating Applications: Plumbing and Wiring Instructions

Notes

¹ The conversion kit is required to convert the Appliance so it will safely operate with Propane Gas (Lx150-400).

² Do not convert models Lx600-800 to Propane (LP). Operate with Natural Gas only.

General Installation Requirements

The installation of your NTI Trinity gas boiler must conform to the requirements of this manual, your local authority, and the National Fuel Gas Code ANSI Z223.1 and or CAN/CGA B149 Installation Codes. Where required by the Authority, the installation must conform to the standard for "Controls and Safety Devices for Automatically Fired Boilers ANSI/ASME CSD-1.

This document pertains to the correct installation and operation of NTI Trinity boiler models Lx150, Lx150E, Lx200, Lx300, Lx400, Lx500, Lx600, Lx700 and Lx800. The instructions detailed in this document supersede any and all previous instructions provided by NTI, written or otherwise. Each unit is provided with various manuals and a Natural to LP Conversion Kit for applicable models. Refer to notes and list of Instruction Manuals in Table 1-1.



The Lx600-800 is not approved for operation with Propane (LP Gas). Failure to comply with these instructions will result in property damage, serious injury or death.



Read and understand this entire document prior to proceeding with the installation of the Trinity Lx boiler. Failure to follow the instructions outlined in this document will result in property damage, serious injury or death.



Failure to have the boiler properly serviced and inspected on a regular basis by a qualified service technician may result in property damage, serious injury or death.

User Responsibilities

This appliance may only be installed and serviced by a qualified boiler installer/service technician. For normal residential applications this boiler must be serviced / inspected annually, by a qualified boiler technician. Other applications (e.g. commercial or other more strenuous conditions) may require more frequent service/inspection. As the User/owner of this equipment, you are responsible for ensuring the maintenance is performed at the required intervals.

2.0 BOILER AND HEATING SYSTEMS PIPING

The heat exchanger of the Trinity boiler is designed to attain the highest level of heat transfer in a compact design. To accomplish this, the heating water flows through a series of fin shaped tubes, designed to maximize the heat transfer area. To maintain the efficient and reliable operation of the heat exchanger, and to avoid heat exchanger failure, it is critical to ensure the rules and guidelines in this section are followed.



Failure to follow the instructions provided in this section will void the NTI warranty and may result in property damage, fire, serious injury or death.

Boiler System Preparation

Prior to connecting plumbing to the boiler, flush the entire system to ensure it is free of sediment, flux, solder, scale, debris or other impurities that may be harmful to the system and boiler. During the assembly of the heating system, it is important to keep the inside of the piping free of any debris including construction and copper dust, sand and dirt.

For retrofits, all system piping including radiators, must be cleansed of all build-up including sludge and scale. All systems, old and new, must be cleansed to remove flux, grease and carbon residue. NTI recommends cleansing the boiler system with “Ferrox F3 Cleaner”. For retrofit applications with heavy limescale and sludge deposits, a heavier duty cleaner may be required; NTI recommends the use of “Ferrox DS-40 System Cleaner”. For information on performing the cleansing, follow the instructions included with the Ferrox DS-40 System Cleaner. See Table 2-1 for a list of recommended boiler cleansing products.



Failure to rid the heating system of the contaminants listed above will void your NTI warranty and may result in premature heat exchanger failure and property damage.


Table 2-1 Boiler System Cleansers and Corrosion Inhibitors

Application	Ferrox Product	NTI Part #	Description
Boiler Water Treatment	F1 Protector	83448	Corrosion inhibitor.
Cleanser for new and old systems	F3 Cleaner	83449	Removes flux, grease and carbon residue.
Cleanser for Retrofits	DS-40 System Cleaner	83450	Removes heavy limescale and sludge deposits.

Boiler Water

Pressure - The Trinity boilers are intended solely for use in pressurized closed loop heating systems operating with a minimum pressure of 15 PSI at the boiler outlet. To obtain the minimum system design pressure, follow the piping diagrams illustrated in this section.

Oxygen Elimination - This boiler may only be installed in a pressurized closed-loop heating system, free of air (oxygen) and other impurities. To avoid the presence of oxygen, ensure all of the air is removed from the system during commissioning via strategically placed adequately sized air-removal devices, located throughout the heating system. See figures in this section detailing the location of the primary air-removal device required for the boiler. Immediately repair any leaks in the system plumbing to avoid the addition of make-up water; make-up water provides a source of oxygen and minerals that may lead to heat exchanger failure. Failure to follow these instructions will result in poor performance, unnecessary wear of system components and premature failure.



The “Boiler Application” is not approved for operation in an “open system”, thus it cannot be used for direct potable water heating or process heating of any kind.

Water Chemistry – The installer of the Trinity Lx boiler must consider the condition of the water in the heating system. Ensure the condition of the boiler water falls within the following parameters:

- Water hardness – between 3 and 9 Grains/gal.
- PH – between 7.5 and 9.5.

Treatment - Boiler water that falls outside of the conditions listed above must be treated with a corrosion inhibitor. Each Trinity Lx boiler is provided with at least 1 bottle of “Fernox F1” corrosion inhibitor (Lx500-800 comes with 2 bottles), adequate to treat a 26.4 gallon (100 liter) heating system to a minimum required concentration of 0.5%. Systems with greater volume will require more inhibitor. For information on performing the treatment, follow the instructions included with the Fernox F1 Protector. See Table 2-1 for a list of recommended boiler system cleansers and corrosion inhibitors.

IMPORTANT

To maintain protection, the level of corrosion inhibitor must be monitored periodically for the correct concentration.

Anti-freeze - For systems requiring freeze protection, use only inhibited propylene glycol, specially formulated for hydronic heating systems; use of other types of antifreeze may be harmful to the system and will void the warranty. Note: the use of glycol may reduce the usable output capacity of the boiler, thus requiring the unit to be “down-fired” by limiting the maximum operating capacity and/or the maximum water temperature. NTI recommends against exceeding 35% concentration of glycol.

Near Boiler Plumbing

Pressure Relief Valve - A Pressure Relief Valve is factory supplied with all Trinity Lx boilers. Models dual certified as either boilers or water heaters include an additional higher pressure relief valve (125PSI or 150PSI). Excluding Lx150’s sold in Canada (MAWP=30PSI), Trinity Lx boilers have a maximum allowable operating pressure of 145PSI (Lx150, 200 & 400) or 160PSI (Lx300 & 500-800). A pressure relief valve with a higher discharge pressure rating (up to the MAWP of the boiler) may be used as long as the relieving capacity is in excess of the maximum input capacity of the boiler. This allows boiler installations to use either the lower or higher pressure relief valve, while water heater installations are required to use the higher pressure relief valve.

The pressure relief valve must be installed at the boiler outlet and in the vertical position, as shown in Figures 2-1(a) and (b), with the drain pipe outlet exiting the side of the pressure relief valve horizontally and elbowing down. If using a higher pressure relief valve, such as 125PSI, ensure the pressure gauge is sized to display the higher pressure value (e.g. 160PSI pressure gauge). See Table 2-2 for a list of pressure relief valves and corresponding pressure gauge sizes.

CAUTION

If installed with the incorrect orientation (horizontally with drain pipe out the bottom) the relief valve may not function properly resulting in property damage or personal injury.

WARNING

Ensure the discharge of the pressure relief is piped to a location where the steam or water will not cause property damage or serious injury.

Pressure Gauge – All Trinity Lx models come with a factory supplied Pressure Gauge. Models Lx200-800, which are dual certified as either a boiler or a water heater, have an additional factory supplied pressure gauge. For boiler installations, either the lower or higher pressure gauge may be used. For water heater installations, the higher pressure gauge must be used along with the corresponding higher pressure relief valve. The pressure gauge must be installed at the appliance’s outlet prior to any circulators and in the vicinity of the pressure relief valve. See Figures 2-1(a), (b). See Table 2-2 for a list of pressure gauges and corresponding pressure relief valve sizes.

Table 2-2 Corresponding Pressure Relief Valve & Pressure Gauge Sizes

Trinity Model	Application	MAWP	Pressure Relief Valve	Pressure Gauge
Lx150 (Canada Only)	Boiler	30PSI	30PSI	30PSI
Lx150-200, Lx400		145PSI	30PSI	30PSI
Lx300		160PSI	30PSI	30PSI
Lx500-800		160PSI	50PSI	60PSI
Lx200, Lx400	Water Heater	145PSI	125PSI	160PSI
Lx300		160PSI	125PSI	160PSI
Lx500-800		160PSI	150PSI	160PSI

Figure 2-1(a) Lx150 (Canadian)

Near Boiler Piping




Figure 2-1(b) Lx150-400

Near Boiler Piping





Figure 2-1(c) Lx500-800

Near Boiler Piping



Flow Switch / Low Water Cutoff – Trinity Lx150-400 boilers are not provided with a LWCO or Flow Switch. Check with your local authorities for the requirements of these devices prior to installing the boiler. If a Flow Switch is installed it must be located in series with the boiler and in accordance with the instructions provided with the flow switch. Install the flow switch in a 1” diameter line for model Lx200 and a 1-1/4” diameter line for model Lx300-400 at the appliance outlet. After the flow switch, increase pipe diameter to the size specified in Tables 2-4 or 2-5 if required. Refer to Section 3.0 for instructions on wiring the safety flow switch.

NOTICE

When external safety devices are used, such as a LWCO, Flow Switch, or a Temperature Limiting Switch, they must be wired as per the instructions provided in this manual. Refer to Section 3.0 for instructions on wiring the safety flow switch or low water cutoff.

NOTICE

Unlike most Trinity boilers, commercial models Lx500-800, come equipped with a factory installed flow switch installed in a 2” diameter line. The flow switch is pre-plumbed with a Nema 4 rated enclosure and prewired via liquid-tight conduit. According to ASME CSD-1, a flow switch must be used in lieu of a Low Water Cut Off (LWCO) for a water tube boiler. See Checklist for Boiler Installations, **Table 11-1, Trinity Lx Installation and Operation Manual**.

Boiler System Plumbing

The Trinity Lx boiler uses a low mass heat exchanger that requires a minimum rate of forced water circulation any time the burner is operating (See Table 2-4 for minimum flow rates). To ensure the minimum flow rate is attained, the boiler must be installed in a “Primary/Secondary” plumbing configuration utilizing “Closely Spaced Tees” to de-couple the Boiler-Primary loop from the System-Secondary loop(s) (see Figures 2-2 and 2-3 for examples). As well as a Primary/Secondary Loop Configuration utilizing closely spaced tees, a properly installed system will as a minimum include the major components in Table 2-3.

Table 2-3 System Major Component Checklist

Factory Supplied Components	Field Supplied Components
<input type="checkbox"/> Pressure Relief Valve ¹	<input type="checkbox"/> Boiler Loop Circulator (Pump B in Figure 2-2 or Pump C in Figure 2-3)
<input type="checkbox"/> Pressure Gauge ¹	<input type="checkbox"/> DHW Loop Circulator (Pump A in Figure 2-2 and Figure 2-3, for applications utilizing Indirect Fired Water Heater only)
<input type="checkbox"/> Flow Switch (Lx500-800 only)	<input type="checkbox"/> Central Heat (CH) Loop Circulator(s) (CH Circulator - Pump C in Figure 2-2; Zone Circulators in Figure 2-3)
	<input type="checkbox"/> Central Air Removal Devices (i.e. Micro Bubbler or Air-Scoop)
	<input type="checkbox"/> Pressure Regulating “Fill Valve”
	<input type="checkbox"/> Backflow Preventor
	<input type="checkbox"/> Expansion Tank
Notes: ¹ Refer to Table 2-2 for a list of Corresponding Relief Valve and Pressure Gauge sizes for applicable models.	

Circulating Pumps – Trinity Lx150-400 boilers are equipped with three 120VAC pump outputs, while the Lx500-800 is equipped with 3 pump contacts (relays):

1. PUMP A “DHW Pump” - operates during a Domestic Hot Water demand
2. PUMP B “Boiler Pump” - operates during any demand
3. PUMP C “CH Pump” - operates during a Central Heat demand (CH1 or CH2)

Ensure pumps are oriented as per the manufacturers’ instructions. Wiring of these circulators will depend on the system configuration chosen; see Figures 2-2 and 2-3. For further wiring details see Section 3.0.

NOTICE

Circulators responsible for forcing the water flow rate through the boiler must be sized according to Table 2-4, see Figures 2-2 and 2-3 for details.



WARNING

Failure to ensure the minimum water flow rate through the boiler when the burner is on will not only reduce the operating efficiency of the boiler, but may also cause premature failure, overheating and void the warranty. Failure to follow instructions may result in fire, property damage, serious injury or death.

Table 2-4 Minimum Circulator and Pipe Sizes

Model	Restriction Head Loss	Minimum Pipe Size	Min. Flow (GPM)	Max Temp. Rise	Minimum Primary Loop Pump Size			
					B&G	Grundfos	Taco	Armstrong
150	8' at 7 GPM	1"	6	45°F	PL-30	UP 26-99	0011	Astro 50
150E	4' at 7 GPM	1"	6	45°F	PL-30	UP 26-99	0011	Astro 30
200	7' at 10 GPM	1-1/4"	8	45°F	PL-36	UP 26-99	0011	Astro 50
300	7' at 14 GPM	1-1/4"	11	45°F	PL-36	UP 26-99	0011 ¹	E7
400	10' at 20 GPM	1-1/2"	16	45°F	PL-36	UP 26-99	0011 ¹	E8
500	12' at 25 GPM	2"	20	45°F	PL-36 ¹	UP 26-116 ¹	2400-20 ^{1,3}	E8 ¹
600	10' at 30 GPM	2"	24	45°F	PL-55 ⁵	UPS 32-160	2400-45 ⁴	E15 ¹
700	9' at 35 GPM	2"	28	45°F	PL-55 ⁵	UP 43-110 ²	2400-45 ⁴	E15 ¹
800	11' at 40 GPM	2"	32	45°F	PL-55 ⁵	UP 43-110 ²	2400-45 ⁴	E15 ¹

Notes:¹ NOT recommended for DHW indirect circulator when installed as per Figure 2-3, recommend higher head circulator.² Grundfos UPS 32-160 can be considered in place of UP 43-110.³ Taco 2400-40 NOT recommended.⁴ Taco 2400-60 NOT recommended.⁵ B&G PL-75 and PL-130 NOT recommended.

Air Removal – The boiler and system plumbing layout must be configured to promote the removal of air from the water. Air vents and bleeders must be strategically placed throughout the system to aid in purging the air from the system during commissioning of the boiler. The system must also employ the use of a strategically located air removal device, such as an air scoop or micro-bubbler, designed to remove the air from the water as it flows through the system.

NOTICE

Follow the installation instructions included with the air removal device when placing it in the system; air removal devices generally work better when placed higher in the system. Always locate air removal devices in areas of the system that have a guaranteed positive pressure, e.g., in close proximity to the water fill and expansion tank.

NOTICE

Trinity boilers are equipped with an automatic air removal device to aid in the purging of air from the boiler during the initial fill. This device is **NOT** intended, nor is it sufficient to remove the air from the system plumbing, even if the air makes it back to the boiler. A strategically located air removal device must be installed in the system.

Expansion Tank – The expansion tank must be sized in accordance with the water volume of the system as well as the firing rate of the appliance. It is important to locate the expansion tank, and make-up water fill, on the inlet side of any circulator in the system, as doing so will guarantee the lowest pressure in the system will be at least equal to the tank and make-up water pressure. See examples in Figures 2-2 and 2-3.

**CAUTION**

Ensure the expansion tank cannot become isolated from the boiler anytime the system is operating. Failure to follow these instructions may result in discharge of the Pressure Relief Valve may result in property damage or personal injury.

NOTICE

The installation of flow checks, motorized valves or other shutoff devices (other than for the purpose of servicing) are not permitted between the location of the “Closely Spaced Tees” and the expansion tank; see Figures 2-2 and 2-3.

Indirect Fired Water Heater – When installed as per Figure 2-3, the indirect fired water heater is in series with the boiler during a demand for DHW. Therefore when using this configuration it is important to use an Indirect Fired Water Heater that has minimal head loss. Indirect fired water heater head loss must not exceed those specified in Table 2-5, when installed as per Figure 2-3.

Table 2-5 Maximum Indirect Fired Water Heater Head Loss (Boiler Side) at Minimum Flow

Lx150	10' at 6 GPM	Lx500	18' at 20 GPM
Lx150E	14' at 6 GPM	Lx600	18' at 24 GPM
Lx200	14' at 8 GPM	Lx700	15' at 28 GPM
Lx300	12' at 11 GPM	Lx800	12' at 32 GPM
Lx400	9' at 16 GPM		

Stand Alone Boiler Applications

Single or stand alone boilers have the option of two heating inputs. On a central heat call, input CH1 is used as a lone input or as the high temperature input in a dual heating temperature system. CH1 is considered the “local” central heat call and has priority in a dual heating temperature system. The second central heat input (CH2) is used as a low temperature input in a dual heating temperature system. Figures 2-2 and 2-3 are examples of plumbing configurations for stand alone boilers using a single system circulator and multiple system circulators, respectively. Figure 2-3 also illustrates an optional second /low temperature heating zone.

Figure 2-2: Single System Circulator Configuration - Often used in applications zoned with “Zone Valves”. During a demand for central heat, the boiler energizes the System Circulator via the Central Heating (CH) pump output (PUMP C). The System Circulator must be sized to provide adequate circulation throughout the heating system. During a Domestic Hot Water (DHW) demand, the boiler de-energizes the System Circulator (PUMP C) and energizes the DHW Circulator (Pump A). With this configuration the Boiler Circulator is the only pump that causes flow through the boiler and it is powered during any demand via the boiler pump output (PUMP B). This circulator must be sized according to Table 2-4.

NOTICE

The piping configuration described above requires the Central Heating system and DHW system to be de-coupled from the “Primary Loop” via closely spaced tees (Figure 2-3).


Figure 2-3: Multiple System Circulator Configuration - Often used in applications with “Zone Circulators”. This configuration requires the installation of a check valve located at each circulator. During a central heating demand the boiler energizes the Central Heat Circulator via the Central Heat pump out (PUMP C). During a Domestic Hot Water (DHW) demand, the boiler de-energizes PUMP C and energizes the DHW Circulator (Pump A). Both Pump A and C, used in this configuration, are responsible for water flow through the boiler and must be sized according to Table 2-4. Pump output, PUMP B is not used in this configuration.

NOTICE

Figures 2-2 and 2-3 illustrate typical piping systems. These piping schematics do not illustrate all of the required concepts and components required to have a proper installation. Concepts not shown include: prevention of thermal-siphoning (heat traps), isolation valves, drain and purge valves, etc. It is the responsibility of the installing contractor and system designer to determine which system best meets the need of the installation and to consider all aspects of a proper system design. Contractor modifications to these instructions may be required, based upon existing piping and system design.

Figure 2-2 All Models

**Stand Alone Boiler Plumbing Primary/Secondary Loop
(Single System Circulator Configuration)**




LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
---	MAKE-UP WATER		BACKFLOW PREVENTOR		AIR SEPARATOR
---	PRIMARY LOOP		PRESSURE RELIEF VALVE		PUMP
---	CENTRAL HEATING SECONDARY LOOP		PRESSURE REGULATING VALVE		UNION
---	DHW SECONDARY LOOP		DRAIN VALVE		TEE
	ISOLATION VALVE		AIR VENT		FLOW DIRECTION
	ZONE VALVE		EXPANSION TANK		SYSTEM SENSOR
	ZONE LOAD		PRESSURE GAUGE		

Figure 2-3 All Models

Stand Alone Boiler Plumbing Primary/Secondary Loop
(Multiple System Circulator Configuration)



LEGEND					
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
— — —	MAKE-UP WATER		BACKFLOW PREVENTOR		AIR SEPARATOR
— . —	PRIMARY LOOP		PRESSURE RELIEF VALVE		PUMP
— . . —	CENTRAL HEATING SECONDARY LOOP		PRESSURE REGULATING VALVE		UNION
— - - -	DHW SECONDARY LOOP		DRAIN VALVE		TEE
	ISOLATION VALVE		AIR VENT		FLOW DIRECTION
	ZONE VALVE		EXPANSION TANK		SPRING CHECK VALVE
	ZONE LOAD		PRESSURE GAUGE		SYSTEM SENSOR
	THERMOSTATIC MIXING VALVE		OPTIONAL		

Multiple Boiler Applications

The Lx controller has the internal capacity to stage or Lead-Lag up to 8 boilers configured in a cascade. This Lead-Lag capability allows a designated “Master” boiler to communicate with and effectively control each boiler in a multiple boiler system. This function is accomplished by “Daisy Chaining” a 3-wire cable between each of the boilers and enabling the Master parameter in the boiler of your choice. The boiler with the Master parameter enabled becomes the single point of contact for Central Heating, Domestic Hot Water and Outdoor Reset settings and control. Use the instructions detailed in this section to set-up and install the cascade boiler system; reference *Appendix A – Controller and Touchscreen Display Instructions* for details on more advanced settings and for assistance with navigating the touchscreen display.

Lead Lag Instructions - Common

Plumbing – install as many as 8 Lx boilers in parallel in a primary/secondary plumbing configuration as illustrated in Figure 2-4. Size common piping as per Table 2-6.

Boiler Pump – each boiler must have its own circulator (see Figure 2-4) which is controlled by its *PUMP B* output; see *Field Wiring* Figures and Tables 3-1(a) and 3-1(b). The Boiler Pump must be sized according to Table 2-4.

Communication Wiring – using 3-wire cable, daisy-chain terminals *LL DATA +*, *LL DATA –* and *SENSOR COM* of each boiler in parallel; see *Field Wiring* Tables 3-2(a) and 3-2(b) and Figure 3-2.

System Sensor (Optional) – install a system sensor (NTI P/N: 84010) on the outlet (supply) pipe feeding the heating system, see Figure 2-4. Wire the system sensor to *SENSOR COM* and *SYSTEM (OD / SYS SENSOR* for Lx500-800 models) of the Master Boiler; see *Field Wiring* Tables 3-2(a) and 3-2(b) and Figure 3-2. The system sensor automatically becomes the modulation sensor for the boiler system, i.e. the control attempts to achieve setpoint temperature at the location of the sensor. If a system sensor is **NOT** used, at the Master boiler set the applicable sensor input to *Unconfigured* as follows:

Configure – Sensor Configuration – S10 (J10-7) sensor [S5 (J8-11) sensor for Lx500-800 models]

Outdoor Sensor (Optional) – wire the outdoor sensor to *SENSOR COM* and *OD SENSOR (OD / SYS SENSOR* for Lx500-800 models) of any one of the boilers in the cascade (for Lx500-800 models, outdoor sensor must be connected to a non-Master boiler); see *Field Wiring* Tables 3-2(a) and 3-2(b) and Figure 3-2. Note: only one outdoor sensor is needed for the multiple boiler system.

Modbus Address – assign a unique *MB2 Modbus Address* to each boiler in the cascade. Access the *MB2 Modbus Address* setting via the *System Identification & Access* menu as follows:

Configure – System Identification & Access – MB2 Modbus Address


Master Enable – choose **one** (and only one) boiler in the cascade to be the Master, this boiler will receive all control wiring and will be used for setting control parameters (see steps below). On this one boiler, set *Master enable* equal to *Enabled* via the *Lead Lag Master Configuration* menu, accessed as follows:

Configure – Lead Lag Master Configuration – Master enable

Table 2-6 Minimum Pipe Sizes for Multiple Boiler Applications

# of Units	Lx150/150E	Lx200	Lx300	Lx400	Lx500	Lx600	Lx700	Lx800
	Pipe Size	Pipe Size	Pipe Size	Pipe Size	Pipe Size	Pipe Size	Pipe Size	Pipe Size
2	1-1/2"	2"	2"	2-1/2"	2-1/2"	3"	3"	3"
3	2"	2"	2-1/2"	3"	3"	3"	4"	4"
4	2"	2-1/2"	2-1/2"	3"	4"	4"	4"	4"
5	2-1/2"	2-1/2"	3"	4"	4"	4"	4"	5"
6	2-1/2"	3"	3"	4"	4"	4"	5"	5"
7	2-1/2"	3"	4"	4"	4"	5"	5"	5"
8	2-1/2"	3"	4"	4"	5"	5"	5"	5"

Figure 2-4 All Models
Multiple Boiler Lead-Lag Plumbing Configuration



Lead Lag Instructions – Central Heating

Central Heat Demand Switch (Room Thermostat) – connect to *R (24VAC)* and *CH2 (LL)* of the Master Boiler; see *Field Wiring* Tables 3-2(a) and 3-2(b) and Figure 3-2. Switch must be an isolated end switch (dry contact).

Central Heat Setpoint – at the Master boiler only, set the *CH setpoint* via the *Lead Lag Master Configuration* menu, accessed as follows:

Configure – Lead Lag Master Configuration – CH setpoint

Outdoor Reset Settings – at the Master boiler only, set the *Outdoor reset* parameters via the *Lead Lag Master Configuration* menu, accessed as follows:

Configure – Lead Lag Master Configuration – Advanced Settings – Outdoor reset

CH Pump – one boiler in the cascade can be chosen to operate the Central Heating pump via its *PUMP C* output; see *Field Wiring* Figures and Tables 3-1(a) and 3-1(b). From the respective boiler display, check the box next to *Use for Lead Lag Master demands* for the CH Pump to ensure proper pump behavior. Menu access to the CH Pump parameters is as follows:

Configure – Pump Configuration – Central Heat pump – Use for Lead Lag Master demands

Sensor Configuration (Lx500-800 models only) – at the Master boiler only, set the *Outdoor temperature source* equal to *Unconfigured*, via the *Sensor Configuration* menu as follows:

Configure – Sensor Configuration – Outdoor temperature source

Lead Lag Instructions – Domestic Hot Water

Tank Thermostat – connect to *SENSOR COM* and *DHW* of the Master Boiler; see *Field Wiring* Tables 3-2(a) and 3-2(b) and Figure 3-2. Switch must be an isolated end switch (dry contact).

DHW Setpoint – at the Master boiler only, set the *DHW setpoint* via the *Lead Lag Master Configuration* menu, accessed as follows:

Configure – Lead Lag Master Configuration – DHW setpoint

DHW switch (Lead Lag) – at the Master boiler only, set *DHW switch* equal to *DHW (S6) sensor shorted* via the *Lead Lag Master Configuration* menu, accessed as follows:

Configure – Lead Lag Master Configuration – Advanced Settings – Domestic Hot Water – DHW switch

DHW enable (Local) – at the Master boiler only, set *DHW enable* equal to *Disabled* via the *Domestic Hot Water Configuration* menu, accessed as follows:

Configure – Domestic Hot Water Configuration – DHW enable

DHW Pump – one boiler in the cascade can be chosen to operate the DHW pump via its *PUMP A* output; see *Field Wiring* Figures and Tables 3-1(a) and 3-1(b). From the respective boiler display, check the box next to *Use for Lead Lag Master demands* for the DHW Pump to ensure proper pump behavior. Menu access to the DHW Pump parameters is as follows:

Configure – Pump Configuration – DHW pump – Use for Lead Lag Master demands

NOTICE

Tank Sensor – when operating in a cascade system, the boiler controls do not support the use of a tank sensor; a tank thermostat (switch) must be used.

3.0 FIELD WIRING

All wiring must be in accordance with the Canadian Electrical code, CSA C22.2 and any applicable local codes. Ensure that the wiring complies with this manual. The boiler must be electrically grounded in accordance with the National Electrical Code ANSI/NFPA 70, local codes, and/or the Canadian Electrical Code CSA C22.1.

⚠ WARNING

Avoid Shocks - To Avoid Electrical Shock, turn off electrical power to the boiler prior to opening any electrical box within the unit. Ensure the power remains off while any wiring connections are being made. Failure to follow these instructions may result in component failure, serious injury or death.

CAUTION

Field Wiring - Wire grommets must be used to secure wiring and prevent chafing when passing wiring through the cabinet wall. Failure to follow instructions may damage unit.

Line Voltage Connections

Electrical rating for the Trinity Lx is 120V/1 Phase/60 Hz/12A. The Trinity Lx line voltage junction box is located in the lower right corner of the boiler cabinet on models Lx150-200 and can be accessed by removing the front door of the boiler, followed by the removal of the line voltage junction box cover. On Lx300-400 models, the line voltage junction box is located at the top of the boiler cabinet on the right hand side and can be accessed by removing the top front cover of the boiler. On Lx500-800 models, the line voltage junction box is located at the back of the boiler cabinet on the power switch side. Remove the top back cover of the boiler to access the three holes / knockouts needed for routing field wiring into the line voltage junction box. Line voltage field connections are to be installed in accordance with Figures and Tables 3-1(a) and 3-1(b).

Fuses (120VAC) – The Trinity Lx is equipped with either one or two 7 Amp fuses to protect 120VAC system components. The fast-acting fuses are located on the front of the control panel box and can be easily accessed from the outside of the control panel.

Lx150-400 Control Panel:

- Fuse A: Protects the blower, spark generator and PUMP B output circuits.
- Fuse B: Protects PUMP A and PUMP C output circuits.

Lx500-800 Control Panel:

- Fuse A: Protects the 120VAC circuits within the appliance.

Pump Relays (Lx500-800) – In lieu of the 120VAC pump outputs, the Lx500-800 incorporates three non-powered isolation relay contacts for switching high capacity pumps. Contact Secondary Maximum rating is 1.5HP @ 120V, 3.0HP @ 240V, or 30A. Refer to Figure 3-2(b) for Field Wiring requirements.

⚠ WARNING

Wire Protection - When passing any wiring through the cabinet of the boiler, the installer must use wire grommets suitable for securing the wiring and preventing chafing. Failure to follow instructions may result in component failure, serious injury or death.

⚠ WARNING

Power Supply - The Trinity Lx is designed to be powered using a single phase 120VAC power supply that is fused (or protected via a circuit breaker) to allow a maximum of 15 Amps. Failure to follow instructions may result in component failure, serious injury or death.

⚠ CAUTION

Labeling - Label all wires prior to disconnecting them when servicing controls. Wiring errors can cause improper and dangerous operation. Failure to follow instructions may result in property damage or personal injury.

CAUTION

Continuity - Before connecting the line voltage wiring, perform a continuity check between all wires and ground to make sure that there are no electrical leaks that could blow a fuse or damage electrical components. Also check the polarity of the line and neutral wires. Line must measure 120VAC to ground; neutral must measure zero. Failure to follow instructions may damage the unit.

NOTICE

Max Load – Lx150-400 circulator outputs (PUMP A, B, C) are each limited to operating a circulator with a maximum current load of 3 Amps or a maximum 1/6 hp motor. See Table 3-1.

Figure 3-1(a) Lx150-400 Models

Line Voltage Field Wiring




Table 3-1(a) Line Voltage Field Connections (Lx150-400)

Connection	Location	Description
L1 (120VAC)	1	Location for connecting line voltage of the power supply. Note; most installation codes require the installation of a service switch to break line voltage to the appliance.
PUMP A	2	120VAC output to the DHW circulator; powered during a demand for DHW.
PUMP B	3	120VAC output to the Boiler circulator; powered during all demands; DHW, local Central Heat (CH1) and Lead-Lag Central Heat [CH2 (LL)]. This output is not used for all plumbing configurations, see Section 2.0.
PUMP C	4	120VAC output to the Central Heating circulator; powered during a demand for local Central Heat (CH1) or Lead-Lag Central Heat [CH2 (LL)].
L2 (Neutral)	5	Location for connecting neutral of the power supply and all circulators.
	6	
Ground	7	Location for connecting earth ground and for grounding all of the circulators.
	8	
No Conn.	9	This terminal is used only for factory wiring, do not add or remove wires from this location.

Figure 3-1(b) Lx500-800 Model

Line Voltage Field Wiring




Table 3-1(b) Line Voltage Field Connections (Lx500-800)

Connection	Location	Description
L1 (120VAC)	1	Location for connecting line voltage of the power supply. Note, most installation codes require the installation of a service switch to break line voltage to the appliance.
L2 (Neutral)	2	Location for connecting neutral of the power supply.
Ground	3	Location for connecting earth ground.
Non-Powered Dry Contacts	PUMP A	4
		5
	PUMP B	6
		7
	PUMP C	8
		9

Low Voltage Connections

The Trinity Lx low voltage junction box is located in the lower left corner of the boiler cabinet on Lx150-200 models and can be accessed by removing the front door of the boiler, followed by the removal of the low voltage junction box cover. On Lx300-400 models, the low voltage junction box is located at the top of the boiler cabinet on the left hand side and can be accessed by removing the top front cover of the boiler. On Lx500-800 models, the low voltage junction box is located at the back of the boiler cabinet and can be accessed by removing the top back cover of the boiler. Each boiler is provided with one hole and two knockouts for routing field wiring into the low voltage junction box. Low voltage field connections identified in Tables 3-2(a) and 3-2(b) are to be read in conjunction with Figure 3-2.

Table 3-2(a) Low Voltage Field Connections (Lx150-400)

Connection		Location	Description
COM (24VAC)		1	24VAC Common – Neutral for the 24VAC power supply from the boiler. COM can be used in conjunction with terminal R to provide a power source for a digital thermostat.
R (24VAC)		2	24VAC Hot - Power supply for inputs LIM, CH1, and CH2 (LL).
		3	
LIM		4	External Limit – Input requiring 24VAC from terminal R to permit the burner to operate. Comes factory equipped with a jumper to the R terminal. For installations requiring the use of an additional safety switch, such as a LWCO, Flow Switch, or auxiliary temperature limit, remove the factory installed jumper and install the normally open isolated contacts of the additional limit in its place.
CH1		5	Local Central Heat Demand – Input requiring 24VAC from terminal R to initiate a “local” CH call. Switch is made using an isolated end switch (dry contact) via thermostat, zone controller or other device. Typically used as the lone heat input or as the high temperature input in dual CH temperature systems.
CH2 (LL)		6	Lead-Lag Central Heat Demand – Input requiring 24VAC from terminal R to initiate a “lead-lag” CH call. Switch is made using an isolated end switch (dry contact) via thermostat, zone controller or other device. Typically used as a lead-lag input for cascaded boilers or as the low temperature input in dual CH temperature systems.
Sensor	DHW	7	DHW Tank Demand – Input requiring closure of terminals 7 and 10 to initiate a demand for DHW. Switch made via isolated end switch (dry contact) from a thermostat (AquaStat) located in an Indirect Fired Water Heater. Or optional Tank Sensor (P/N 84632), see Appendix A. (NOTICE: tank sensor cannot be used for cascade boiler arrangements).
	OD SENSOR	8	Outdoor Temperature Sensor – A wall mountable OD Sensor is included with each boiler. When connected to terminals 8 and 10, the control will indicate the outdoor temperature and adjust the boiler temperature set point during a Central Heat demand.
	SYSTEM	9	System Water Temperature – An optional strap-on System Sensor is available from NTI (P/N 84010). When connected to terminals 9 and 10, the control will indicate a “CH” or “Lead-Lag” temperature. The control can be set to use the System Sensor as the Modulation Sensor for a CH1 or Lead Lag demand; see Appendix A.
	SENSOR COM	10	System Common – Common port for field inputs DHW, OD Sensor, System Sensor and Communication terminals.
4-20mA		11	External Modulation Control – Using a 4-20mA signal, an external control can be used to directly modulate the burner firing rate or adjust the active set point. This can be useful for applications using external staging controls or Building Automation Systems.
		12	
Communications	LL DATA+	13	Lead-Lag – Connects internally to the controller’s MB2, Modbus communication port. Terminals 13, 14 and 10 (common) can be “daisy-chained” to multiple boilers (up to 8 in total) for the purpose of staging.
	LL DATA–	14	
	BMS D+	15	Building Management System (BMS) – Connects internally to the display’s COM2, Modbus communication port. Terminals 15, 16 and 10 (common) can be connected to a Gateway for communication to a BMS or other device.
	BMS D–	16	
ALARM		17	Normally Open Alarm Contacts – Contacts close during a lockout or other alarm condition. May be connected to a BMS, maximum capacity of 0.63Amps at 24VAC.
		18	

Table 3-2(b) Low Voltage Field Connections (Lx500-800)


Table 3-2(b) Low Voltage Field Connections (Lx500-800)			
Connection		Location	Description
COM (24VAC)		1	24VAC Common – Neutral for the 24VAC power supply from the boiler. COM can be used in conjunction with terminal R to provide a power source for a digital thermostat.
R1/R2 (24VAC)		2	24VAC Hot - Power supply for inputs EXT. LIM, CH1, and CH2 (LL).
		3	
EXT. LIM		4	External Limit – Input requiring 24VAC from terminals R1/R2 to permit the burner to operate. Comes factory equipped with a jumper to the R2 terminal. For installations requiring the use of an additional safety switch, such as a LWCO or auxiliary temperature limit, remove the factory installed jumper and install the normally open isolated contacts of the field supplied additional limit in place of jumper.
GAS LO PR.		5	Gas Low Pressure Switch (Optional) – Comes factory equipped with a jumper. For applications requiring a Low Gas Pressure Switch, remove jumper and connect normally open isolated contacts of the Gas Low Pressure Switch. Switch must be installed external to unit (24VAC circuit). For preapproved High Gas Pressure Switch, see Note 1 below.
		6	
AUX. PROOF		7	Auxiliary Proof – Comes factory equipped with a jumper. For applications using Indoor Combustion Air, remove jumper and replace with field supplied end switch incorporated with motorized damper/louver control.
		8	
CH1		9	Local Central Heat Demand – Input requiring 24VAC from terminal R to initiate a “local” CH call. Switch is made using an isolated end switch (dry contact) via thermostat, zone controller or other device. Typically used as the lone heat input or as the high temperature input in dual CH temperature systems.
CH2 (LL)		10	Lead-Lag Central Heat Demand – Input requiring 24VAC from terminal R to initiate a “lead-lag” CH call. Switch is made using an isolated end switch (dry contact) via thermostat, zone controller or other device. Typically used as a lead-lag input for cascaded boilers or as the low temperature input in dual CH temperature systems.
Sensor	DHW	11	DHW Tank Demand – Input requiring closure of terminals 11 and 14 to initiate a demand for DHW. Switch made via isolated end switch (dry contact) from a thermostat (aquastat) located in an Indirect Fired Water Heater. Or optional Tank Sensor (P/N 84632), see Appendix A. (NOTICE: tank sensor cannot be used for cascade boiler arrangements).
	OD / SYS SENSOR	12	Outdoor Temperature Sensor – A wall mountable OD Sensor is included with each boiler. When connected to terminals 12 and 14, the control will indicate the outdoor temperature and adjust the boiler temperature set point during a Central Heat demand. System Water Temperature – An optional strap-on System Sensor is available from NTI (P/N 84010). When connected to terminals 12 and 14, the control will indicate a “Lead-Lag” temperature. By default, the System Sensor becomes the Modulation Sensor for a Lead Lag demand. NOTICE: only one sensor can be connected to terminal 12 (System OR Outdoor Sensor); see instructions in Appendix A.
	TOD	13	Time of Day (Night Time Setback) – Input requiring closure of terminals 13 and 14 to initiate TOD setback setting. Switch is made using an isolated end switch (dry contact) using a timer, BAS or other device. [TOD applicable to and available on Lx500-800 only]
	SENSOR COM	14	System Common – Common port for field inputs DHW, OD Sensor and System Sensor.
4-20mA (– / +)		15	External Modulation Control – Using a 4-20mA signal, an external control can be used to directly modulate the burner firing rate or adjust the active set point. This can be useful for applications using external staging controls or Building Automation Systems.
		16	
Communications	LL DATA+	17	Lead-Lag – Connects internally to the controller’s MB2, Modbus communication port. Terminals 17, 18 and 14 (common) can be "daisy-chained" to multiple boilers (up to 8 in total) for the purpose of staging.
	LL DATA–	18	
	BMS D+	19	Building Management System (BMS) – Connects internally to the display’s COM2, Modbus communication port. Terminals 19, 20 and 14 (common) can be connected to a Gateway for communication to a BMS or other device.
	BMS D–	20	
ALARM (A&B)		21	Normally Open Alarm Contacts – Contacts close during a lockout or other alarm condition. May be connected to a BMS, maximum capacity of 0.63Amps at 24VAC.
		22	
Notes ¹ For applications requiring a High Gas Pressure Switch, see supplemental instructions included with NTI High Gas Pressure Switch Kit, P/N 84094. Note that this is the only High Gas Pressure Switch that has been tested with the unit and preapproved for field installation within the appliance cabinet.			

CAUTION

Low Voltage Terminals - Terminals 2 and 3 (R) have 24VAC potential from the internal transformer. Do not connect power from these terminals to any other terminal other than terminals 4, 5 and 6 [LIM, CH1, and CH2 (LL)]. Failure to follow these instructions may damage the unit.

NOTICE

Fuse (24VAC) - Trinity Lx150-400 models are equipped with a “blade style” 2 Amp fuse to protect the internal transformer located within the slide-out control panel box.

Figure 3-2 All Models (Lx150-400 shown)**Low Voltage Field Wiring**



NY Thermal Inc. 65 Drury Cove Road Saint John, NB E2H 2Z8 Canada
Technical Assistance: 1-800-688-2575
Website: www.nythermal.com
Fax: 1-506-432-1135