

GE ZONELINE® ARCHITECTS AND ENGINEERS DATA MANUAL

GE Zoneline packaged terminal air conditioners

QUICK REFERENCE

Full Specs on pages 54 and 55

ALL UNITS REQUIRE POWER CONNECTION KIT

Power Connection Kit determines resistance heat output 7000 BTUH units are not offered with 4.7 KW resistance heater

4100 series cooling with electric heat

MODEL NUMBER	VOLTAGE	COOLING (BTUH)	EER	WATTS
47/1F07D4D	208	6900	12.3	560
AZ41E07DAB	230	7200	12.3	580
A 7/1 FOOD A D	208	9600	12.0	795
AZ41E09DAB	230	9700	12.0	805
A7/1F12DAD	208	11500	11.1	1035
AZ41E12DAB	230	11800	11.1	1060
47/1F1FDAD	208	14000	10.3	1350
AZ41E15DAB	230	14300	10.3	1370
AZ41E07EAB	265	7200	12.3	580
AZ41E09EAB	265	9700	12.0	805
AZ41E12EAB	265	11800	11.1	1025
AZ41E15EAB	265	14300	10.3	1385

4100 series cooling with electric heat (corrosion treated models)

MODEL NUMBER	VOLTAGE	COOLING (BTUH)	EER	WATTS
A7/1F07DAC	208	6900	12.3	560
AZ41E07DAC	230	7200	12.3	580
A7/1F00DAC	208	9600	12.0	795
AZ41E09DAC	230	9700	12.0	805
A7/1512DAC	208	11500	11.1	1035
AZ41E12DAC	230	11800	11.1	1060
A741E15DAC	208	14000	10.3	1350
AZ41E15DAC	230	14300	10.3	1370
AZ41E07EAC	265	7200	12.3	580
AZ41E09EAC	265	9700	12.0	805
AZ41E12EAC	265	11800	11.1	1025
AZ41E15EAC	265	14300	10.3	1385

Dry Air 25 4100 series cooling with electric heat

MODEL NUMBER	VOLTAGE	COOLING (BTUH)	EER	WATTS
AZ41E07DAP	208	6300	11.7	535
AZ41EU/DAP	230	6500	11.7	555
A7/1500DAD	208	8800	11.5	765
AZ41E09DAP	230	9200	11.5	790
AZ41E12DAP	208	11000	10.8	1015
AZ41E1ZUAP	230	11200	10.8	1035
AZ41E07EAP	265	6500	11.7	555
AZ41E09EAP	265	9200	11.5	795
AZ41E12EAP	265	11200	10.8	1020



4100 and 6100 Series Control Panel







QUICK REFERENCE

Full Specs on pages 54 and 55

ALL UNITS REQUIRE POWER CONNECTION KIT

Power Connection Kit determines resistance heat output 7000 BTUH units are not offered with 4.7 KW resistance heater

6100 series heat pump with backup electric heat

MODEL NUMBER	VOLTAGE	COOLING (BTUH)	EER	WATTS	HEATING (BTUH)	СОР	WATTS
AZ61H07DAB	208	6900	13.0	525	6100	3.9	445
AZ01HU/DAB	230	7100	13.0	545	6200	3.9	465
A7611100DAD	208	9100	12.2	740	8100	3.7	635
AZ61H09DAB	230	9400	12.2	755	8300	3.7	650
AZ61H12DAB	208	11600	11.6	965	10400	3.6	835
AZOIHIZDAB	230	11700	11.6	985	10600	3.6	855
AZ61H15DAB	208	14200	10.6	1335	13400	3.3	1120
AZOIRISDAD	230	14500	10.6	1360	13500	3.3	1165
AZ61H07EAB	265	7000	12.8	545	6200	3.9	450
AZ61H09EAB	265	9400	12.2	765	8100	3.6	655
AZ61H12EAB	265	11700	11.6	1000	10700	3.6	870
AZ61H15EAB	265	14400	10.6	1355	13500	3.3	1165

6100 series heat pump with backup electric heat (corrosion treated models)

MODEL NUMBER	VOLTAGE	COOLING (BTUH)	EER	WATTS	HEATING (BTUH)	СОР	WATTS
AZ61H07DAC	208	6900	13.0	525	6100	3.9	445
AZ01HU/DAC	230	7100	13.0	545	6200	3.9	465
A7611100DA6	208	9100	12.2	740	8100	3.7	635
AZ61H09DAC	230	9400	12.2	755	8300	3.7	650
AZ61H12DAC	208	11600	11.6	965	10400	3.6	835
AZOIMIZDAC	230	11700	11.6	985	10600	3.6	855
AZ61H15DAC	208	14200	10.6	1330	13400	3.3	1155
AZOIRISDAC	230	14500	10.6	1350	13500	3.3	1190
AZ61H07EAC	265	7000	12.8	545	6200	3.9	450
AZ61H09EAC	265	9400	12.2	765	8100	3.6	655
AZ61H12EAC	265	11700	11.6	1000	10700	3.6	870
AZ61H15EAC	265	14400	10.6	1355	13500	3.3	1165

6100 series heat pump with backup electric heat (models featuring ICR - internal condensate removal)

MODEL NUMBER	VOLTAGE	COOLING (BTUH)	EER	WATTS	HEATING (BTUH)	СОР	WATTS
AZ61H07DAD	208	6900	12.7	530	6100	3.9	440
AZOIHU/DAD	230	7000	12.7	550	6200	3.9	465
AZ61H09DAD	208	9100	11.9	750	8000	3.6	640
AZOIHU9DAD	230	9200	11.9	760	8100	3.6	655
AZ61H12DAD	208	11600	11.4	960	10400	3.6	835
AZOINIZUAU	230	11700	11.4	980	10600	3.6	855
AZ61H15DAD	208	14100	10.4	1330	13400	3.2	1200
AZBIHISDAD	230	14300	10.4	1345	13500	3.2	1200
AZ61H07EAD	265	6900	12.7	540	6200	3.9	455
AZ61H09EAD	265	9200	11.9	760	8200	3.6	665
AZ61H12EAD	265	11700	11.4	1015	10900	3.6	880
AZ61H15EAD	265	14300	10.4	1355	13500	3.2	1210

POWER CONNECTION KITS

230/208-Volt Line-Cord Connection Units

Line Cord Kit	Electric Heat BTUH	Electric Heater Watts	Electric Heat Amps	Min. Circuit Protection (Amps)
RAK3153A	8150/7900	2450/2360	11.0/11.6	15
RAK3203A	11200/10900	3350/3230	15.1/16.0	20
RAK3303A	16000/15450	4750/4580	21.2/22.4	30

Electric Heat Amps include electric heater and fan motor current draw. Each Line-Cord Kit has an integral Leakage Current Detection and Interruption (LCDI) or Arc Fault Current Interrupter (AFCI) device as required by National Electrical Code (NEC) and Underwriters Laboratories (UL) for units manufactured after August 1, 2004.

230/208-Volt Sub-Base and Direct-Connected Units

Sub-Base	Direct Connection Kit	Electric Heat BTUH	Electric Heater Watts	Electric Heat Amps	Min. Circuit Protection (Amps)
RAK204D15P	RAK4157	8150/7900	2450/2360	11.0/11.6	15
RAK204D20P	RAK4207	11200/10900	3350/3230	15.1/16.0	20
RAK204D30P	RAK4307	16000/15450	4750/4580	21.2/22.4	30

Electric Heat Amps include electric heater and fan motor current draw.

Units connected through sub-base do not require an LCDI or AFCI device since they are not considered to be line-cord connected. Each 230/208-volt sub-base kit consists of sub-base with appropriate receptacle for minimum circuit amperage, chaseway to route power connector from sub-base to chassis, wiring to connect sub-base to building wiring and a short line cord with 9-pin connector to connect to chassis and plug into receptacle in sub-base.

Short sub-base line cord may not be used without sub-base. Junction box for 230/208-volt chassis must be purchased separately

RAK4002A for 2900, 3900, 4100, and 6100 series units, RAK4002B for 5800 series units.

265-Volt Sub-Base and Direct-Connected Units

Sub-Base	Power Connection Kit	Direct Connection Kit	Electric Heat BTUH	Electric Heater Watts	Electric Heat Amps	Min. Circuit Protection (Amps)
RAK204E15	RAK5172	RAK5157	8150	2460	9.6	15
RAK204E20	RAK5202	RAK5207	11550	3460	13.3	20
RAK204E30	RAK5302	RAK5307	16350	4860	18.6	30

Electric Heat Amps include electric heater and fan motor current draw.

265-volt units are to be permanently connected in compliance with National Electrical Code and local codes and have a factory-installed junction box on the chassis. Each 265-volt sub-base kit consists of sub-base with appropriate receptacle for minimum circuit amperage, chaseway to route power connector from sub-base to chassis and wiring to connect sub-base to building wiring.

265-Volt Power Connection Kit must be ordered separately

Important

Essential Elements Ordering Overview


230/208-volt line-cord connected units — order line cord kit 230/208-volt sub-base connected units — order sub-base

265-volt units — order sub-base and power connection kit

ZONELINE® CHASSIS NOMENCLATURE

The Zoneline chassis is identified by a model number defining the type of unit, cooling capacity, electrical information and optional features included on the unit. When specifying or ordering the Zoneline chassis, the use of this nomenclature will assure receiving the correct unit.

EXAMPLE



The Zoneline 4100 and 6100 Series have incorporated changes suggested by customers, along with enhancements by GE's Technology Team and changes necessary to meet new UL and NEC requirements. "L" shaped condenser coil.

Cross-flow blower across the product line for quieter operation.

The "Partial Open Vent Air" feature was a specific request by a customer.

"Heat Sentinel" is an enhancement developed by GE's Technology Team to help lodging professionals welcome their guests with a moderate-temperature room and to help lower cooling costs.

Devices have been added on cord-connected units to protect against injury from unsafe power cords.

See the "Features and Benefits" section for in-depth explanation of these changes and the industry-leading features of GE Zoneline retained from the previous series.

The Deluxe 4100 Series Zoneline models include The "Dry Air 25" models, which remove 25% more moisture than other Zoneline models.



Deluxe Dry Air 25 Models Cooling With Resistance Heat

- Removes 25% more moisture than standard Zoneline models
- Cools and dries air in less time than standard Zoneline models
- Dry Air is a separate sealed refrigerant system
 - No mechanical parts No special maintenance required
- Helps maintain lower relative humidity in rooms
- Maintains comfort at slightly higher room temperatures
 - Reduces operating costs Provides comfort without overcooling
- Corrosion treatment is standard
- Excellent choice for humid climates
- Available in 7,000, 9,000 and 12,000 BTU sizes

The Dry Air 25 system, a heat pipe, is a hermetically sealed heat transfer surface installed in a "saddlebag" configuration around the indoor (evaporator) coil of the Zoneline unit. This coil arrangement will transfer heat from the front coil of the saddlebag to the rear coil without power consumption. This assembly uses R-410A as the refrigerant and is not connected to the regular Zoneline refrigerant circuit.

As warm, humid air is pulled through the pre-cool (front) section of the heat pipe, the heat removed from the air is absorbed by the refrigerant, causing the refrigerant to change to a gas and flow to the re-heat (rear) section of the heat pipe. The air leaving the pre-cool section of the heat pipe is cooler and at a higher relative humidity level than the room air. The pre-cooled air is further cooled as it passes through the evaporator, consequently allowing the evaporator coil to remove more moisture.

When the cold air from the evaporator comes in contact with the re-heat section of the heat pipe, the heat that was removed by the pre-cool section is added back to the air and the refrigerant in the heat pipe condenses and flows back to the pre-cool (front) section. The air discharged into the room by this process is much drier, creating a more comfortable room condition.

The Dry Air 25 models center around GE's exclusive use of the patented Dinh® Dehumidifier Heat Pipe from Heat Pipe Technology, Inc. This innovative NASA spin-off technology enables Dry Air 25 to remove 25% more moisture from the air than other leading manufacturers' packaged terminal air conditioners. This helps maintain room comfort at a higher room temperature, reducing operating costs.

The Dry Air 25 keeps a room cool and dry, and this is the most important benefit when it comes to the occupant of the room—hotel guests, apartment residents, students. In a hot, humid climate, getting away from the humidity is just as important as getting away from the heat, and the Dry Air 25 is the perfect solution. The dehumidification of the Dry Air 25 has been verified by the same AHRI test conditions under which standard units are rated.

TABLE OF CONTENTS

Front Cover	1
Mini Specs 4100 and 6100 Series	2–3
Mini Specs Power Connection Kits and Nomenclature	4
The 4100/6100 and Dry Air 25	5
Table of Contents	6
Introduction	7
The Zoneline® System	8
Features and Benefits	
Features Table	9
Features and Benefits	10-12
Auxiliary Control Settings	13-14
Central Desk Control	15
Remote Thermostat Control	16-18
Heat Pumps and Energy Savings	19-20
Installation and Dimensions	
Application Comments	21
Case Dimensions	22
Wall Case/Sub-Base Installation	23-34
Condensate Disposal Systems	35–37
Ducted Installations	38-40
Exterior Grilles	41-42
Product Data	
Electrical Connection	43
Essential Elements Ordering Overview	44
Maximum Connected Load	45
Latent System Capacity	45
Normal Yearly Operating Data	46
Schematics	47–50
Product Specifications	
Suggested Bid Form Specifications	51-52
Zoneline Chassis Nomenclature/Receptacles/Sub-Bases	53
Preliminary Specifications	54-55
Complete Accessory List	56
General Installation Suggestions	57-58
Warranty	58
Alphabetical Index	59
Back Cover	60

Important Notice

Equipment used as a primary source for heating or cooling is an integral part of the building in which it is installed. Proper application is essential for satisfactory performance over a wide range of operating conditions. It is strongly recommended that a professional engineer determine proper application.

If the unit is a replacement unit, its specifications and performance may differ from those of the unit it is replacing. For that reason, we again strongly recommend that a professional engineer determine proper application.

INTRODUCTION

This manual is designed to provide product, performance and application information to our customers and their architects and engineers for use in selection and design of a zonal comfort control system utilizing GE Zoneline Packaged Terminal Air Conditioners (PTAC) and Packaged Terminal Heat Pumps (PTHP). GE Zoneline PTACs and PTHPs are self-contained units designed for through-the-wall installations in hotels, motels, apartments, hospitals, nursing homes, add-on rooms and many other installations.

Zoneline units provide individual room or zone control in both cooling and heating operation. There is a model for practically every application, ranging in cooling capacity from 7,200 to 14,500 BTUH and heating capacity from 6,200 to 13,500 BTUH in heat pump operation. See pages 42 and 52 for resistance heaters available.

The *Deluxe Line* consists of the 4100 Series with electric resistance heat, the 4100 Series Dry Air 25 Models with enhanced dehumidification for hot and humid climates and the 6100 Series heat pump. The 6100 Series heat pump features reverse-cycle defrost and simultaneous supplemental resistance heat, when needed, to maintain room comfort. Both offer tactile touch controls with digital display and optional corrosion protection.

Deluxe Line Standard Features:

- Two-fan-motor system with indoor cross-flow blower for quieter operation
- Digital Controls
 - —LED Temperature Display
 - -Easy Temperature Selection
 - —Tactile Touch Pad
- Universal Heaters
- Heat Sentinel
- "L" Coil Design Condenser
- 3-Position Vent Door
- Freeze Sentinel
- Indoor Coil Frost Control
- Central Desk Control Interface
- Remote Thermostat Control Interface
- Random Restart
- Electronic Temperature Limiting
- "Smart Fan" Fan Cycle/Continuous Control
- Transfer Fan Interface
- Reverse Cycle Defrost and Simultaneous Supplemental Resistance Heat on Heat Pumps
- Quick Heat Recovery

Deluxe Line Optional Features:

- Corrosion Protection
- Internal Condensate Removal (on 6100 Series Heat Pump without Corrosion Protection)

NOTE: Dry Air 25 models include all the standard features of the 4100 Series plus standard corrosion protection.

Advantages of the GE Zoneline System:

- Flexible Application
 - –May be installed from flush to finished floor, to 3" from the ceiling
 - -7,200 to 14,500 BTUH units in same physical size
 - —Deluxe 4100 and 6100 Series may be ducted to condition more than one room
 - —Compatible with Class 2 remote thermostat control
 - —Compatible with 2-wire CDC or many Energy Management Systems
- Economical Installation
 - -No ductwork necessary
 - No mechanical equipment rooms or pipes required for heating/cooling units
 - Replacement units fit existing 42"-wide by 16"-high wall cases
- Quiet Operation
 - -Indoor cross-flow blower
- Energy-Saving Operation
 - -Units in unoccupied areas may be turned off
 - Designed for efficient cooling operation EERs from 10.3 to 13.0
 - -Efficient heat pump units COPs from 3.3 to 3.9
 - Extended heat pump operation without sacrificing room comfort
- Ease of Maintenance
 - -Permanently lubricated fan motors
 - —Upfront lift-out interchangeable filters
 - —Slide-out chassis for easy access for cleaning or if service is required
- Reverse Cycle Heat Pump Operation


The 6100 Series heat pumps utilize the unique GE PTAC heat pump operation to ensure a comfortable room. The logic used by the units is the same logic used by central system heat pumps to provide greater savings.

THE ZONELINE® SYSTEM

The typical Zoneline installation consists of the wall case (or sleeve), chassis, power cord and exterior grille. Some installations may use a sub-base for support of the unit or for ease of electrical connections. Each of the components should be the standard products offered by GE, or, in the case of the exterior grille, approved by GE Applications Engineering. Use of components not specifically designed or approved for use with the Zoneline unit can result in unsatisfactory operation and can be the cause of failure not covered by the warranty.

Components of the Zoneline System

Typical Installation (Deluxe Series shown)



Optional Accessories of the Zoneline System



RAK204D20P Sub-Base (shown)



Power Supply Cord (included with certain 208V/230V sub-bases)



RAK6052 Duct Adapter



RAK601/602 Duct Extension, Register and Trim Flange

ZONELINE FEATURES

	Resista	Heat pump	
	AZ	AZ	AZ
	41 Series	41 Dry Air 25	61 Series
Cooling EER range (230 Volts/265 Volts)	10.6 - 12.8	11.3 - 12.2	10.8 - 13.2
Heating COP range (230 Volts/265 Volts)	N/A	N/A	3.3 - 4.0
Refrigerant type	R-410A	R-410A	R-410A
Cross-flow (tangential) blower	Standard	Standard	Standard
Enhanced dehumidification	Optional	Standard	_
Heat pump with resistance heat back-up	_	_	Standard
Heat pump with supplemental resistance heat	_	_	Standard
Staged heating	_	_	3-Stage***
Universal heaters - UPC**	Standard	Standard	Standard
Tactile touch-pad controls with LED	Standard	Standard	Standard
Touch control set-up features	Standard	Standard	Standard
Highly featured microcomputer controls	Standard	Standard	Standard
Electric resistance heat lock-out (above 46°F)	<u> </u>	_	Standard
Automatic emergency heat	Standard	Standard	Standard
Heat pump defrost system	_	_	Reverse cycle
High-temperature operation protection	_	_	Standard
Quick heat recovery	_	_	Standard
Heat boost	_	_	Selectable
Separate indoor & outdoor	AC	AC	DC
motors — permanently lubricated			
2-speed outdoor fan	Standard	Standard	Standard
Indoor fan speed settings	Hi/Low	Hi/Low	Hi/Low
"Fan Only" setting—2-speed	Hi/Low	Hi/Low	Hi/Low
"Cool & Heat Only" settings	Hi/Low/Auto	Hi/Low/Auto	Hi/Low/Auto
"SmartFan" fan cycle control	Standard	Standard	Standard
Auto power recovery	Standard	Standard	Standard
Automatic compressor restart delay	Standard	Standard	Standard
Freeze Sentinel (41F)	Standard	Standard	Standard
Heat Sentinel (85F)	Standard	Standard	Standard
Automatic indoor frost control	Standard	Standard	Standard
Temperature limiting	Electronic 7-step	Electronic 7-step	Electronic 7-step
Solid-state thermostat	Standard	Standard	Standard
Remote thermostat compatibility	Standard	Standard	Standard
Central Desk Control compatibility	Standard	Standard	Standard
2-position discharge grille 50°/40°	Standard	Standard	Standard
Upfront filter (interchangeable)	Standard	Standard	Standard
3-position manual air vent control	Standard	Standard	Standard
Sleep function	Standard	Standard	Standard
Transfer fan connections	Standard	Standard	Standard
Ducted installation capability	Optional	Optional	Optional
Corrosion-treated chassis	Optional	Standard	Optional
Internal condensate removal (ICR)*	_	_	Optional

^{*}Not for use in corrosive environments

**UPC — Universal Power Cord Connection (see pages 43 and 53).

*** Two-stage heating if using remote thermostat

265-volt units must be connected in a manner to meet National Electrical Code and all local codes.

FEATURES AND BENEFITS

Standard Physical Dimensions

GE has maintained the same dimensions since 1961 — 42" wide x 16" high x 13-3/4" deep — making replacement of older units easy.

Weather-Protected Electrical Components

Vital electrical components are protected from the weather by locating them on the indoor side of the weather barrier.

Weather-Resistant "Superseal"

Properly installed unit in undistorted case keeps air leakage to a minimum.

7 CFM air infiltration with 25 MPH wind on ICR units — even less on units without ICR

Industry specification is 19 CFM of air infiltration

Heater Sizes to Meet Room Requirements

All units are equipped with a universal heater—the resistance heat output is determined by power connection kit.

230/208-volt — Line-Cord Connected Units — 2.4/2.32 KW with RAK3153A — 15-amp circuit 3.3/3.20 KW with RAK3203A — 20-amp circuit

4.7/4.53 KW with RAK3303A — 30-amp circuit

230/208-volt - Sub-Base Connected Units —

2.4/2.32 KW with RAK204D15P — 15-amp circuit 3.3/3.20 KW with RAK204D20P — 20-amp circuit 4.7/4.53 KW with RAK204D30P — 30-amp circuit

265-volt -

2.4 KW with RAK5172 — 15-amp circuit 3.4 KW with RAK5202 — 20-amp circuit 4.8 KW with RAK5302 — 30-amp circuit

Unit Controls

4100 and 6100 Series — touch pad controls with digital readout of temperature set point

Highly Featured Microprocessor Controls

Microprocessor controls are programmed to interface with the temperature sensors to maximize comfort conditions for the room occupant and provide outstanding features.

Thermistors are used to sense small changes in temperature to give excellent room control and allow the microprocessor to monitor and react to changing conditions.

Electric Resistance Heat Lock-Out

To maximize the savings of the heat pump operation, the Zoneline® heat pumps do not utilize the resistance heater when the outdoor temperature is above 46°F during normal operation. The resistance heat is used in the Quick Heat Recovery feature.

Automatic Emergency Heat

Automatically uses electric resistance heat if the heat pump output is not sufficient to maintain selected room temperature.

Reverse Cycle Heat Pump Defrost System

Standard on all Zoneline 6100 Series heat pumps

Enables heat pump to operate at lower temperatures when other systems switch to more expensive electric resistance heat.

See pages 18 and 19 for discussion of heat pump operation and defrost systems.

High-Temperature Heat Pump Operation Protection

Automatically protects the compressor if heat pump is operated with high outdoor temperatures.

Power to the outdoor fan is turned off if the indoor coil gets too hot during heat pump operation to prevent damage to the compressor.

Quick Heat Recovery – Heat Pump Units

When the unit operation is changed from STOP or COOL to HEAT, the electric resistance heaters are used to warm the room to the thermostat set point. This provides faster room temperature increase for greater guest comfort.

Fan Motors – Permanently Lubricated

All units have two fan motors for quiet operation and maximum operating efficiency.

Motors are permanently lubricated to reduce maintenance and totally enclosed to keep dirt and water out of the motor windings.

Outdoor Fan

The unit automatically selects the most efficient speed for the outdoor fan. The operating sound level is lower when the outdoor fan can operate in low speed, yet there are situations where it must operate in high speed. The unit changes the fan speed automatically.

Indoor Fan Speed Selections - HIGH/LOW

Unit may be operated in HIGH HEAT or LOW HEAT or HIGH COOL or LOW COOL.

FEATURES AND BENEFITS (cont)

Fan-Only Setting - HIGH/LOW

The unit provides the option of selecting either HIGH or LOW speed for Fan-Only operation.

Fan-Cycle Switch – "SmartFan"

Unique "SmartFan" allows unit to operate fan continuously in cooling operation and fan cycle in heating to provide better guest comfort. Eliminates complaint of cold-air draft during the heating season.

Eliminates the need for changing fan-cycle switch seasonally. "SmartFan" settings are controlled via the auxiliary control setting push button.

Compressor Random Restart

In the event of a power failure, all compressors attempting to restart immediately when power is restored can result in a power surge that can cause another power interruption.

The microprocessors in the Zoneline units have a random restart logic system that prevents all units from starting at the same time.

Rotary Compressor

Provides smoother operation for quiet, dependable service. GE has used rotary compressors since 1961.

Compressor Restart Delay

Zoneline units are designed to provide a minimum of three minutes of compressor-off time to allow refrigerant pressures to equalize before restarting to prevent compressor damage.

Zoneline units are also designed to provide a minimum of three minutes of compressor-run time to prevent room occupant disturbance due to short-cycling of the air conditioner.

Freeze Sentinel

Detects low room temperature and turns on heater to help protect against damage caused by freezing room temperature.


Heater turns on at 41°F and warms indoor thermistor temperature to 46°F and shuts off.

Freeze Sentinel may be turned off by dip switch on auxiliary control.

Heat Sentinel

The property owner may choose to activate the Heat Sentinel feature on the Zoneline unit. If the Heat Sentinel is activated and room temperature reaches 85°F (even when the unit is in the "STOP" setting), the unit will automatically start in air conditioning operation and will shut off when the room temperature reaches 80°F. This will help dehumidify the air and lower high temperatures so the guest will not be entering an extremely hot room.

Indoor Coil Frost Control



Prevents indoor coil from freezing and causing complaints due to lack of cooling. Frost can form on the indoor coil when the unit is operated in cooling when outdoor temperatures are low. The unit automatically shuts the compressor off until the indoor coil temperature warms to the point where frosting will no longer occur.

Transfer Fan Interface

24 VAC terminals are provided to operate a relay to control a fan mounted in a wall to move conditioned air into another space. The electrical power for the operation of the transfer fan itself is not provided by the Zoneline unit. Transfer fans and their controlling relays are field supplied.

Electronic Temperature Limiting

Seven independent programmable heating temperature limits and seven independent programmable cooling temperature limits.

	Highest Heat										
65	70	70 72 74 76 78 80									
Lowest Cool	Cooling Temperature Limits										
60	64	66	68	70	72	74	76				

Limits are set via the auxiliary control setting push button.

Remote Control Capability with Wall-Mounted Thermostat

See pages 16-18.

Central Desk Control Capability

See page 15.

Energy Management System Interface with Load-Shedding Option

All units have a switch via the auxiliary control setting to allow the indoor fan to continue operating if the unit is connected to an energy management system that shuts off compressor or heater operation. By allowing the indoor fan to run when the heater or compressor is shut off by the energy management system, the guest is less likely to realize the operation of the unit has been altered. This helps reduce peak energy demand loads without disturbing the room occupant.

Reversible Indoor Air Louvers

Allows air to be directed into room at 40° or 50° angle to provide better air distribution.

Angle is changed by removing room front and screws holding louver in place, and rotating louver section.

FEATURES AND BENEFITS (cont)



Up-Front Air Filters

Two interchangeable up-front filters, easy to remove and reinstall, may be cleaned without opening or removing the room front.

Clean filters by brushing, vacuuming or backflushing under faucet or shower head.

Concealed Manual Vent Control

Open ventilation doors on GE Zoneline® Packaged Terminal Air Conditioners and Heat Pumps allow



outside air to enter the room through a screen-covered opening in the weather barrier that separates the indoor and outdoor sections of the unit.

A concealed lever, located along the left side of the unit under the front cover, is used to open and close the vent door.

The 3-position manual vent door control may be closed, partially open or fully open. Positive vent door closure prevents accidental opening and unwanted air infiltration.

Vent CFM High Speed

Unit	Full Open	Partial Open
7000	50	40
9000	70	45
12000	75	45
15000	75	45

CFM ratings at 230 and 265 volts.

For each CFM of air to enter the room, an equal amount of air must be removed through exhaust fans in the bathroom or roof tops. Greater amounts of air will be introduced (from chart shown above) depending on the size of the exhaust fan.

Outside ambient air entering the room through this screened vent opening is <u>not</u> conditioned. This unconditioned air becomes mixed with the conditioned air that is circulated by the indoor fan. This air mixture generates an additional heat load/heat loss that causes the unit to run longer and may translate into higher operating costs.

Zoneline vent openings are not intended to be the source of make-up air for building ventilation systems due to the additional heating or cooling loads generated.

Corrosion Protection (Optional)

4100 and 6100 Series units may be ordered with special protection to better withstand damage from salt air and salt water in seacoast or other corrosive areas.

Corrosion protection is standard on the Dry Air 25 models.

Heat pump units with ICR are not available with corrosion protection and should not be installed in seacoast or other corrosive environments.

Units installed in corrosive areas should use the RAB77 wall sleeve and be examined/cleaned more frequently than normal installations.

Internal Condensate Removal (ICR)

See page 35 for a discussion of the Internal Condensate Removal system available on 6100 Series heat pumps.

Enhanced Dehumidification

Moisture removal is an important function of an air conditioner. People are more comfortable at higher temperatures when the humidity level is relatively low. Air conditioners operate with less energy consumption when the room temperatures are set higher.

The GE Zoneline 4100 Series with the Dry Air 25 heat pipe application removes 25% more moisture than the base 4100 Series unit.

The GE Zoneline Dry Air 25 chassis is the only PTAC available with the application of the patented Dinh® Dehumidifier Heat Pipe under license from Heat Pipe Technology, Inc.

Customers who are using the Dry Air 25 report a freshersmelling room as a result of the lower humidity levels, as well as lower operating costs.

Locking Door Kit


RAK8023 — A door with a lock that replaces the standard control cover door to prevent unauthorized changing of control settings is offered as an accessory.

AUXILIARY CONTROL—AUX SET BUTTON

The auxiliary control push button is located behind the room cabinet, below the control panel. The auxiliary controls come preset to the modes most desired by customers. However, the owner is responsible for ensuring the auxiliary controls are set to the desired function. There are 9 different modes that can be set using the auxiliary set button.

To change modes:

- Press the STOP button.
- Press AUX SET ("AU" appears on the display).
- Press the MODE button on the control pad until the first digit in the display shows the number corresponding to the mode you are choosing and the correct HEAT/COOL LED is lit.
- Press the UP or DOWN arrow to change the mode setting selection (second digit in the display).
- Press the MODE button to move to the next feature or the AUX SET button to exit the set up process.



Press "AUX SET"		
First Digit	Second Digit	
Press "Mode"	Press ▲ / ▼	
Smart Fan		
Load Shedding		
Sentinel HEAT COO		
Constant Fan		
Temperature Limit HEAT		
Class 2 Mode		
Duct Mode	-	
All I2R Mode (AZ61 Only)		
Boost Heat (AZ61 Only)		

AUXILIARY CONTROL SETTINGS

*Note: In cyclic Cooling Mode, the indoor fan will activate occasionally to verify air temperature in the room. In cyclic Heating Mode, the fan will continue to operate for 90 seconds after the heating function has stopped in order to increase unit efficiency.

Mode 2—Load Shedding (Central Desk Control)

The default setting for Mode 2 is OFF.

This feature is active only if the unit is connected to a CDC and the CDC has control. When this mode is on, only the indoor fan can be turned ON or OFF with the unit controls. When this mode is off, all operation is disabled except Heat/Freeze Sentinel (Mode 3).

Press "SET"	I	
First Digit	Second Digit	
R	H	
Press "Mode"	Press ▲ / ▼	
	Smart Fan Cool – Cycle*	
HEAT COOL	Smart Fan Cool – Continue	
Press "Mode"	Press ▲ / ▼	
	Smart Fan Heat – Cycle*	
HEAT COOL	Smart Fan Heat – Continue	
Press "Mode"	Press ▲ / ▼	
3	Load Shedding – Off	
	Load Shedding - On	

AUXILIARY CONTROL SETTINGS (cont)

Mode 3—Freeze Sentinel/Heat Sentinel The default settings for Mode 3 are: Heat Sentinel is off	Press "Mode"	Press ▲ / ▼ Freeze Sentinel – Off
Freeze Sentinel is on. When Freeze Sentinel is activated, it automatically provides	HEAT COOL	Freeze Sentinel – On
heat without user interface. This helps to prevent plumbing damage by turning the heater and indoor fan ON at 41°F and OFF at 46°F.	Press "Mode"	Press ▲ / ▼
When Heat Sentinel is activated, it automatically provides cooling without user interface. This helps to prevent an	3	Heat Sentinel – Off
excessively hot room by turning the air conditioner ON at 85°F and OFF at 80°F.	HEAT COOL	Heat Sentinel – On
NOTE: These functions are active whenever the unit is plugged in, even if the unit is in the STOP position.	Press "Mode"	Press ▲ / ▼ Constant Fan – Off
Mode 4—Constant ON Fan The default setting for Mode 4 is OFF.		Constant Fan – On
Mode 5—Temperature Limiting ————————————————————————————————————	Press "Mode"	Press ▲ / ▼
Heat: 5 (60°F to 78°F)	5	Temperature Limit Cool 0: 60F-85F 1: 64F-85F 2: 66F-85F
Temperature limits—CoolTemperature limits—Heat $0 = 60^{\circ}F$ to $85^{\circ}F$ $0 = 60^{\circ}F$ to $65^{\circ}F$ $1 = 64^{\circ}F$ to $85^{\circ}F$ $1 = 60^{\circ}F$ to $70^{\circ}F$	HEAT COOL	3: 68F-85F 4: 70F-85F 5: 72F-85F 6: 74F-85F 7: 76F-85F
$2 = 66^{\circ}F \text{ to } 85^{\circ}F$ $2 = 60^{\circ}F \text{ to } 72^{\circ}F$ $3 = 68^{\circ}F \text{ to } 85^{\circ}F$ $3 = 60^{\circ}F \text{ to } 74^{\circ}F$ $4 = 70^{\circ}F \text{ to } 85^{\circ}F$ $4 = 60^{\circ}F \text{ to } 76^{\circ}F$	Press "Mode"	Press ▲ / ▼ Temperature Limit Heat
4 = 70°F to 85°F		0: 60F-65F 1: 60F-70F 2: 60F-72F 3: 60F-74F 4: 60F-76F
7 = 76°F to 85°F	HEAT COOL	4. 60F-76F 5: 60F-78F 6: 60F-80F 7: 60F-85F
The default setting for Mode 6 is OFF. Setting this mode to ON will allow the unit to operate with a Class 2 Remote Control Wall Thermostat.	Press "Mode"	Press ▲ / ▼ Class 2 Mode – Off
Mode 7—Duct Mode		Class 2 Mode – On
This setting is used when the unit is installed using a duct adapter kit. If the unit is ducted, the Duct Mode needs to be set to ON. This increases the fan speed to	Press "Mode"	Press ▲ / ▼ Duct Mode – Off
ensure proper circulation. Mode 8—All-Electric Heat (AZ6100 only)		Duct Mode – On
The default setting for Mode 8 is OFF. This electric heat option functions only on the 6100 model. When this option is ON, heat pump operation is locked out, causing the unit to provide only electric resistance heat.	Press "Mode"	Press ▲ / ▼ ALL 12R Mode – Off
Mode 9—Heat Boost (AZ6100 only)		ALL 12R Mode – On
The default setting for Mode 9 is OFF. When Heat Boost is ON and outer temperatures are between 25°F and 46°F, heat pump-only operation is locked out. This setting is used to provide supplementary heat to the	Press "Mode"	Press ▲ / ▼ Boost Heat – Off
heat pump operation by electric resistance heat in conditions where the heat pump-only operation is not sufficient to maintain a consistent, comfortable room temperature.		Boost Heat – On
NOTE: Heat Boost option should NOT be used with remote thermostat operation. This will cause the unit to switch to		
resistance heat when the outdoor temperature is 46°F		

resistance heat when the outdoor temperature is $46^{\circ}F$.

CENTRAL DESK CONTROL

Some installations may want to govern the ability of the unit to operate from a control device remote to the unit or even remote to the room in which the unit is located. The general term given to systems such as this is Central Desk Control (CDC). The most common installation of this type of system is a switch mounted at the registration desk and, upon guest check-in, a button is pushed or a switch is moved to allow the air conditioner to operate. Likewise, when the guest checks out, the device is put into the "OFF" position so the unit will not operate while the room is vacant.

It is not necessary that the controlling device be located at a central desk to employ a device that will control the unit operation. For instance, in some resort areas, devices are connected to sliding glass doors and opening the door causes a contact to close, turning the air conditioner off. This prevents energy being wasted by operating the air conditioner when warm, humid air is entering the room. Some systems operate by motion sensors or heat-sensing detectors mounted in the room. These types of systems determine occupant presence in the room and allow the unit to operate; if no one is in the room the device signals the air conditioner to turn off.

Zoneline® models offer load-shedding capabilities on units connected to Central Desk Control systems. For more information on the models' load-shedding feature, see page 11.

There is a wide variety of devices available, each with its own benefits and constraints. While GE does not offer components that are external to the unit for a Central Desk Control system, GE Zoneline units are compatible with most CDC and energy management systems. Zoneline units provide a 24 VAC circuit that powers the Central Desk Control system and no external power is needed.

All Zoneline 4100 and 6100 Series units are compatible with simple on/off 2-wire Central Desk Control systems. Consult with the provider of the energy management system to be sure it is compatible with GE Zoneline units. Zoneline units have standard connectors factory-installed to provide a CDC interface that permits the unit to be connected to most of the energy management systems. The devices connected to the Zoneline units require no power supply or transformers external to the unit.

Important CDC Comments (all series applicable)

- 1. When the switching device closes the circuit of the CDC conductors, the unit operation stops.
- 2. Do not use a common bus (at the unit or at the switch panel) in the wiring. Both wires comprising the circuit must connect to the unit connectors and to the controlling switch. Running one wire from one unit to another unit is common busing and may damage internal components or cause erratic operation of the system.
- 3. A 24-volt transformer is contained within the Zoneline unit. No external voltage may be applied to the unit through the CDC terminals. (Voltage on the CDC conductors is 24 volts AC.)

4. Recommended wire size must be followed as a minimum requirement.

Wire Size #AWG	Maximum Allowable Length
#22	600 Ft.
#20	900 Ft.
#18	1500 Ft.
#16	2000 Ft.


Freeze Sentinel and Heat Sentinel remain operational when the unit is connected to a CDC system. Even if the unit is turned "OFF" at the central location, if the sensor at the unit detects the low or high limit temperature, the unit will automatically turn on until it reaches the preset shutdown temperature (46°F heating, 80°F cooling).

Connecting the Zoneline unit to a CDC system does not eliminate the ability to connect the unit to a remote thermostat. Once the circuit is "opened," and control of the unit removed from the CDC system, the selected controls—either the unit-mounted control or the remote thermostat—govern the operation of the unit.

Please see page 57 for installation recommendations for the Central Desk Control wiring.

CDC Terminal Location and Typical Wiring

See page 16 for location of CDC terminals on unit.



REMOTE THERMOSTAT CONTROL

In some installations, control of the operation of the unit at a location remote from the unit itself may be desired. A unit mounted high in the wall or over a door, for instance, where the unit-mounted controls are inaccessible, can be connected to a wall-mounted thermostat. Other installations may use remote thermostat control for design or performance enhancement. The unit is connected to the thermostat by low-voltage wiring which permits the operation of the unit to be selected and the temperature sensed at the thermostat.

Important Notes: Remote thermostat wiring should NOT be run through the wall case. Thermostat wiring should exit the wall below the unit and enter the unit between room cabinet and chassis. Wire molding may be used to hide thermostat wiring. If a sub-base is used, the thermostat wiring may be concealed by the sub-base. Thermostat wiring should NOT be run parallel to line voltage wires since induced current may cause erratic operation.


All Zoneline® 4100 and 6100 Series units are adaptable to Class 2 remote low-voltage thermostats. The only additional field-supplied components are the remote thermostat and wiring necessary to connect it.

The controls on the unit are not functional when the remote control function is used.

RAK806 Universal Control Cover Label

When a Zoneline unit is using a remote thermostat control,

the RAK806 Universal Control Cover Label is recommended. The RAK806 is only available in a package of 10 labels. The label is placed over the control panel to direct the user to the wall thermostat for operation of the Zoneline unit.



Resistance Heat Models

The Zoneline 4100 resistance heat units may be connected to a single-stage thermostat designed for use with cooling with electric heat systems. GE offers two thermostats compatible with the 4100 Series unit.



RAK164D2 a solid-state digital thermostat requiring five connection wires.



RAK164P2 — a solid-state digital

programmable thermostat requiring five connection wires. The remote thermostat-Class 2 option (Mode 6 in the auxiliary control setting) must be turned ON to enable remote thermostat control. Refer to installation instructions packaged with the chassis.

Please see page 57 for installation recommendations for the remote thermostat wiring. Compatibility of other thermostats considered for use with GE Zoneline units is the responsibility of the customer.

The control voltage on the remote control conductors is 24 volts AC. The AC voltage may not be compatible with some solid-state thermostats.

The *fan speed* for the 4100 Series in remote thermostat operation is selected by the connection of the fan wire from the thermostat to either the HIGH or LOW terminal on the unit. See the sketch of the unit terminals below for the location of the HIGH and LOW fan-speed terminals. Operating the unit in low fan speed reduces the operating sound level of the unit.

Freeze Sentinel and Heat Sentinel remain operational if the unit is connected to a remote thermostat. The unit may be connected to a Central Desk Control (CDC) system and controlled with a remote thermostat when the CDC system has the unit in operation. See page 15 for additional information on the CDC system.

Unit temperature-limiting settings are not functional when unit is connected to a remote thermostat.

Field Wiring Terminal

R - 24V AC

GL — Low-Speed Fan


GH — High-Speed Fan

B — Not Used on 4100

Y — Compressor

W — Heater

C — Common



REMOTE THERMOSTAT CONTROL (cont)

Heat Pump Models

The Zoneline 6100 Series heat pump units may be connected to a single-stage cooling/two-stage heating thermostat designed for use with heat pump systems. GE offers two thermostats compatible with the 6100 series units:





RAK148D2 solid-state digital thermostat requiring six connection wires.

RAK148P2 solid-state digital programmable thermostat requiring six connection wires.

Please see page 57 for installation recommendations for the remote thermostat wiring. Compatibility of other thermostats considered for use with the GE Zoneline unit is the responsibility of the customer.


The control voltage on the remote control conductors is 24 VAC. The remote thermostat-Class 2 option (Mode 6 in the auxiliary control setting) must be turned ON to enable remote thermostat control. Refer to installation instructions packaged with the chassis.

The *fan speed* for the 6100 Series in remote thermostat operation is selected by the connection of the fan wire from the thermostat to either the HIGH or LOW terminal on the unit. See the sketch of the unit terminals for the location of the HIGH and LOW fan speed terminals. Operating the unit in low fan speed reduces the operating sound level of the unit.

Field Wiring Terminal

R — 24V AC GL — Low-Speed Fan GH — High-Speed Fan B — Reversing Valve Y — Compressor W — Heater

C — Common



Feature	Heat Pump	Electric Heat
Indoor frost control	Yes	Yes
Freeze Sentinel	Yes	Yes
Heat Sentinel	Yes	Yes
Auto fan speed	No	No
Electronic temperature limiting	No	No
Switch to resistance heat based on indoor temperature	Determined by remote thermostat	N/A
Switch to resistance heat based on outdoor temperature	Yes	N/A
Reverse cycle defrost	Yes	N/A
Simultaneous resistance heat with heat pump	No	N/A
Resistance heat lockout	Yes	N/A
"Smart Fan" fan cycle	Fan ON/AUTO set on remote thermostat	Fan ON/AUTO set on remote thermostat
Central Desk Control	Yes	Yes

When connected to a remote thermostat, indoor air-temperature sensing is shifted from the unit to the remote thermostat. For this reason, the units will operate slightly differently when connected to a remote thermostat. The above chart shows the unit operation when connected to a remote thermostat.

The Heat Boost option should NOT be used with remote thermostat operation since this will cause the unit to switch to resistance heat when outdoor temperatures are below 46°F.

REMOTE THERMOSTAT CONTROL (cont)

Remote Thermostat Control Selection Chart For Zoneline® Packaged Terminal Units

Zoneline Series	Thermostat Model	Туре	Function	Low-Voltage Conductors
4100	RAK164D2	Digital	Carling on and the ations	5
	RAK164P2	Digital Programmable	Cooling and Heating	5
6100	RAK148D2	Digital	Single-Stage Cooling –	6
	RAK148P2	Digital Programmable	2-Stage Heating	6

Thermostat wire size - up to 60 feet AWG20 - up to 66 feet AWG18

For remote thermostat operation follow the steps below:

- 1. Turn on the unit and ensure it is working properly BEFORE proceeding.
- 2. Unplug the unit or disconnect power and remove the room cover.
- 3. Connect the thermostat wiring per the appropriate diagram/colors for your model.
- 4. Plug the unit back in or reconnect power.
- 5. Press the AUX SET button once. The letters AU will appear in the display.
- 6. Press the MODE button until the number "6" appears in the left hand digit.
- 7. Press the UP arrow once so the top half of the right hand digit is lit.
- 8. Press the AUX SET button to exit the setup function.
- 9. Replace the room cover.

See pages 13 and 14 for full instructions on using the $\mbox{\sc Auxiliary}$ Controls Feature.

HEAT PUMPS AND ENERGY SAVINGS

 GE Zoneline heat pumps are designed to provide cost-efficient heat pump operation while monitoring room conditions to maintain comfort.

The units employ a logic system monitoring both outdoor and indoor temperatures to determine the heat source, thus increasing energy savings by operating longer in the heat pump mode.

Heat pumps save energy and cost less to operate than units with electric resistance heaters as the only heat source. Just as the EER of an air conditioner is an indication of the efficiency of the unit, COP (Coefficient of Performance) is the indication of the efficiency of the heat pump. This relative efficiency of a heat pump compares the unit to electric resistance heat. If a unit has a COP of 3.0, it means the unit will produce three times as much heat at rating conditions for the same electrical input wattage used for electric resistance heat.

The compressor is used in heat pump operation just as in air conditioning operation. In heat pump operation, the hot refrigerant gas is directed to the indoor coil rather than to the outdoor coil. Room air that circulates over the indoor coil gains heat from the coil rather than losing heat to the coil as during cooling operation.

As the outdoor temperature falls, the heat pump cannot extract as much heat from the outdoor air to raise the temperature of the indoor air. For this reason, all packaged terminal heat pumps also have electric resistance heaters as backup to heat pump operation. At some point, the heat pump is unable to provide sufficient heat to adequately warm the room. Many Packaged Terminal Heat Pumps cease heat pump operation and change to more expensive resistance heat at some pre-determined outdoor temperature to compensate for the inability of the heat pump to maintain room temperature. This point, called the "switchover point," is usually at an outdoor temperature where savings from heat pump operation may still be realized if the unit is designed to maintain room comfort at the lower outdoor temperatures.

Balance Point

An important consideration in the selection of a heat pump unit is the "balance point" of the installation. Virtually every room is unique—with different insulation, different sizes and types of windows, different types of construction and different directional exposures. All these variables, as well as geographical location, must be considered in order to determine the balance point, the point at which the heat pump is unable to produce enough heat to compensate for the heat loss of the room or area being heated. For these reasons, a consulting engineer should be engaged to calculate the heat loss and specify the heat pump unit required.

The Zoneline 6100 series heat pump units—with highly featured microprocessor controls—react to the indoor temperature as well as the outdoor temperature in determining the heat source to provide comfortable room conditions and energy savings. This determination of the heat source based on the indoor temperature helps provide a more comfortable room.

HEAT PUMPS AND ENERGY SAVINGS (cont)

Heat Pump Operation — Zoneline® 6100 Series

Heat sources: Heat pump, heat pump and simultaneous electric resistance heat, or electric resistance heat.

Zoneline heat pumps employ a highly featured microprocessor control system interfaced with thermistors to accurately measure indoor air temperature, outdoor air temperature, indoor coil temperature and outdoor coil temperature. This system allows the microprocessor to precisely and predictably react to changing conditions in order to provide a very advanced packaged terminal heat pump operating system.

Zoneline heat pumps are designed to help ensure a comfortable room. When "HEAT" is selected, the unit will determine if the room air is warm enough to satisfy the thermostat setting. If the temperature at the unit sensor is below the desired temperature, the electric resistance heater will be utilized to warm the room to the point where the thermostat is satisfied. This feature is designed to allow the temperature of an unoccupied room to be maintained at an energy-saving level without inconveniencing the room occupant. Once the thermostat has been satisfied, the resistance heater will turn off and the heat pump will operate (as shown below in the Heat Source Logic chart) until the thermostat calls for heat again. The unit will operate in this manner even if connected to a Central Desk Control.

Zoneline Heat Pump Heat Source Logic

ROOM TEMPERATURE VS. THERMOSTAT SET POINT	Above 46°F	Between 46°F and 25°F	Below 25°F
Less Than 1.8°F Below	Heat Pump	Heat Pump*	Full Resistance Heat
1.8°F to 2.7°F Below	Heat Pump	Heat Pump + Supplemental Heater	Full Resistance Heat
More than 2.7°F Below	Heat Pump	Full Resistance Heat	Full Resistance Heat

The Heat Boost option feature utilizes the supplemental simultaneous heater at the same time as heat pump operation when the outdoor temperature is below 46°F, regardless of the indoor air temperature**. The chart above indicates the heat source of the heat pump under various indoor and outdoor conditions. The unit is designed to provide heat pump savings without sacrificing room comfort. The Quick Heat Recovery feature is not affected by the Heat Source Logic shown in the chart above. For more information about the Quick Heat Recovery feature, see page 9. The full heat output of the resistance heater is dependent upon circuit amperage and the power connection kit used. See pages 4 and 43–44 for information on power connection kits

An option is provided in the auxiliary controls (Mode 8) to allow the unit to operate only in resistance heat. The use of this option significantly increases the cost for heating.

Heat pump defrost — Zoneline 6100 Series

Zoneline heat pumps utilize a reverse-cycle, demanddefrost system to extend heat pump operation and increase savings from extended operation. The microprocessor determines the need for defrosting by criteria based on continuous compressor running time, outdoor air temperature, outdoor coil temperature and the rate of temperature change of the outdoor coil. When defrosting is required, the unit reverses the flow of refrigerant to direct the hot gas into the outdoor coil to melt the frost buildup. Before and after the reverse-cycle defrosting, the unit shuts off the compressor to allow the refrigerant pressures to equalize throughout the system. This eliminates the possibility of a loud reversing noise. During these periods of pressure equalization, the full resistance heat capacity of the unit is activated to help ensure room comfort conditions during the defrost cycle. The unit remains in the defrost cycle for a minimum of two minutes up to a maximum of nine minutes. The defrost cycle terminates when the outdoor coil reaches a temperature of 68°F or the maximum time has been reached.

Heat pump condensate

Zoneline 6100 Series heat pumps may be ordered with a factory-installed Internal Condensate Removal (ICR) system to minimize the amount of condensate water draining from the unit during heat pump operation. The ICR system has proven to be an effective means of minimizing the amount of heat pump condensate dripping from the unit. However, if the requirements of a particular installation will allow no dripping of condensate water from the wall case, the installation of an internal or external drain system is recommended. See page 35 for more information on heat pump condensate.

Units with ICR may not be installed in seacoast or other corrosive environments.

and available heater capacities.

^{*}If the Heat Boost switch (auxiliary setting #9) is "ON", the supplemental simultaneous heater will be used with heat pump operation.

Simultaneous supplemental heater: 1.0 KW @ 230 V;

0.8 KW @ 208V; 1.0 KW @ 265V.

^{**}Heat Boost option only applies to systems controlled at the unit. Heat Boost option should NOT be used with remote thermostat operation since this will cause the unit to switch to resistance heat when outdoor temperatures are below 46°F.

APPLICATION COMMENTS

Use and Care Manual and installation instructions are shipped with Zoneline units. It is important that any air conditioning system be properly sized and applied in order to achieve the desired temperature and humidity levels in the space to be conditioned. Zoneline units are designed primarily to provide heating and cooling with the additional benefit that during operation in the cooling mode, the units also remove some moisture from the conditioned space. The following are some brief application comments on undersizing, oversizing, heating, wall coverings, and air infiltration: all are important in the proper matching of the heating/air conditioning system to the building structure.

Undersizing: If an air conditioner is undersized (cooling capacity is less than required for a specific application), the unit will typically not be able to cool the space down to the desired temperature (thermostat set point), nor be able to remove enough moisture from the air. The result could be a warm and humid or warm and dry conditioned space.

Oversizing: If an air conditioner is oversized (cooling capacity is greater than required for the specific application), the unit will typically cool the space down to the desired temperature (thermostat set point) too quickly. The compressor then begins to cycle on and off. Dehumidification only takes place when the compressor is operating in the cooling mode. A typical result in a hot/humid climate could be a cool but excessively humid space.

Heating: Undersizing can result in not being able to maintain the desired temperature level within the conditioned space.

Wall Covering: Use of a non-permeable wall covering (some paints, some wallpapers, and other types of coverings) which severely restricts passage of air or water vapor can cause a severe moisture problem. Typical results could be staining of room surfaces, wall damage, as well as mold and mildew growth in hot/humid climates.

Air Infiltration: Excessive air infiltration can magnify problems associated with undersizing or oversizing of an air conditioner unit and can be the root cause of insufficient cooling, dehumidification or heating. Some sources of air infiltration include vents, gaps around windows and doors, and improperly sealed floor, ceiling and wall joints.

Recommendation: For the above reasons it is strongly recommended that a professional engineer be retained to match the Zoneline unit with the building structure.

Air Distribution


Zoneline packaged terminal air conditioners and heat pumps discharge air from the top of the unit through reversible two-position discharge louvers. Unit discharge louvers are reversed by removing the room cabinet from the unit, removing seven screws that hold the louver section in place, removing the louver section and rotating it end for end, reinstalling the louver section in the room cabinet with the seven screws, and reinstalling the room cabinet on the unit. The unit is shipped from the factory with the discharge louvers at an angle of 50° off vertical. In the alternate position, the louvers will be at an angle of 40° off vertical. All room cabinets return air through the front of the unit.


High Wall Mount: For units mounted high in the wall, the discharge louvers should be at a setting that provides the most horizontal air discharge. Recommended installation is at least 3" below the ceiling. In




installations where units are close to the ceiling, the greatest horizontal discharge angle can be obtained by removing the discharge grille from the room cabinet.


Supply Air Throw: One Zoneline unit should not be required to do a job obviously requiring two or more units. Units should be located around large rooms according to calculated loads or in such fashion as to achieve balanced air distribution in all parts of the room. The single unit in the "Incorrect" illustration below obviously cannot condition the entire room. Add a second unit as shown in the "Correct" illustration.







CASE DIMENSIONS



*SHOWN WITH ACCESS COVERS REMOVED. NOTE: CAUTION - REMOVE KNOCKOUTS FROM INSIDE OUT.

Installation instructions packed with wall case. See page 26 for additional information concerning outdoor weather panel and case stiffener.

WALL CASE

A choice of wall cases is available for Zoneline® units.

RAB71A — This insulated case is constructed of heavy-gauge galvanized steel and finished with a baked-enamel finish for protection and appearance. Design of the case provides for support of the chassis and free draining of any water entering the wall case. A petroleum microcrystalline wax is applied at critical points of fabrication to seal against moisture. The dimensions of the RAB71A wall case are 42" wide by 16" high by 13-3/4" deep, the same dimensions as the original wall case for GE Zoneline units built in 1961. The RAB71A wall case is also available in depths other than the standard depth. It is available on special order as: RAB7116 – 16" deep; RAB7124 – 24" deep; RAB7128 – 28" deep; and RAB7131 – 31" deep. All these special-order deep wall cases are insulated and have sheet-metal dividers, or splitters, to prevent the recirculation of condenser discharge air.

RAB77A4 — This non-insulated wall case is molded from fiberglass-reinforced polyester compound. This SMC (Sheet-Molded Compound) wall case offers outstanding strength, durability, color retention, water integrity and corrosion resistance. The dimensions of the RAB77A4 wall case are 42-1/8" wide by 16-1/4" high by 13-7/8" deep.

- Both wall cases are of universal design, accepting all Zoneline chassis of current design as well as all GE Zoneline chassis produced since 1961.
- Drain holes are provided in the rear of the wall case to permit excessive cooling condensate water, heat pump condensate or precipitation entering the wall case to drain freely. A drain kit may be connected to the wall case to control any water draining from the wall case. See page 36 for information on RAD10 Drain Kit.

RAK901L — For installations where the wall case extends into the room, RAK901L is an insulation kit that can be used with the RAB77 or any existing non-insulated wall case to minimize the possibility of condensation forming on the indoor side of the case during the winter.

SUB-BASE

The sub-base is an optional accessory for the Zoneline unit and is presented with the wall case information since deciding whether or not to use a sub-base in the installation is a factor in the location of the wall opening. National Electrical Code® (NEC) requires that air conditioning units connected to voltages in excess of 250 volts be "permanently connected." There are also some installations where units connected to voltage sources under 250 volts may also need to be "permanently connected." If you are in doubt about the requirements for a particular installation, consult Article 440 of the NEC or the local electrical inspector. These requirements are designed to protect personal safety and should be strictly followed. Although NEC is cited here as a reference, all electrical wiring and installations must conform to any and all local electrical codes and regulations.

"Permanent connection" generally means wiring to the unit must be contained in an enclosed "chaseway," where access to the wiring connections is more restrictive than a normal line cord plugged into a receptacle. NEC requirements may be met by using flexible or rigid conduit to contain the wiring between the unit and a junction box that contains the wiring connections. The conduit is connected to the unit and to the junction box with connectors to hold the conduit in place. The junction box may be located in the floor or the wall of the structure, but only approved connectors may be used outside the unit or the junction box. The sub-base is UL® listed as a junction box for permanent connection of a Zoneline unit.

Using a sub-base in an installation requiring permanent connection provides a convenient, consistent location for unit wiring to be connected to building wiring. The use of a sub-base is not required, but the convenience and the improved aesthetics it offers make the use of a sub-base a viable means of permanent connection.

RAK204U — The RAK204U Series of sub-bases provides a variety of designs that fit the site needs and are available for use with Zoneline PTAC/PTHP units. The RAK204U will most likely be used for support of the wall case and unit. The RAK204U is the same physically as the other sub-bases except there is no receptacle installed. Receptacles and wiring can be field installed and, by using the RAK205CW chaseway and the RAK4002A junction box, perform the same function as any of the other sub-base kits by selecting the correct receptacle and installing it in the interior mounting plate inside the RAK204U.

208/230-volt receptacles can also be mounted in the cover plate for easy access when direct-connect wiring is not required. 265-volt units are to be "Permanently (or Direct) Connected" and the external receptacle (when wiring is not enclosed in a chaseway) does not meet this requirement. A knockout for a fuseholder or a disconnect is also provided in the cover plate.

RAK204U — No receptacle, no wiring; will accept any 15-, 20-, 30-amp receptacle and wiring. No chaseway is included. RAK205CW chaseway must be ordered separately.

The 230/208-volt sub-bases below include a short, sub-base power connection kit. Since sub-base connected units are not considered to be line-cord connected, a Leakage Current Detection and Interruption or Arc Fault Current Interrupter device is not necessary.

The junction box (RAK4002A for 4100 and 6100 Series units) that mounts on the chassis of 230/208-volt sub-base connected units must be purchased separately.

RAK204D15P 208/230-volt 15-amp receptacle. Receptacle is NEMA6-20R with 18" of #12AWG wires attached to the receptacle. Short power connection kit included. Chaseway included.

RAK204D20P 208/230-volt 20-amp receptacle. Receptacle is NEMA6-20R with 18" of #12AWG wires attached to the receptacle. Short power connection kit included. Chaseway included.

SUB-BASE (cont)

RAK204D30P 208/230 volt 30-amp receptacle. Receptacle is NEMA6-30R with 18" of #12AWG wires attached to the receptacle. Short power connection kit included. Chaseway included.

The junction box (RAK4002A for 4100 and 6100 Series units) that mounts on the chassis of 230/208 volt sub-base connected units must be purchased separately.

Sub-bases for the 265-volt units:

RAK204E15 265-volt 15-amp receptacle. Receptacle is NEMA7-15R with 18" of #12AWG wires attached to the receptacle. Chaseway included.

RAK204E20 265-volt 20-amp receptacle. Receptacle is NEMA7-20R with 18" of #12AWG wires attached to the receptacle. Chaseway included.

RAK204E30 265-volt 30-amp receptacle. Receptacle is NEMA7-30R with 18" of #12AWG wires attached to the receptacle. Chaseway included.

The junction box for 265-volt units is shipped with the chassis since all 265-volt units are to be "permanently (or direct) connected."

The power connection kit is not included

There are separate internal compartments to permit separation of low-voltage (Class 2) connections from line-voltage connections as required by National Electrical Code (NEC). Conduit containing building wiring enters the sub-base through knockouts located in the rear or bottom of the sub-base and is not accessible when the wall case is installed.

The sub-base attaches to the RAB71A wall case with two clips (field-assembled) that are screwed into pre-drilled holes in the bottom front flange of the wall case. It attaches to the RAB77A4 wall case with clips that fit over molded ribs without requiring the use of screws into the wall case. (See page 34 for illustration.) Since the sub-base extends under the wall case, clearance from the inner edge of the wall case to the finished wall must be 2-3/8" or greater. The sub-base has four leveling legs and adjustable side channels to enable the area under the wall case to be enclosed. Clearance from the bottom edge of the wall case to the finished floor must be between 3" and 5".

The sub-base may be used as support for the chassis and wall case in installations where the wall is of insufficient thickness to provide secure mounting of the wall case.

WALL CASE INSTALLATION DATA

General

Generally, Zoneline® units are installed 3" to 5" above the floor (flush to finished floor installation is possible) as near to the center of the room as possible; underneath a window or a glass panel is typical. Normal installation of the wall case allows installation flexibility; from flush with the finished interior wall to a minimum of 1/4" of the wall case extending beyond the finished exterior of the building. Special consideration must be given to installations where the wall case does not extend a minimum of 1/4" beyond the finished exterior wall. See pages 31 and 32 for information on this type

of installation. The unit may be installed high in the wall and these installations usually require a remote thermostat and are discussed on pages 16 and 17.

Regardless of the installation, there are several things to consider when selecting a location for installing the unit. For instance, drapery location could interfere with air discharge, and placement of furniture may have an impact on the performance of the unit. The following information is intended to minimize installation problems and assure you of trouble-free installation.

Refer to page 22 for required wall opening dimensions. Minimum recommended interior and exterior case projections for standard wall thicknesses are shown in the drawings in this manual. The case may be installed flush with the finished indoor wall. Special attention must be paid to room-side case projection when the unit is installed in a ducted application as shown on pages 39 and 40.

In walls thicker than 13-1/2" for line-cord-connected units and 11-1/8" for sub-base installations, it may be necessary to install a field-fabricated case extension or use one of the special-order RAB71 deep wall cases. Such extensions must be carefully flashed and sealed both to the wall case and to the wall to ensure water integrity. This is necessary to ensure that any water entering the wall case, either from operation of the unit or from other sources, such as rain storms or from washing the exterior of the building, will drain from the case without the possibility of capillary action drawing the water into either the room or the wall cavity. In an installation where the case is recessed less than 3" from the outside surface. flashing and sealing may be all the modification necessary. In such an installation, the sides and top of the wall opening must be waterproof to prevent moisture from seeping into and damaging the walls. See pages 31 and 32 for suggested detail. Since the installation of a case extension requires a considerable amount of attention, we recommend using one of the deep wall cases if the standard case is not of sufficient depth.

Mounting an outdoor grille or louver section to the building face may cause a space between the outdoor coil and the louver section. Air splitters, aligned with the ends of the outdoor coil, must be installed between the outdoor coil inlet and outlet air streams. Gaps between the outdoor coil and the louver section may allow condenser air recirculation and affect the operation of the unit. See page 41 for requirements for custom louvers.

The wall case should be level from side to side and from level to 1/4 bubble tilt to the outdoors. The condensate disposal system in the unit is designed to dissipate the condensate water generated during cooling operation in accordance with AHRI standards and actually uses this water for maximum unit efficiency. A level unit will also ensure proper performance of the Internal Condensate Removal (ICR) system optional on heat pump units.

WALL CASE INSTALLATION DATA (cont)

For new construction, early planning with the architect is necessary. Unit location, electrical connection locations and wall openings of the proper dimensions are essential to avoid the necessity of rework, fillers, framing, moving electrical outlets and other expensive modifications.

For existing construction it is important that carpentry, masonry and electrical work be performed by competent, qualified personnel. Since installations in existing construction may involve removal of building material from the structure, locating the wall case must be done correctly.

ARCHITECTURAL WINDOW/ LOUVER INSTALLATION

Many installations utilize an architectural window/louver combination to enhance the exterior appearance of the building. The exterior grille for the air conditioner is built as an integral part of the window frame. An internal drain system is highly recommended for these installations (see page 37). When this type of installation is made, there must be provision in the grille work for condensate water to drain to the exterior (including the overflow relief drain holes) and not be routed back into the interior of the building or into the wall cavity. Failure to allow for the drainage of condensate water can cause extensive damage to structural components.

The problems associated with the lack of condensate drain consideration often show up shortly after the air conditioners are turned on in a new building. New buildings that have been virtually wide-open during construction have a significant amount of moisture in the air and in the building components that the air conditioners start removing as they operate. The free area in the louver section must also comply with the requirements shown on page 42.

The wall case should be anchored to the architectural window/louver section to reduce air infiltration and excessive vibration of the chassis and wall case during unit operation. Field-fabricated and -installed case angles are the recommended method of securing the wall case to the window/louver framework.

WINDOW, CURTAIN AND PANEL WALL CONSTRUCTION

With this type of construction, provision for support of the unit, other than by the wall itself, is often required. Such support may be in the form of wood or metallic material of the proper thickness to maintain a level case. This additional support should be located both near the wall and at the front of the wall case. Sub-base (RAK204 Series) with four leveling legs provides an excellent support for the unit in this type of installation. (See page 29 for details of this type of installation.)

In existing construction, common practice is to remove a pane of glass, metal, wood, or other construction material and build a frame around the wall case. Similar filler panel material may be installed around the case for appearance and weather seal.

MASONRY WALL CONSTRUCTION

The wall case should be installed during construction and lintels should be used to support the blocks above the wall case. The wall case will <u>not</u> support the concrete block. The installation instructions show how the wall case must be secured to the masonry and caulked. Do not remove the cardboard stiffener supplied with the wall case until ready to install the chassis. (See page 30 for details of installation in masonry wall)

For existing masonry construction, wall openings must be made by removing concrete blocks to achieve the propersize opening. Consult the builder, architect or owner to determine the necessity for lintels to support the block above the wall case.

Anchor bolts are normally required to secure the case to the wall and shims may be required to prevent distortion of the wall case when securing the wall case to the wall. Fieldsupplied case angles can be used to position and secure the wall case to the wall and to cover oversized wall openings.

BRICK, FRAME, STUCCO AND SHINGLE CONSTRUCTION

For new construction, the opening for the wall case should be framed and the wall case inserted into the opening during construction. Lintels should be used when the building material is heavy and is not self-supporting (such as brick). The wall case will fit an opening of six courses of standard brick or five courses of jumbo brick. Wall framing in this type construction is normally on 16" centers and the wall case will fit a framed opening spanning three 16" O.C. 2" x 4" stud spaces.

For existing construction, the indoor and outdoor wall will need to be cut out, allowing for clearances of 1/8" on all sides of the wall case. Work should begin on the inside wall. Cut the correct dimensions and mark (using drill holes) the outside wall from each corner of the inside cutout. Studding that interferes with the opening must be removed and a suitable frame constructed to secure the wall case and provide adequate support for case and chassis.

As shipped, the RAB71A Series or RAB77A4 is ready for installation.

PREPARATION OF THE WALL CASE FOR ALL TYPES OF CONSTRUCTION

Do not remove the stiffener from inside the wall case or the weather closure panel from the outside face of the wall case until the outdoor grille and chassis are ready to be installed. Installation of Wall Case in Wall Opening

1. Position the wall case into the wall. The room-side edge of the RAB71A or RAB77A4 wall case should be at least flush with the finished wall for line-cord installations and permanent-connection installations when no sub-base is used, and should project into the room at least 2-3/8" when a sub-base is used. The outside edge of the wall case should extend at least 1/4" beyond the outside wall. This is necessary for proper caulking, to prevent sealing the drain holes in the rear flange of the wall case, and to facilitate the installation of an accessory drain, if used. If the minimum exterior dimensions are not met, refer to pages 31 and 32.

The wall case should be level from side to side and from level to 1/4 bubble tilt to the outdoors. The condensate disposal system in the unit is designed to dissipate the condensate water generated during cooling operation in accordance with AHRI standards and actually uses this water for maximum unit efficiency. A level unit will also ensure proper performance of the Internal Condensate Removal (ICR) system optional on heat pump units.

2. The wall case should be secured to the wall at both sides. Use a minimum of two screws or other fastening device on each side. (See Figure 2 on page 27.) Mark the wall case on each side 2" from the bottom and 2" from the top at a point where basic wall structure is located. Drill wall case and use fasteners appropriate for wall construction. All holes for fasteners in the side of the wall case must be at least 2" up from the bottom of the wall case. Never locate screws or put other holes in the bottom of the wall case. The ONLY exception is when an RAD10 drain kit is installed to connect to an internal drain system. (See page 37 for RAD10 drain kit information.)

If the wall opening is greater than the case dimensions, spacers must be used on the sides between the wall case and the wall support structure to prevent distorting the wall case.

- 3. Caulk or gasket the entire opening on the outside between the wall case and exterior wall surface (four sides) to provide total water and air seal.
- 4. Caulk or gasket room-side opening between wall case and interior wall surface (four sides). Openings beneath or around the wall case can allow outdoor air to leak into the room, resulting in increased operating costs and improper room temperature control.


Care should be taken in location of electrical supply entry in relationship to wall sleeve to assure access to receptacle or junction box once unit is installed.


- Refer to page 44 for maximum power cord length.
- Permanently connected units close to finished floor must allow for conduit clearance.


CASE ANGLES


In some installations, such as curtain walls, window walls, or where the structural material of the wall is insufficient to support or fasten wall case, case angles may be used. Case angles are pieces of steel or other material of similar structural strength that are formed to a 90° angle, with holes to fasten the case angle to the wall case and to the structural component of the wall surrounding the wall case. The following describes the procedure when *field-fabricated and -installed* case angles are applied.

- 1. Position case angles around top and sides of wall case at the desired location. Position case angles vertically on each side of wall case to provide a level installation.
- 2. Mark wall case through holes in case angles. The lowest hole on the sides of the wall case must be a minimum of 2" above the bottom of the case.
- 3. For RAB71A wall case, drill 5/32" diameter holes at locations marked on wall case in Step 2, and assemble angles to wall case using #10 x 1/2" self-tapping screws. For RAB77A4 wall case, follow the same procedure except use a #10 x 1/2" bolt, washer and nut to attach case angles to case. Install screws or bolts from inside wall case.
- 4. Do not drill any holes in bottom of wall case. Do not distort wall case.
- 5. Do not use case angles for a lintel.









METAL CASE EXTENSION FOR WALLS DEEPER THAN 13-1/8" (11-1/8" WITH SUB-BASE)

Field fabricated – GE recommends the use of one of the deeper RAB71 wall cases offered as special order items.

is to apply a flashing to the bottom of the wall case as shown on page 32. Where waterproofing is questionable than the wall case. Where the case recession is less than Zoneline® units can be installed in walls of greater depth bearing and the connection between the two must be watertight. The case extension must contain splitters sides and top of the opening, the suggested procedure container, the extension likewise must also be water-3" and where it is possible to waterproof the exposed or not possible, or for installations in walls of greater procedure. It involves the field fabrication of a case to prevent recirculation of the outdoor air circuit. extension. Since the wall case is a water-bearing depth, the following is a suggested application

between the completed wall case/extension assembly 1. The case extension is field fabricated. The extension to apply sealant or caulking for a tight weather seal clearance to the finished wall and ample surfaces and the wall opening. It is recommended that the extension be painted and corner and lap joints be additionally sealed with a quality-grade sealant. depth "D" should allow for a minimum outdoor projection of 1/4". This allows for room cabinet

 $6-1/4" \pm 1/4"$


SEALANT - ALL FOUR (4) FLANGES

grade sealant should be applied to all four (4) butting to attach the two assemblies. Clean all drain holes of flanges. Use bolts and nuts or oversized self-tapping excess sealant. The assembly must be free draining. screws (driven from the wall case to the extension) 2. The wall case and extension should be connected prior to installation in the wall opening. A quality-

Install flashing, using a quality-grade sealant between the flashing and wall as shown in section A-A below.

caulked to the wall around all four sides both outdoors 4. Install the wall case/extension assembly following procedures described for a standard installation. See diagrams below. The assembly should be sealed or NOTE: The wall case/extension assembly should and indoors. be level

5. Suggested materials for case extension and flashing should be non-ferrous metals. Minimal acceptable material: Galvanized G-90 painted.






EXTENSION

ALL 4 FLANGES

WALL CASE



FLASHING




FLASHING (FIELD SUPPLIED)

13-3/4" + D"

2" MIN.

ALTERNATE – CASE RECESSION LESS THAN 3" WITH SIDES AND TOP OF WALL OPENING WATERPROOF, FLASHING ON BOTTOM ONLY





DIMENSIONS:

A. DISTANCE FROM GRILLE OR CASETO OUTSIDE SURFACE OF WALL PLUS 2"TO 4" (TO INSERT UNDER CASE).


*Caulk around perimeter of wall case all four sides where it joins the building - Interior and Exterior.


B. 1" DRIP LIP (MINIMUM)

C. 42" PLUS - SUFFICIENT TO FIT SNUGGLY UNDER AND UP AROUND THE CASE.

D. 2" MINIMUM

(CAUTION: WHEN CAULKING **DO NOT BLOCK DRAIN HOLES IN CASE OR GRILLE.)** IF GRILLE ISTO BE MOUNTED TO WALL SURFACE "A" SPLITTERS MUST BE USED. (SEE PAGE 30.)





Knockout holes in the sub-base access plate may accommodate a receptacle, which allows the use of a power cord (if permitted by code for the particular installation). A knockout for a circuit breaker, fuseholder or a disconnect is also provided. See pages 23 and 24 for description of electrical contents of these sub-bases. Electrical wiring may enter the sub-base through any of the knockout holes provided in the sub-base.

CONDENSATE DISPOSAL SYSTEMS

Cooling Condensate

Air conditioners produce condensate water as a result of lowering the humidity of the area being conditioned. When the indoor coil temperature is below the dew point, moisture in the air condenses into water droplets on the coil. This water drains to a pan located under the indoor coil and is routed through the barrier (the partition separating the indoor and outdoor sides of the unit) to the base pan on the outdoor side. It is then picked up and dispersed against the outdoor coil, which is hot when the unit is in the air conditioning mode. The water is evaporated into the atmosphere by contact with the hot outdoor coil. This evaporation process also helps lower the temperature of the outdoor coil and improves the operating efficiency of the unit.

Slinger Ring Systems

Packaged terminal units employ various means of dispersing the condensate water. One of the most popular, and most effective, means is by the use of a "slinger ring." A slinger ring is a ring around the circumference of the outdoor fan. The design of the unit positions the slinger ring very close to the bottom of the base pan so water in the base pan is lifted by the rotating ring. Water picked up by the slinger ring will be dispersed into the air stream and deposited on the hot outdoor coil where it evaporates.

All Zoneline® Series packaged terminal air conditioners and packaged terminal heat pumps utilize a slinger ring for cooling condensate disposal.

Certification Test Requirements

AHRI (Air Conditioning, Heating & Refrigerating Institute) requires that all certified packaged terminal air conditioners and packaged terminal heat pumps pass a cooling condensate disposal test. One stipulation of the AHRI test is that "the test start with condensate collection pan brimful." In order to pass the AHRI Condensate Disposal Test the unit must operate continuously for four hours without condensed water blowing, dripping, or running off the unit casing during the test or after the unit has been turned off. Under extremely high outdoor humidity conditions or extreme operating conditions, such as exceptionally high air infiltration (a door or window left open while the unit is running, for instance) it is possible for any air conditioner to be unable to dissipate all the cooling condensate generated.

All Zoneline Series packaged terminal air conditioners and packaged terminal heat pumps meet the condensate disposal requirements of AHRI standards 310 and 380.

Heat Pump Condensate

During the operation of a unit in the heat pump, or "reverse cycle," mode, the outdoor coil becomes the cold coil and the indoor coil becomes the hot coil due to reversing the flow of the refrigerant. When the temperature of the outdoor coil is below the dew point, condensation will form on the outdoor coil just as it does on the indoor coil during cooling operation. Since the dew point is humidity- as well as temperature-related, there may be more condensate on days when the relative humidity is high.

Heat Pump Condensate Disposal

Since the outdoor coil is cold during heat pump operation, the condensate water cannot be deposited on the outdoor coil because the water would cause frost to form on the coil. This frost would block the airflow through the coil. Rather than allow this problem to occur, heat pump units must dispose of the condensate in another manner.

Temperature-Activated Drain Valve



The most widely used method of disposing of heat pump condensate is with a temperature-activated drain valve. This is a device mounted in the base pan of a heat pump unit with a bellows that expands on temperature rise and contracts with temperature drop. A shaft with a rubber plug on the end is connected to the bellows. When the outdoor

temperature remains above a certain temperature, the bellows is expanded and the plug fits tightly into a hole in the bottom, or base pan, of the unit. When the plug is blocking the hole, as it should be during cooling operation, the condensate water is contained in the base pan. At temperatures when heating is required, the bellows contracts, the rubber plug is retracted from the hole and the heat pump condensate water is allowed to drain into the wall case. The valve is fully open at approximately 45°F.

Drain Kits


Although the Zoneline units are designed to dissipate most of the condensate generated during normal cooling operation, there may be times when abnormal operating conditions cause more condensate than the unit can dissipate. Heat pumps also generate condensate that the unit may not be designed to dissipate. For these reasons, if condensate dripping from the wall case is objectionable, an internal or external drain system should be installed. See pages 36 and 37 for information covering the drain systems and the RAD10 kit available to connect to the wall case.

Internal Condensate Removal (ICR) System

GE has developed an Internal Condensate Removal (ICR) system for packaged terminal heat pumps. This system has been offered as an option on Zoneline packaged terminal Heat Pumps since 1982, and thousands of them are in use. During heat pump operation, the ICR system utilizes a small pump to lift the water from the base pan and pump it into a collector tray positioned above the indoor coil. The water drains from the collector tray and drips onto the warm indoor coil where it is evaporated into the room atmosphere. If an excess amount of water is pumped to the indoor side, it is routed back to the outdoor portion of the base pan.

The ICR system has proven to be an effective means of minimizing the amount of heat pump condensate dripping from the unit. However, if the restrictions of a particular installation will allow absolutely no drippage of condensate water from the wall case, the installation of an internal or external drain system is recommended.

Units with ICR may not be installed in seacoast or other corrosive environment applications.



These drain holes must not be blocked when mounting or caulking the wall case.

water in the wall case than can be drained through these holes it will drain through the three overflow drain holes

For those installations where water draining from the drain holes is objectionable or where positive drainage is desired, the RAD10 drain kit is available with either a 90° elbow or a 6″ straight tube to be used either to connect to a field supplied drain line or to allow the water to drip free rather than drain down the surface of the building.

through RAG63 exterior grilles. Modification must be made to the RAG61 through RAG63 exterior grilles when using the straight tube. Modification must be made to the RAG67 grille if using either the 90° elbow tube or the straight tube (see NOTE: Drain kit using either the 90° elbow tube or the straight tube may be installed without modification when using RAG60 exterior grille. Drain kit using the 90° elbow tube may be installed without modification when using RAG61 installation instructions with the RAG67 grille).

0

FLOOR

Ó.0 0


MIN. 2 SUPPORTS FIELD SUPPLIED

T

₽4

PROJECTION BEYOND WALL CASE

90° ELBOW DRAINTUBE



DUCTED INSTALLATIONS

4100 and 6100 Series Zoneline[®] units may be used in ducted installations.

With a ducted installation it is possible to condition the air in two areas that have a common wall separating them. A special adapter mounts on the wall case and a transition piece directs the air from the unit into the adapter. Instructions for mounting the adapter to the wall case are included with the duct adapter. The adapter contains a grille that allows air from the unit to be discharged into the primary room and the adapter connects to a duct extension that allows the air to flow to the adjoining room. Ducting a unit may allow a single unit to be used rather than a separate unit in each room, providing a means of reducing initial equipment cost. The duct may extend a total of 15 feet (with a field-fabricated insulated duct extension) in one direction, either to the right or to the left of the unit. A baffle installed in the discharge duct of the adapter is provided from the factory to provide approximately 35% air discharge into the primary room (room in which the unit is installed) and 65% into the secondary (adjacent) room. To increase the amount of air discharged into the primary room, the damper may be modified by removing the discharge grille on top of the adapter and folding over (or cutting off) the scored section of damper to provide approximately a 50/50 split. Completely removing the discharge damper will result in approximately 75% air discharge into the primary room and 25% into the secondary room.

The installation of the wall case and sub-base, if used, is the same for units being ducted as for free-standing units. The duct adapter support bracket overlaps the wall case by 1" and the bracket and mounting screws add approximately 3/8" (3/16" on each side) to the width of the wall case. If less than 1" of the wall case projects into the room it will be necessary to allow for the additional width in the opening for the wall case. The duct adapter mounting brackets should be mounted prior to installing the case in the wall.

Refer to pages 39 and 40 for drawings of ducted installations. Prior to the installation of the transition from the room cabinet to the adapter, it will be necessary to remove the discharge grille from the room cabinet. Instructions for this modification are included with the duct adapter.

NEW DUCTED INSTALLATIONS



Components

Duct Adapter RAK6052 — The duct adapter is secured to each side of the wall case and requires the drilling of mounting holes in the wall case during installation. A template for the hole location is in the installation instructions. By securing the duct adapter to the wall case, the chassis retains the slide-out feature for servicing after the transition piece is removed.

Duct Extension RAK601 — This kit contains a 44"-long insulated duct, a register mounting collar, and an air supply register. It can be secured to the duct adapter at either end of the adapter. This duct may be cut at any dimension and used in two applications providing the sum of the two duct lengths necessary does not exceed the 44" length. Even in single applications, the mounting flange must be cut off one end of the duct to accept the collar and supply register.



Duct Extension, Mounting Collar and Register RAK601

Mounting Collar and Supply Register RAK602 —These components are included in the Duct Extension Kit RAK601. They may be ordered separately for installations where two duct extensions are made from one RAK601.

DUCTED APPLICATION CONSIDERATIONS

When designing a ducted application, some application considerations to be made include:

- 1. Do not exceed the 15-foot-length maximum for the duct extension. Field-supplied duct extension must be completely insulated with minimum of 1/2" insulation
- 2. The duct **must be a straight run**. Turns or bends in the duct extension create air pressure drops that the unit is not designed to overcome.
- Turn the "Duct Mode" on in the auxiliary control settings (Mode 7). This increases the fan speed to ensure proper circulation.
- 4. Minimum recommended clearance between the unit and the adjacent wall is 2".
- 5. Provisions for return air must be made to allow air circulation from secondary room. Doors in both secondary and primary rooms may be undercut or a return grille may be installed through a common wall.
- 6. When calculating the heat gain/heat loss take both areas into consideration.

REPLACEMENTS OF EXISTING DUCTED UNITS

Since the design of the Zoneline chassis has changed over the years to provide better performance and appearance, some of the components used in ducted applications have changed. Select the proper components from the information below. The best procedure in determining the correct kit is to measure the existing duct extension cross section.


Flat-Top Discharge Units (Zoneline Units Built Prior to 1988)


Existing Duct Extension Cross-Section Measurements: 8-3/8" height x 6-1/2" width

Duct Adapter RAK7012 — This duct adapter will allow the replacement of a new chassis (4100 or 6100 Series unit) into an existing ducted application. This adapter will align properly with the duct extension and will eliminate the need to modify the wall opening. In order to minimize replacement costs, some of the components of the old duct adapter must be removed and used in the new installation. Consult the Installation Instructions of the RAK7012 before removing and discarding the old duct adapter. (See notes on page 58.)

Slope-Front Discharge Units (AZ series models) Existing Duct Extension Cross-Section Measurements: 7-3/32" height x 6-1/2" width


Duct Transition RAK7022 — This duct transition will allow the replacement of a new slope-front discharge Zoneline chassis (4100 or 6100 Series unit) into a previous-design slope-front ducted installation. (See notes on page 58.)





EXTERIOR GRILLES

Four styles of outdoor grilles are available for exterior treatments. The standard stamped aluminum grille (RAG60), the molded architectural louvered exterior grilles (RAG61-63) and the extruded aluminum architectural louvered grille (RAG67). All grilles include air deflectors (RAK40) and gaskets to prevent condenser air recirculation.



RAG60 Outdoor Grille

RAG60 Outdoor Grille — The standard exterior grille is made of durable aluminum to protect chassis components and prevent air recirculation.



RAG61 Outdoor Grille

RAG61, 62, 63 Architectural Grille — One-piece optional molded grille and frame assembly provides improved appearance, protection and weatherability. Molded of durable polycarbonate, the surfaces of the grille have a colorfast, slightly textured finish which blends well with most types of wall surfaces. The grilles can be painted in the field to match the building for improved aesthetics.

Colors: RAG61 — Beige RAG62 — Dark Maple

RAG63 — Bittersweet Chocolate



RAG67

RAG67 Extruded Aluminum Grille — The RAG67 is made from extruded anodized aluminum for use where an aluminum architectural grille is preferred. The RAG67 is available in a clear finish and may be special ordered from GE in other colors. Minimum order quantities may be required. Contact your GE salesperson for details.

All grilles are installed and secured to the wall case from the inside. Keyhole slots in the rear flange of the case allow the grille to be placed in position before securing it firmly to the wall case.

Replacement of existing units: If an existing grille is not replaced, capacity and efficiency will be reduced and the unit may fail to operate properly or fail prematurely. A deflector kit, RAK40, must be used with grilles that were not designed for current AZ Series GE Zoneline® units. The RAK40 contains air deflectors and gaskets that mount to the chassis to direct the hot exhaust air away from the air intake to allow the unit to function properly. All grilles used with GE Zoneline units must comply with requirements of Exterior Architectural Treatments and Special Outdoor Grilles (See page 42).

EXTERIOR ARCHITECTURAL TREATMENTS AND SPECIAL OUTDOOR GRILLES

The architectural design of a building may dictate the use of special or oversized louvers for aesthetic reasons. Louvers other than standard Zoneline® exterior grilles may be used on the Zoneline unit, however, these special louvers, or any special exterior architectural treatments of the building facade that may restrict the free circulation of condenser airflow, should be referred to GE Application Engineering for evaluation and approval. The following guidelines should be followed in selecting a louver:


- 1. The louver must have a minimum of 65% free area.

 ASHRAE defines "free area" as the minimum area of the opening in an air inlet or outlet through which air can pass. Percent (%) free area equals the X dimension divided by the Y dimension.
- 2. The louver should be attached to the wall case in a manner that will prevent recirculation of condenser discharge air into the air inlet. If the louver is not attached directly to the wall case, a field-supplied splitter or gasket is required between the chassis and the louver to prevent recirculation.

It is important that the above criteria be followed since a louver that is too restrictive or allows recirculation will reduce the unit's capacity and efficiency, increase the electrical current draw, cause intermittent operation due to the compressor overload protector shutting the compressor off, and cause failure of the compressor overload protector and shorten compressor life. Using the unit with a grille that is too restrictive or allows recirculation *may constitute improper installation and will void the unit's warranty*.

A scale drawing of the louver section should be sent to GE Application Engineering. To assure the proper performance of the Zoneline unit and comply with Underwriters Laboratories requirements, it may be necessary to send a sample louver section (at least $16" \times 42"$) to an independent lab to be tested with the Zoneline unit.

Sample Calculations
Free Area (%) =
$${}^{\times}_{y} \times 100 \quad x = 1$$
" $y = 1.5$ "
F.A. % = ${}^{1}_{1.5} \times 100 = 66.7$ %



POWER CONNECTION FOR 4100 AND 6100 SERIES ZONELINE UNITS

All 4100 and 6100 Series Zoneline units are equipped with universal heaters allowing chassis installation flexibility. The Zoneline units are connected to the building power supply by a unique power connection kit. By utilizing a separate universal power connection (UPC) kit, each unit is capable of providing various outputs of electric resistance heat to more closely meet the heating requirements of the particular room, thereby increasing the installation flexibility of the particular chassis. This power connection kit is the only means of supplying power to the Zoneline chassis. The appropriate kit is determined by the voltage, the means of electrical connection, either line-cord connected or permanently connected, and the desired resistance heat output that may be supported by the branch circuit.

230/208-Volt Line-Cord Connected Units

Line Cord Kits consist of a self-aligning nine-pin molded connector that plugs into a mating connector on the Zoneline chassis and insulated line cord with an electrical plug on the end. The configuration of the electrical plug conforms to National Electrical Code (NEC) standards for the circuit amperage, and the position of the wires in the nine-pin connector determines the heater wattage and current requirements when it is plugged into the Zoneline chassis.

The power connection kit is selected by the amperage of the circuit where it will be installed. Each line cord kit has an integral Leakage Current Detection and Interruption (LCDI) or Arc Fault Current Interrupter (AFCI) device as required by the NEC and Underwriters Laboratory (UL) for line-cord connected air conditioners manufactured on or after August 1, 2004. The line-cord power connection kits are shown in the table below.

230/208-Volt Line-Cord Connected Units

Line Cord Kit	Electric Heat BTUH	Electric Heater Watts	Electric Heat Amps	Min. Circuit Protection (Amps)
RAK3153A	8150/7900	2450/2360	11.0/11.6	15
RAK3203A	11200/10900	3350/3230	15.1/16.0	20
RAK3303A	16000/15450	4750/4580*	21.2/22.4	30

Electric Heat Amps include electric heater and fan motor current draw. *Wattage not available with 7,000 BTU systems.

230/208-Volt Permanently Connected Units

Permanently connected units do not require the LCDI or AFCI device. Permanent connection is usually made through the use of a sub-base. Each 230/208-volt sub-base consists of a sub-base with appropriate receptacle for minimum circuit amperage, a chaseway to route power connector from the sub-base to the chassis, wiring to connect the sub-base to building wiring and a short line cord with a self-aligning nine-pin connector to connect to chassis and plug into the receptacle in the sub-base. Permanent, or direct-wired, installation of a 230/208-volt unit requires a junction box kit, RAK4002A, which attaches to the chassis to form an enclosed junction box.

The short sub-base line cord may <u>not</u> be used without the sub-base.

Specifications subject to change.

For 4100 and 6100 Series 230/208-volt units where a permanent installation using flexible conduit is desired, the RAK4002A forms an enclosed junction box on the chassis. The RAK4002A has a 7/8"-diameter hole to allow conduit to be connected to the junction box. For direct connection, purchase and install the appropriate Universal Power Supply

Kit (also referred to as the Direct Connection Kit below) that matches the ampacity of the building circuit connected to the unit. This nine-pin connector with three 7"-long conductor wires is used for direct connections to the building wiring inside a direct-connect junction box. These wires are then connected to the building wiring by field-supplied connectors.



230/208 Volt Sub-Base and Direct-Connected Units

Sub-Base	Direct Connection Kit	Electric Heat BTUH	Electric Heater Watts	Electric Heat Amps	Min. Circuit Protection (Amps)
RAK204D15P	RAK4157	8150/7900	2450/2360	11.0/11.6	15
RAK204D20P	RAK4207	11200/10900	3350/3230	15.1/16.0	20
RAK204D30P	RAK4307	16000/15450	4750/4580*	21.2/22.4	30

Electric Heat Amps include electric heater and fan motor current draw. *Wattage not available with 7,000 BTU systems.

265- or 277-Volt Unit Installation — Permanently Connected Units

NEC (Article 440.60) requires permanent connection for units connected to power sources over 250 volts; therefore these units must be permanently connected (direct-wired) with field-supplied connectors. Units connected using a sub-base meet the requirement for permanent connection since all wiring is internal wiring between the sub-base and the chassis.

Since 265-volt units may not be line-cord connected, an LCDI device is not required.

265 Volt Sub-Base and Direct-Connected Units

Sub-Base	Electric Heat BTUH	Electric Heater Watts	Electric Heat Amps	Min. Circuit Protection (Amps)
RAK204E15	8150	2460	9.6	15
RAK204E20	11550	3460	13.3	20
RAK204E30	16350	4860*	18.6	30

Electric Heat Amps include electric heater and fan motor current draw.
Each 265-volt sub-base kit consists of a sub-base with appropriate receptacle for minimum circuit amperage, a chaseway to route the power connector from the sub-base to the chassis and wiring to connect the sub-base to the building wiring.
*Wattage not available with 7,000 BTU systems.

The 265-volt power connection kit must be ordered separately.

All wiring must conform to local electrical regulations and codes.

ESSENTIAL ELEMENTS ORDERING OVERVIEW

230/208-volt line-cord connected units — order line cord kit. 230/208-volt sub-base connected units — order sub-base (includes power connection kit) and junction box for chassis (if hard wired).

265-volt units — order sub-base and power connection kit separately.

ELECTRICAL WIRING INFORMATION – 4100/6100 SERIES

All Zonelines are single-phase 60 hertz units.

For all installations, the feeder, sub-feeder, branch circuit and electrical protective devices and selection must conform to the National Electrical Code (NEC) and to local codes.

Maximum connected load in amperes, including demands for the electric heater and the fan motor, are shown on page 45. Branch circuit ampacity and electrical protective device sizing are shown on page 43 for 230/208-volt and for 265-volt units.

More than one unit per branch circuit is not recommended. When in doubt, consult the NEC. All wiring, including installation of receptacle, must conform to local electrical regulations and codes.

REPLACEMENT OF EXISTING CHASSIS

230/208-Volt and 265-Volt Units


There have been changes to NEC and improvements and modifications to the Zoneline® chassis and sub-bases since the unit was first introduced. Some of these changes require alterations to be made when replacing an older unit with a new chassis.

Line-Cord Connected Units

The plug configuration of new line-cord connected units complies with the current NEC standards. Older installations may have wall receptacles that conformed to NEC standards at the time the building was constructed and may not match the configuration of the plug on the new line cord. The recommended solution is to change the wall receptacle to conform to current standard plug configuration. See chart on this page for current receptacle configuration.



Typical Line-Cord Power Connection Kit RAK3203A shown



Maximum Cord Extension

Permanently Connected Units With Sub-Base

If the existing unit is connected to a sub-base, the installation of the new unit may involve modifying the existing installation slightly. It is recommended these modifications be made by a qualified electrician.

If the existing sub-base is the full width of the wall case, RAK201 sub-base access plate may be ordered and used to replace the cover on the old sub-base. Field-supplied wiring, conduit and conduit connectors should be used to make a connection between the new chassis and the center knockout of the RAK201. The wiring connections should be made inside the sub-base and the RAK201 attached to the sub-base with the two screws provided.

If the existing sub-base is not the full width of the wall case, the electrician will have to modify the existing cover plate to allow field-supplied wiring, conduit and conduit connectors to be run from the permanent connection kit to the sub-base.

The wiring harness can be ordered separately as RAK4002CW.

Receptacle

•			
Туре	Mfg	Part No	Configuration
15 AMP Tandem NEMA6-15R	Hubbell P&S	5661 5661	
20 AMP Perpendicular NEMA6-20R	Hubbell P&S	5461 5871	
30 AMP Large Tandem NEMA6-30R	Hubbell P&S	9330 5930	

MAXIMUM CONNECTED LOAD

The maximum connected load of a Zoneline unit occurs when the unit is in resistance heating operation. The maximum amperage shown in the tables below is the combined total of the resistance heater and the indoor fan motor.

230/208-Volt Line-Cord Connected Units

			Power Coi	nnector Kit		
	RAH	3153A (4157 04D15P	RAK	3203A 4207 04D20P	RAK3 RAK4 RAK20	4307
MODEL NUMBER	230 V	208 V	230 V	208 V	230 V	208 V
AZ41E07DA*	11.0	11.6	15.1	16.0	N/A	N/A
AZ41E09DA*	11.0	11.6	15.1	16.0	21.2	22.4
AZ41E12DA*	11.0	11.6	15.1	16.0	21.2	22.4
AZ41E15DA*	11.0	11.6	15.1	16.0	21.2	22.4
AZ61H07DA*	11.0	11.6	15.1	16.0	N/A	N/A
AZ61H09DA*	11.0	11.6	15.1	16.0	21.2	22.4
AZ61H12DA*	11.0	11.6	15.1	16.0	21.2	22.4
AZ61H15DA*	11.0	11.6	15.1	16.0	21.2	22.4

^{*}All versions

Electric Heat Amps include electric heater and fan motor current draw.

265-Volt Units

	Sub-Base/Power Connector Kit				
	RAK204E15 RAK5172 RAK5157	RAK204E20 RAK5202 RAK5207	RAK204E30 RAK5302 RAK5307		
MODEL NUMBER	265 V	265 V	265 V		
AZ41E07EA	9.6	13.3	N/A		
AZ41E09EA*	9.6	13.3	18.6		
AZ41E12EA*	9.6	13.3	18.6		
AZ41E15EA*	9.6	13.3	18.6		
AZ61H07EA*	9.6	13.3	N/A		
AZ61H09EA*	9.6	13.3	18.6		
AZ61H12EA*	9.6	13.3	18.6		
AZ61H15EA*	9.6	13.3	18.6		

^{*}All versions

Electric Heat Amps include electric heater and fan motor current draw.

LATENT SYSTEM CAPACITY

The total capacity of an air conditioner is made up of the **sensible** capacity, the output of the unit used to remove heat from the air in the area being conditioned, and the **latent** capacity, the output of the unit used to dehumidify the air in the area being conditioned. For humid climates and applications, the sensible/latent capacity split of the unit should be considered. The sensible capacity listed in the specification charts on pages 54 and 55 is at a standard rating condition of 95°F dry bulb/75°F wet bulb outdoors; 80°F

dry bulb/67°F wet bulb indoors. The latent system capacity is 1.00 minus the sensible capacity. (If the sensible capacity is listed at .74 the latent capacity is .26. This means that 74% of the capacity of the unit is used to remove heat from the air and 26% is used to remove moisture from the air at standard test conditions.)

In some applications, information about the sensible/latent split, or ratio, at conditions other than the standard rating conditions is needed.

NORMAL YEARLY OPERATING DATA

(Cooling Hours based on 75°F indoor temperature with air conditioner sized to meet the design conditions.)

Location	ASHRAE Heating Degree Days	Estimated Cooling Hours	Location	ASHRAE Heating Degree Days	Estimated Cooling Hours		Location	ASHRAE Heating Degree Days	Estimated Cooling Hours
ALABAMA	,		I/ENITH CI//	,		1 1	OHIO		
Birmingham	2,551	1,390	KENTUCKY Lexington	4,683	830		Cincinnati	5,265	840
Huntsville	3,070	1,340	Louisville	4,660	1,130		Cleveland	6,351	610
Mobile	1.560	1.640	LOUISIANA	4,000	1,130		Columbus	5,660	810
Montgomery	2,291	1,580	Alexandria	1,921	1,670		Dayton	5,622	740
ARIZONA	2,231	1,500	Baton Rouge	1,560	1,860		Toledo	6,494	590
Flagstaff	7.152	310	New Orleans	1,385	1,790		OKLAHOMA	0,454	330
Phoenix	1,765	2,280	Shreveport	2,184	1,470		Oklahoma City	3,725	1,200
Tucson	1,800	1,920	MAINE	2,104	1,470		Tulsa	3.860	1,410
Yuma	974	2,520	Portland	7,511	290		OREGON	3,000	1,410
ARKANSAS] ,,,	2,320	MARYLAND	7,511	250		Medford	5,008	620
Fort Smith	3,292	1,410	Baltimore	4,654	850		Pendleton	5,127	590
Little Rock	3,219	1,330	MASSACHUSETTS	7,057	030		Portland	4,635	270
CALIFORNIA	3,213	1,550	Boston	5,634	500		PENNSYLVANIA	4,055	270
Bakersfield	2,122	1,530	MICHIGAN	3,034	300		Harrisburg	5,251	730
Fresno	2,611	1,210	Detroit	6,293	590		Philadelphia	5,144	810
Los Angeles	2,061	310	Flint	7,377	440		Pittsburgh	5,987	590
Sacramento	2,502	1,030	Grand Rapids	6,894	530		Scranton	6,254	440
San Diego	1.458	390	MINNESOTA	0,054	330		Williamsport	5,934	600
San Francisco	3,015	110	Duluth	10,000	200		RHODE ISLAND	3,554	000
COLORADO	3,013	110	Minneapolis	8,382	550		Providence	5,954	470
Colorado Springs	6,423	520	MISSISSIPPI	0,502	330		SOUTH CAROLINA	3,554	470
Denver	6,283	550	Jackson	2,239	1,560		Charleston	2,033	1,390
Grand Junction	5,641	910	MISSOURI	2,233	1,500		Columbia	2,484	1,440
CONNECTICUT	3,041	310	Columbia	5,046	960		Greenville	2,980	1,120
Hartford	6,235	480	Kansas City	4,711	1,210		SOUTH DAKOTA	2,500	1,120
DISTRICT of COLUMBIA	0,233		Springfield	4,900	970		Rapid City	7,345	580
Washington	4,224	1,010	St. Louis	4,900	1,080		Sioux Falls	7.839	610
DELAWARE	.,	2,010	MONTANA	1,500	1,000		TENNESSEE	1,000	010
Wilmington	4,930	770	Billings	7,049	520		Chattanooga	3,254	1,180
FLORIDA	,,500		Glasgow	8,996	410		Knoxville	3,494	1,070
Jacksonville	1,239	1,690	Great Falls	7,750	420		Memphis	3,232	1,320
Miami	214	2,850	Missoula	8,125	350		Nashville	3,578	1,220
Orlando	766	1,930	NEBRASKA	-,			TEXAS	-,,,,,	_,
Tallahassee	1,485	1,500	Grand Island	6,530	770		Corpus Christi	914	2,380
Tampa	683	2,350	Omaha	6,612	750		Dallas	2,363	1,900
GEORGÍA		'	NEVADA				El Paso	2,700	1,580
Atlanta	2,961	1,130	Ely	7,733	500		Houston	1,396	1,850
Augusta	2,397	1,400	Lás Vegas	2,709	1,980		Lubbock	3,578	1,310
Macon	2,136	1,440	Reno	6,332	520		San Antonio	1,546	1,920
Savannah	1,819	1,510	NEW JERSEY				UTAH	1	
IDAHO			Newark	4,589	710		Milford	6,497	910
Boise	5,809	670	NEW MEXICO				Salt Lake City	6,052	830
Lewiston	5,542	600	Albuquerque	4,348	1,040		VERMONT		
Pocatello	7,033	570	Clayton	5,158	720		Burlington	8,269	130
ILLINOIS			Silver City	3,705	1,260		VIRGINIA		
Chicago	6,155	780	NEW YORK				Norfolk	3,421	1,010
Moline	6,408	760	Albany	6,875	480		Richmond	3,865	1,020
Springfield	5,429	890	Binghamton	7,286	310		Roanoke	4,150	870
INDIANA			Buffalo	7,062	450		WASHINGTON		
Evansville	4,435	1,090	New York	4,811	790		Seattle	5,145	180
Fort Wayne	6,205	710	Rochester	6,748	470		Spokane	6,655	430
Indianapolis	5,699	820	Syracuse	6,756	500		Yakima	5,941	530
South Bend	6,439	600	NORTH CAROLINA		[WEST VIRGINIA		
IOWA			Asheville	4,042	690		Charleston	4,476	860
Burlington	6,114	730	Charlotte	3,191	1,230		Huntington	4,446	820
Des Moines	6,588	710	Raleigh	3,393	1,070		WISCONSIN		
Sioux City	6,951	770	Winston-Salem	3,595	960		Madison	7,863	530
KANSAS			NORTH DAKOTA		[Milwaukee	7,635	450
Dodge City	4,986	1,020	Bismarck	8,851	510		WYOMING		
Goodland	6,141	800	Fargo	9,226	490		Casper	7,410	600
Topeka	5,182	880	Williston	9,243	580		Cheyenne	7,381	420
Wichita	4,620	1,070					Sheridan	7,680	530

Formula for Calculating Operating Costs Using Above Data:


 $\label{eq:heating*-leaving} Heating^* - \frac{\text{Heat Loss KW x Heating Degree Days x "C" x Cost Per KWH}}{\text{Outdoor Design Temperature Difference}} = \text{Operating Cost}$

The local power supplier should be consulted for recommended value of "C." This factor will vary between 17 and 24.

 $\text{Cooling} - \frac{\text{Calculated Heat Gain (BTUH)}}{\text{Installed unit capacity (BTUH)}} \ \ \text{x} = \frac{\text{Unit Cooling Watts}}{1000 \ \text{Watts/KW}} \ \ \text{x} \ \ \text{Cooling Hours} \ \ \text{x} \ \ \text{Cost per KWH} \ = \ \text{Operating Cost}$

^{*}The above formula is for electric resistance heating only. Power consumption using the Zoneline® heat pumps should be adjusted by Seasonal Performance Factor (SPF).

TYPICAL 4100 SERIES, 230/208-VOLT WIRING DIAGRAM



NOTE:

*1:The lead wires are multicolured with black tube.
*2:The jointwires are white except that the first one is red.
*3:The 7k BTU models don't have this wire.

2.COLOR: BK:BLACK BL:BLUE GY:GRAY WH:WHITE BR:BROWN OR:ORANGE YL:YELLOW

3.THERMISTOR SENSOR RESISTANCE:

SENSOR RESISTANCE(ohm)				
degF	ROOM	I.D COIL		
10	63260	94900		
30	34620	51940		
32	32860	49330		
50	19970	29960		
70	11950	17930		
90	7320	10970		

4.TRANSFORMER WINDING RESISTANCE:

MODEL NAME	PRIMARY COIL RESISTANCE(ohm) BK-BK	SECONDARY COIL RESISTANCE(ohm) WH-WH
208/230V PA052JB	100±10%	1.31±10%
265V PA053JB	127±10%	1.27±10%

5.This diagram applied to AZ41E series. 6.HEATER RESISTANCE: TEST TEMPERATURE IS 68degF.

HEATER	CHECK POINT	HEATER RESISTANCE(ohm	
	CONNECTOR	208V/230V	265V
1.0kW	PIN NO.1-4 BK-BR	195±35%	200±35%
1.4kW	PIN NO.2-5 RD-YL	200±35%	205±35%
2.4kW	PIN NO.3-6 WH-BL	75±35%	85±35%

	WINDING RESISTANCE(ohm)				
	INDOOR	OUTDOO			
MODEL NAME	MOTOR RD-BK	HIGH SPEED RD-BK	LOW SPEED WH-BK		
AZ41E07DAB	183±15%	390±15%	284±15%		
AZ41E07DAC	183±15%	399±15%	148±15%		
AZ41E07DAP	183±15%	399±15%	148±15%		
AZ41E07EAB	265±15%	400±15%	234±15%		
AZ41E07EAC	265±15%	400±15%	139±15%		
AZ41E07EAP	265±15%	400±15%	139±15%		
AZ41E09DAB	183±15%	193±15%	204±15%		
AZ41E09DAC	183±15%	193±15%	204±15%		
AZ41E09DAP	183±15%	193±15%	204±15%		
AZ41E09EAB	265±15%	294±15%	125±15%		
AZ41E09EAC	265±15%	294±15%	125±15%		
A441E09EAP	265±15%	294±15%	125±15%		
AZ41E12DAB	183±15%	126±15%	146±15%		
AZ41E12DAC	183±15%	126±15%	146±15%		
AZ41E12DAP	183±15%	126±15%	146±15%		
AZ41E12EAB	265±15%	148±15%	124±15%		
AZ41E12EAC	265±15%	148±15%	124±15%		
AZ41E12EAP	265±15%	148±15%	124±15%		
AZ41E15DAB	183±15%	126±15%	146±15%		
AZ41E15DAC	183±15%	126±15%	146±15%		
AZ41E15EAB	265±15%	148±15%	124±15%		
AZ41E15EAC	265±15%	148±15%	124±15%		

8.FAULT ANALYSIS OF INDOOR FAN MOTOR


If the motor winding resistance is out of spec,please check whether it's the motor's problem;

If there is no voltage between pin1 and pin2 of CN102, please check whether it's the problem of PWB.


47

47

TYPICAL 4100 SERIES, 230/208-VOLT SCHEMATIC DIAGRAM



TYPICAL 6100 SERIES, 230/208-VOLT WIRING DIAGRAM



- 1.
 **I:The lead wires are multicolured with black tube.
 **2:The jointwires are white except that the first one is red.
 **3:The XBTU models don't have this wire.
 **4:AZ61H series don't have these wires, except for
 AZ61H07DAD.AZ61H09DAD.AZ61H12DAD.AZ61H15DAD.
 AZ61H07EAD.AZ61H09EAD.AZ61H12EAD.AZ61H15EAD.
- 2. COLOR:

OR:ORANGE RE:RED WH:WHITE YL:YELLOW BK:BLACK BL:BLUE BR:BROWN GR:GREEN GY:GRAY

3. THERMISTOR SENSOR RESISTANCE:

SENSOR RESISTANCE(ohm)					
degF	ROOM	I.D COIL	O.D COIL &OUTDOOR		
10	63260	94900	28030		
30	34620	51940	15340		
32	32860	49330	14570		
50	19970	29960	8850		
70	11950	17930	5300		
90	7320	10970	3280		

4. TRANSFORMER WINDING RESISTANCE:

MODEL NAME	PRIMARY COIL RESISTANCE(ohm) BK-BK	SECONDARY COIL RESISTANCE(ohm) WH-WH
208/230V PA052JB	100 ` 10%	1.31 ` 10%
265V PA053JB	127 ` 10%	1.27 ` 10%

5. This diagram applied to AZ61H series. 6. Heater resistance: TEST TEMPERATURE IS 68degF.


HEATER	CHECK POINT	HEATER RES	ISTANCE(ohm)
	HEATER CONNECTOR	208V/230V	265V
1.0kW	PIN NO.1-4 BK-BR	195 ` 35%	200 ` 35%
1.4kW	PIN NO.2-5 RD-YL	200 ` 35%	205 ` 35%
2.4kW	PIN NO.3-6 WH-BL	75` 35%	85` 35%

TOR VOLTAGE:

(1)CN103:PIN 1-2(BK-WH) DC15V; PIN1-6(BK-RD): The DC voltage is AC power supply voltage x 1.4 (2)CN102:PIN1-2(BK-WH) DC15V; PIN1-5(BK-RD): The DC voltage is AC power supply voltage x 1.4

NOTICE: Turn off the power supply for 2 minutes before disconnecting motor connector (CN102.CN103). or motor damage may occur.

TYPICAL 6100 SERIES, 230/208-VOLT SCHEMATIC DIAGRAM



SUGGESTED BID FORM SPECIFICATIONS

The following are suggested specifications for the Zoneline® 4100 Series Packaged Terminal Air Conditioner and the 6100 Series Packaged Terminal Heat Pump.

The contractor will furnish Packaged Terminal Air Conditioners of the sizes and capacities shown on the schedule and in the specifications. The units shall be located as shown on the drawings and each shall consist of a chassis, room cabinet, wall case, sub-base if specified, and outdoor grille.

Units shall be listed by UL, and AHRI and cUL certified as to capacity and efficiency and shall be GE Zoneline models or equal. Unit dimensions shall not exceed 42-1/8" wide and 16-1/4" high with room cabinet in place.

Units shall be designed to operate on (208) (230) (265) volts, 60 Hz, single-phase power.

Chassis. The air conditioner chassis shall be the standard product of the manufacturer and shall be shipped in protective cartons to prevent damage. Cartons shall be appropriately marked at the factory with wording sufficient to warn handlers against improper stacking, up-ending, rolling or dropping. The chassis shall be the slide-in type, ready to operate after installation

Each shall consist of the following sections and components:

- Each unit shall have a matching, easily removable, textured finish, wrap-around room cabinet molded of hightemperature styrene to resist corrosion and damage. The room cabinet shall have slide-out washable filters accessible without requiring removal of room cabinet from chassis;
- Hermetically sealed refrigerant system with external vibration isolated rotary-type compressor, condenser and evaporator coils and capillary refrigerant control. Airflow system consisting of one permanently lubricated two-speed fan motor for the outdoor fan and a separate permanently lubricated two-speed fan motor for the indoor fan. Outdoor fan shall be multi-blade axial-flow design made of non-corrosive material. Indoor fan shall be of a design to optimize airflow and operating sound. All motors on the exterior side of the weather barrier shall be of an enclosed design to reduce the effects of moisture and corrosion;
- Line-cord connected units shall require a line-cord power connection kit with integral Leakage Current Detection and Interruption device or Arc Fault Current Interrupter as required by National Electrical Code® (NEC) and Underwriters Laboratories. The unit shall have a universal resistance heater with output determined by connection to the power source with the appropriate power connection kit to provide specified heat output;
- A fan-cycle option to permit continuous fan operation or fan cycle operation, independently selectable for heating and cooling operation;
- Fan-only operation in either high or low fan speed selectable by room occupant;
- A positive cooling condensate disposal system which meets the test requirements of applicable AHRI Standard 310 (for Packaged Terminal Air Conditioners) and 380 (for Packaged Terminal Heat Pumps) (80°F dry bulb, 75°F wet bulb, 80% relative humidity);

- Condenser and evaporator coils to be constructed of copper tubing and aluminum plate fins designed to achieve EER and COP rating of the unit;
- Indoor and outdoor airflows that match the capacity of the coils for efficient heat transfer. Water blow-off shall not occur on the indoor coil;
- Adjustable indoor discharge air louvers that provide a 50° off vertical air pattern with an alternate position to provide a 40° off vertical air pattern;
- Easily accessible controls for selection of unit operation and thermostat setting. Controls shall be covered by a hinged door;
- Positive-closing, manually controlled, three-position fresh-air vent capable of providing selection of fully open, partially open or closed setting. Vent door is to be secured for shipping;
- Solid-state thermostat control to sense room temperature;
- Electronic temperature limiting with seven independent heating and cooling settings to limit maximum and minimum temperatures without restricting movement of thermostat control knob;
- Freeze Sentinel to automatically activate the electric
 resistance heater and fan motor to warm and circulate indoor
 air to help prevent damage due to freezing temperatures.
 Freeze Sentinel shall operate as long as unit is connected
 to powered electrical circuit and unit shall provide ability for
 owner to defeat the Freeze Sentinel operation;
- Heat Sentinel to automatically activate air conditioner operation when the unit is in the STOP setting when the room temperature warms to 85°F and turns air conditioner operation off when the room temperature cools to 80°F, if selected by owner;
- Compatible with two-wire Central Desk Control systems;
- Remote Thermostat compatibility with Class 2 remote thermostat;
- Connections to interface with a transfer fan to move air into another room:

Unit shall have means of electrical connection listed by Underwriters Laboratories and compatible with the unit's required voltage and ampacity in conformance with National Electrical Code and local codes.

Additional specifications for GE Zoneline 6100 Series Packaged Terminal Heat Pumps

Heat pump units shall provide operation that will either: A) automatically phase in electric resistance heat, if outdoor temperature is below 46°F, if heat pump alone is unable to maintain room temperature; or B) use partial electric resistance heat simultaneous with heat pump operation any time the outdoor temperature is below 46;°F. Selection of A or B operation is made by means of a selector concealed from room occupant. In either A or B operation, the unit will switch to full resistance heat if room temperature continues to decline or the outdoor temperature falls below 25°F. If the outdoor temperature is above 46°F, unit will lock out electric resistance heat and operate on heat pump only.

SUGGESTED BID FORM SPECIFICATIONS (cont)

Heat pump unit shall include Reverse Cycle Defrost that automatically begins a defrost cycle when microprocessor determines criteria for defrosting has been met. Defrosting shall be accomplished by systematically ceasing heat pump operation, pausing to allow internal refrigerant pressures to equalize, then operating the compressor with the flow of refrigerant reversed to allow the hot gas to flow through the outdoor coil, melting the accumulated frost. The unit shall automatically resume heat pump operation, after pausing to allow refrigerant pressures to equalize, at conclusion of defrost cycle.

The unit shall be equipped with a temperature-activated drain valve to allow water generated in heat pump operation and defrost cycles to drain into the wall case.

The unit shall have a switch concealed from room occupant to allow heat pump operation to be overridden and heat provided by electric resistance heat regardless of outdoor temperature.

In the event of compressor failure during heat pump operation, unit shall automatically switch to electric resistance heat to maintain selected room temperature regardless of outdoor temperatures.

Specifications for optional Internal Condensate Removal (ICR) system for 6100 Series heat pump units.

The unit shall have a factory-installed Internal Condensate Removal (ICR) system to permit unit to automatically dispose of heat-pump-generated condensate water with no overflow to outdoors during heating under outdoor ambient of 55°F dry bulb, 90% relative humidity; indoor ambient 70°F dry bulb, 52% relative humidity, for four hours of continuous run time.

Wall Cases and Grilles (needed for new installations.) (Alternate specification for steel wall case)

Wall Case. The wall case shall be constructed of heavy-gauge, insulated, zinc-coated phosphated steel with a protective baked-on enamel finish. Bottom critical points of the steel wall case shall be coated with petroleum microcrystalline wax for added corrosion protection and shall meet ASTM B-117, 1800-hour hot air aerated salt spray test.

(Alternate specification for molded wall case)

Wall Case. The wall case shall be constructed of a non-corroding fiberglass-reinforced polyester compound.

Cases shall be installed through exterior walls where shown on the plans and shall be installed per manufacturer's installation instructions. In no instance shall fasteners be used through the bottom in order to retain the water integrity of the bottom of the wall case.

Outside weather panels shipped with the cases shall remain in place until the outdoor air louvers and chassis are installed, at which time they are to be removed and discarded by the installer.

Outside Grille. Each unit shall be equipped with a standard exterior grille that has been designed to allow unit operation in high ambient conditions. Grilles shall be of material and design specified.

Special grilles or customer louver sections to be supplied by others will conform to a minimum of 65% free area (as calculated by ASHRAE) to allow for proper unit operation and shall be submitted to the PTAC/PTHP manufacturer, if requested, for feasibility and airflow characteristics.

Specifications for Sub-Base (if required)

Sub-Base. Each unit shall have a field-installed UL-listed electrical sub-base. The sub-base shall be attached to the lower inside flange of the wall case prior to installation in the exterior wall. It shall include adjustable screws at the bottom corners to permit exact leveling of the wall case. The sub-base shall have a factory-installed receptacle to allow unit line cord to plug into mating receptacle and shall have a chaseway to contain and conceal the line cord. The sub-base shall have side panels adjustable from a minimum of 2-3/8" to a maximum of 13-3/4" to enclose the area under the wall case.

Weather Resistance. Complete unit including outside louver shall be submitted to an independent agency for weather-resistance tests.

Air-infiltration test to be conducted in accordance with ASTM E283-91. With static air pressure differential of 1.57 lb./ft.² (.3" H²O) equivalent to 25 mph wind, allowable air infiltration shall not exceed 7 ft.³/min.

Water-infiltration test to be conducted in accordance with ASTM E331-86 with static air pressure differential of 10.0 lb./ft² (1.93" H²0) equivalent to 63 mph wind, 5.0 gal./ft² (8" rain/ft²/hr.) for 15 minutes and there shall be no leakage into the room.

Approvals. Units shall be certified under the AHRI and cUL certification program and listed by UL.

Service. Submit complete information with bid covering service availability to whom service on units will be assigned, along with complete address and phone number, including phone number of emergency service personnel.

Start-Up, Adjust, Demonstrate. Contractor shall be responsible for the initial starting of units, adjustments thereto, etc., to place the units in required operating condition. Contractor shall demonstrate to the owner or his representative the operation of units for both summer and winter functions.


Warranty. The warranty shall be a full one-year parts and labor on the entire unit, plus an additional full four years parts and labor for the sealed refrigerating system, including service call for diagnosis and transportation to and from service shop (if necessary) at no charge to the customer. The warranty shall also include a limited second-through-fifth-year parts-only warranty for fan motors, switches, thermostat, heater, heater protectors, compressor overload, solenoids, circuit boards, auxiliary controls, thermistors, frost controls, ICR pump, capacitors, varistors and indoor blower bearing.

Installation Responsibility. Units shall be installed according to the manufacturer's recommendations and the manufacturer shall not be responsible for unit failure as a result of improper installation, or unit performance when installed with accessories not approved by the manufacturer.

ZONELINE® CHASSIS NOMENCLATURE

The Zoneline chassis is identified by a model number defining the type of unit, cooling capacity, electrical information and optional features included on the unit. When specifying or ordering the Zoneline chassis, use of this nomenclature will assure receiving the correct unit.

EXAMPLE



RECEPTACLES/SUB-BASES



Tandem 230/208V 15 Amp NEMA6-15R



Perpendicular 230/208V 20 Amp NEMA6-20R



Large tandem 230/208V 30 Amp NEMA6-30R



265V 15 Amp NEMA7-15R



265V 20 Amp NEMA7-20R:



265V 30 Amp NEMA7-30R:

Sub-bases							
	RAK204U	RAK204D15P	RAK204D20P	RAK204D30P	RAK204E15	RAK204E20	RAK204E30
Voltage	N/A	230/208	230/208	230/208	265	265	265
Amps	N/A	15	20	30	15	20	30
Receptacle	N/A	NEMA6-20R	NEMA6-20R	NEMA6-30R	NEMA7-15R	NEMA7-20R	NEMA7-30R

^{230/208} Volt sub-bases include appropriate power cord kit

Power connection kits are required on all Zoneline® chassis (see chart below).

The correct kit for the installation is determined by the voltage and amperage of the electrical circuit and the means of connecting the unit to the building wiring. If the unit is to be plugged into a receptacle, a line-cord kit would be used; if the unit is to be permanently connected, a permanentconnection kit would be used. 265 volt cord set units must be installed in compliance with National Electrical Code®.

Power connection kits Required on all models. See specification sheet for heater KW and branch circuit ampacity.



RAK3153A/3203A/3303A 230/208 volt line-cord connection kit



RAK4157/4207/4307 230/208 volt universal power supply kit

RAK5172

2,460

8,150

9.6

15

15 amp

time-delay fuse



RAK5157/5207/5307 265 volt universal power supply kit

265 volt Permanent-connected units** (Cord set)

RAK5302

4,860*

16,350

18.6

30

30 amp

time-delay fuse

RAK5202

3,460

11,550

13.3

20

20 amp

time-delay fuse

230/208 volt	Line-cord connected units			
LCDI Power Connection Kit	RAK3153A	RAK3203A	RAK3303A	
Heater KW	2.4/2.32	3.3/3.2	4.7/4.53	
Watts	2,450/2,360	3,350/3,230	4,750/4,580*	
BTUH	8,150/7,900	11,200/10,900	16,000/15,450	
Amps	11.0/11.6	15.1/16.0	21.2/22.4	
Min. circuit amps	15	20	30	
Recommended protective device	15 amp time-delay fuse or breaker	20 amp time-delay fuse or breaker	30 amp time-delay fuse or breaker	

230/208 volt	08 volt Direct-connection kit [†]				
	RAK4157	RAK4207	RAK4307		
Heater KW	2.4/2.32	3.3/3.2	4.7/4.53		
Watts	2,450/2,360	3,350/3,230	4,750/4,580*		
BTUH	8,150/7,900	11,200/10,900	16,000/15,450		
Amps	11.0/11.6	15.1/16.0	21.2/22.4		
Min. circuit amps	15	20	30		
Recommended protective device	15 amp time-delay fuse or breaker	20 amp time-delay fuse or breaker	30 amp time-delay fuse or breaker		

265 volt Direct-connection kit [†]					
RAK5157	RAK5157 RAK5207 RAK5307				
2.4	3.4	4.8			
2,460	3,460	4,860*			
8,150	11,550	16,350			
9.6	13.3	18.6			
15	20	30			
15 amp time-delay fuse	20 amp time-delay fuse	30 amp time-delay fuse			

²⁵⁶⁵ Volt units are to be direct connected. Cordet through enclosed chaseway into interior sub-base receptacle meets the NEC requirements.

^{*}Wattage not available with 7,000 BTU systems.

^{**}To be used with sub-base

[†]To be used with sub-base or connection to building wiring Specifications subject to change.

PRELIMINARY SPECIFICATIONS

	4100 series cooling with electric heat				
230/208V Models	AZ41E07DAB	AZ41E09DAB	AZ41E12DAB	AZ41E15DAB	
Capacity					
Cooling BTUH	7,200/6,900	9,700/9,600	11,800/11,500	14,300/14,000	
EER (BTU/Watt)	12.3/12.3	12.0/12.0	11.1/11.1	10.3/10.3	
Dehumidification Pts/Hr	1.7	2.7	3.5	4.6	
Features					
Refrigerant type	R-410A	R-410A	R-410A	R-410A	
CFM, indoor fan high	290	340	420	409	
CFM, indoor fan low	219	229	323	324	
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45	
Power/Ratings					
Power factor	89%	93%	93%	90%/92%	
Sensible heat ratio @ 230 volts	80%	75%	70%	70%	
Watts	580/560	805/795	1,060/1,035	1,370/1,350	
Cooling Amperes, F.L.	2.8/3.0	3.6/3.9	4.7/5.1	6.7/7.2	
Amperes, L.R.	19.0	21.0	29.5	31.0	
Weight (Net/Ship)	89.2/102.5	100.0/113.0	99.4/112.4	100.3/113.3	

265V Models	AZ41E07EAB	AZ41E09EAB	AZ41E12EAB	AZ41E15EAB
Capacity				
Cooling BTUH	7,200	9,700	11,800	14,300
EER (BTU/Watt)	12.3	12.0	11.1	10.3
Dehumidification Pts/Hr	1.7	2.7	3.5	4.6
Features				
Refrigerant type				
CFM, indoor fan high	290	340	420	406
CFM, indoor fan low	215	229	323	324
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	90%	91%	92%	92%
Sensible heat ratio @ 265 volts	80%	75%	70%	70%
Watts	580	805	1,025	1,385
Cooling Amperes, F.L.	2.4	3.2	4.1	5.7
Amperes, L.R.	12.0	16.5	23.5	26.0
Weight (Net/Ship)	91.3/104.3	101.2/114.2	99.9/112.9	101.0/114.0

	4100 series cooling with electric heat (corrosion treated mo				
230/208V Models	AZ41E07DAC	AZ41E09DAC	AZ41E12DAC	AZ41E15DAC	
Capacity					
Cooling BTUH	7,200/6,900	9,700/9,600	11,800/11,500	14,300/14,000	
EER (BTU/Watt)	12.3/12.3	12.0/12.0	11.1/11.1	10.3/10.3	
Dehumidification Pts/Hr	1.7	2.7	3.5	4.6	
Features					
Refrigerant type	R-410A	R-410A	R-410A	R-410A	
CFM, indoor fan high	290	340	420	409	
CFM, indoor fan low	218	229	323	324	
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45	
Power/Ratings					
Power factor	89%	93%	93%	90%/92%	
Sensible heat ratio @ 230 volts	80%	75%	70%	70%	
Watts	580/560	805/795	1,060/1,035	1,370/1,350	
Cooling Amperes, F.L.	2.8/3.0	3.6/3.9	4.7/5.1	6.7/7.2	
Amperes, L.R.	19.0	21.0	29.5	31.0	
Weight (Net/Ship)	91.3/104.3	100.3/113.3	99.4/112.4	100.3/113.3	

s)				
265V Models	AZ41E07EAC	AZ41E09EAC	AZ41E12EAC	AZ41E15EAC
Capacity				
Cooling BTUH	7,200	9,700	11,800	14,300
EER (BTU/Watt)	12.3	12.0	11.1	10.3
Dehumidification Pts/Hr	1.7	2.7	3.5	4.6
Features				
Refrigerant type				
CFM, indoor fan high	290	340	420	406
CFM, indoor fan low	215	229	323	324
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	90%	91%	92%	92%
Sensible heat ratio @ 265 volts	80%	75%	70%	70%
Watts	580	805	1,025	1,385
Cooling Amperes, F.L.	2.4	3.2	4.1	5.7
Amperes, L.R.	12.0	16.5	23.5	26.0
Weight (Net/Ship)	91.7/104.7	101.4/114.4	100.3/113.3	101.0/114.0

	Dry Air 25		
230/208V Models	AZ41E07DAP	AZ41E09DAP	AZ41E12DAP
Capacity			
Cooling BTUH	6,500/6,300	9,200/8,800	11,200/11,000
EER (BTU/Watt)	11.7/11.7	11.5/11.5	10.8/10.8
Dehumidification Pts/Hr	2.3	3.4	4.4
Features			
Refrigerant type	R-410A	R-410A	R-410A
CFM, indoor fan high	220	280	330
CFM, indoor fan low	190	208	270
Vent CFM (full open/partial open)	50/40	70/45	75/45
Power/Ratings			
Power factor	86%/87%	92%	92%
Sensible heat ratio @ 230 volts	60%	60%	60%
Watts	555/535	790/765	1,035/1,015
Cooling Amperes, F.L.	2.8/3.0	3.6/3.9	4.7/5.1
Amperes, L.R.	19.0	21.0	29.5
Weight (Net/Ship)	97.0/110.0	105.2/118.2	105.4/118.4

265V Models	AZ41E07EAP	AZ41E09EAP	AZ41E12EAP
Capacity			
Cooling BTUH	6,500	9,200	11,200
EER (BTU/Watt)	11.7	11.5	10.8
Dehumidification Pts/Hr	2.3	3.4	4.4
Features			
Refrigerant type			
CFM, indoor fan high	220	280	330
CFM, indoor fan low	190	208	270
Vent CFM (full open/partial open)	50/40	70/45	75/45
Power/Ratings			
Power factor	87%	91%	92%
Sensible heat ratio @ 265 volts	60%	75%	60%
Watts	555	795	1,020
Cooling Amperes, F.L.	2.4	3.2	4.1
Amperes, L.R.	12.0	16.5	23.5
Weight (Net/Ship)	97.4/110.5	104.9/117.9	108.0/121.0

	6100 series heat pump with backup electric heat			
230/208V Models	AZ61H07DAB	AZ61H09DAB	AZ61H12DAB	AZ61H15DAB
Capacity				
Cooling BTUH	7,100/6,900	9,400/9,100	11,700/11,600	14,500/14,200
EER (BTU/Watt)	13.0/13.0	12.2/12.2	11.6/11.6	10.6/10.6
Dehumidification Pts/Hr	1.7	2.7	3.5	4.5
Features				
Refrigerant type	R-410A	R-410A	R-410A	R-410A
CFM, indoor fan high	340	360	370	370
CFM, indoor fan low	194	212	284	290
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	91%	92%	92%	91%/92%
Sensible heat ratio @ 230 volts	85%	75%	70%	65%
Cooling Watts	545/525	755/740	985/965	1,360/1,335
Cooling Amperes, F.L.	2.6/2.8	3.5/3.8	4.6/5.0	6.3/6.8
Amperes, L.R.	19.0	21.0	29.5	31.0
Reverse cycle heat BTUH	6,200/6,100	8,300/8,100	10,600/10,400	13,500/13,400
COP	3.9/3.9	3.7/3.7	3.6/3.6	3.3/3.3
Heating Watts	465/445	650/635	855/835	1,165/1,120
Heating Amperes	2.2/2.4	3.1/3.3	4.1/4.5	5.8/6.3
Weight (Net/Ship)	94.1/107.1	101.4/114.4	102.1/115.1	100.8/113.8

265V Models	AZ61H07EAB	AZ61H09EAB	AZ61H12EAB	AZ61H15EAB
Capacity				
Cooling BTUH	7,000	9,400	11,700	14,400
EER (BTU/Watt)	12.8	12.2	11.6	10.6
Dehumidification Pts/Hr	1.7	2.7	3.5	4.5
Features				
Refrigerant type	R-410A	R-410A	R-410A	R-410A
CFM, indoor fan high	340	360	370	370
CFM, indoor fan low	194	211	284	290
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	94%	90%	92%	93%
Sensible heat ratio @ 265 volts	85%	75%	70%	65%
Cooling Watts	545	765	1,000	1,355
Cooling Amperes, F.L.	2.2	3.1	4.0	5.4
Amperes, L.R.	12.0	16.5	23.5	26.0
Reverse cycle heat BTUH	6,200	8,100	10,700	13,500
COP	3.9	3.6	3.6	3.3
Heating Watts	450	655	870	1,165
Heating Amperes	2.0	2.7	3.6	5.0
Weight (Net/Ship)	94.6/107.6	103.6/116.6	103.6/116.6	104.3/117.3

	6100 series he	eat pump with l	backup electric	heat (corrosion
230/208V Models	AZ61H07DAC	AZ61H09DAC	AZ61H12DAC	AZ61H15DAC
Capacity				
Cooling BTUH	7,100/6,900	9,400/9,100	11,700/11,600	14,500/14,200
EER (BTU/Watt)	13.0/13.0	12.2/12.2	11.6/11.6	10.6/10.6
Dehumidification Pts/Hr	1.7	2.7	3.5	4.5
Features				
Refrigerant type	R-410A	R-410A	R-410A	R-410A
CFM, indoor fan high	340	360	370	370
CFM, indoor fan low	194	212	284	290
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	91%	92%	92%	91%/92%
Sensible heat ratio @ 230 volts	85%	75%	70%	65%
Cooling Watts	545/525	755/740	985/965	1,350/1,330
Cooling Amperes, F.L.	2.6/2.8	3.5/3.8	4.6/5.0	6.3/6.8
Amperes, L.R.	19.0	21.0	29.5	31.0
Reverse cycle heat BTUH	6,200/6,100	8,300/8,100	10,600/10,400	13,500/13,400
COP	3.9/3.9	3.7/3.7	3.6/3.6	3.3/3.3
Heating Watts	465/445	650/635	855/835	1,190/1,155
Heating Amperes	2.2/2.4	3.1/3.3	4.1/4.5	5.8/6.3
Weight (Net/Ship)	94.1/107.1	102.3/115.3	105.4/118.4	104.5/117.5

265V Models	AZ61H07EAC	AZ61H09EAC	AZ61H12EAC	AZ61H15EAC
Capacity				
Cooling BTUH	7,000	9,400	11,700	14,400
EER (BTU/Watt)	12.8	12.2	11.6	10.6
Dehumidification Pts/Hr	1.7	2.7	3.5	4.5
Features				
Refrigerant type	R-410A	R-410A	R-410A	R-410A
CFM, indoor fan high	340	360	370	370
CFM, indoor fan low	194	211	284	290
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	94%	90%	92%	93%
Sensible heat ratio @ 265 volts	85%	75%	70%	65%
Cooling Watts	545	765	1,000	1,355
Cooling Amperes, F.L.	2.2	3.1	4.0	5.4
Amperes, L.R.	12.0	16.5	23.5	26.0
Reverse cycle heat BTUH	6,200	8,100	10,700	13,500
COP	3.9	3.6	3.6	3.3
Heating Watts	450	655	870	1,165
Heating Amperes	2.0	2.7	3.6	5.0
Weight (Net/Ship)	94.6/107.6	104.1/117.1	103.6/116.6	104.7/117.7

	6100 series heat pump with backup electric heat			
230/208V Models	AZ61H07DAD	AZ61H09DAD	AZ61H12DAD	AZ61H15DAD
Capacity				
Cooling BTUH	7,000/6,900	9,200/9,100	11,700/11,600	14,300/14,100
EER (BTU/Watt)	12.7/12.7	11.9/11.9	11.4/11.4	10.4/10.4
Dehumidification Pts/Hr	1.7	2.7	3.5	4.5
Features				
Refrigerant type	R-410A	R-410A	R-410A	R-410A
CFM, indoor fan high	340	360	370	370
CFM, indoor fan low	194	212	284	290
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	91%	92%	92%	91%/92%
Sensible heat ratio @ 230 volts	85%	75%	70%	65%
Cooling Watts	550/530	760/750	980/960	1,345/1,330
Cooling Amperes, F.L.	2.6/2.8	3.5/3.8	4.6/5.0	6.3/6.8
Amperes, L.R.	19.0	21.0	29.5	31.0
Reverse cycle heat BTUH	6,200/6,100	8,100/8,000	10,600/10,400	13,500/13,400
COP	3.9/3.9	3.6/3.6	3.6/3.6	3.2/3.2
Heating Watts	465/440	655/640	855/835	1,200/1,200
Heating Amperes	2.2/2.4	3.1/3.3	4.1/4.5	5.8/6.3
Weight (Net/Ship)	96.8/109.8	104.1/117.1	105.8/118.8	106.0/119.0

DOTAL ALL	47641107540	47541100540	A76411405AD	A36411455AB
265V Models	AZ61H07EAD	AZ61H09EAD	AZ61H12EAD	AZ61H15EAD
Capacity				
Cooling BTUH	6,900	9,200	11,700	14,300
EER (BTU/Watt)	12.7	11.9	11.4	10.4
Dehumidification Pts/Hr	1.7	2.7	3.5	4.5
Features				
Refrigerant type	R-410A	R-410A	R-410A	R-410A
CFM, indoor fan high	340	360	370	370
CFM, indoor fan low	194	211	284	290
Vent CFM (full open/partial open)	50/40	70/45	75/45	75/45
Power/Ratings				
Power factor	92%	90%	92%	93%
Sensible heat ratio @ 265 volts	85%	75%	70%	65%
Cooling Watts	540	760	1,015	1,355
Cooling Amperes, F.L.	2.2	3.1	4.0	5.4
Amperes, L.R.	12.0	16.5	23.5	26.0
Reverse cycle heat BTUH	6,200	8,200	10,900	13,500
COP	3.9	3.6	3.6	3.2
Heating Watts	455	665	880	1,210
Heating Amperes	2.0	2.7	3.6	5.0
Weight (Net/Ship)	97.0/110.0	106.3/119.3	106.5/119.5	106.3/119.3

COMPLETE ACCESSORY LIST

Kit Number	Description For Additional Information Re	fer to Page
RAA63	Spare Filters for AZ2900, AZ3900, AZ4100, AZ5800 and AZ6100 Series units	12
RAB71A	Steel Wall Case – 13-3/4" deep	23
RAB7116	Steel Wall Case – 16" deep	23
RAB7124	Steel Wall Case – 24" deep	23
RAB7128	Steel Wall Case – 28" deep	23
RAB7131	Steel Wall Case – 31" deep	23
RAB77A4	Molded Wall Case	23
RAD10	Interior/Exterior Drain kit	36
RAF453A	Room Front for A228, 29, 38, 39, 58, 41 & 61 series (included with chassis)	12
RAG60	Stamped Aluminum Exterior Grille	41
RAG61	Architectural Exterior Grille, Beige Molded High-Impact Plastic	41
RAG62	Architectural Exterior Grille, Maple Molded High-Impact Plastic	41
RAG63	Architectural Exterior Grille, Bittersweet Chocolate Molded High-Impact Plastic	41
RAG67	Aluminum Architectural Grille (Custom Colors Available by Special Order)	41
RAK40	Condenser Air Deflector Kit	41
RAK148D2	Wall Thermostat For Heat Pump Models - Electronic Digital	17
RAK148P2	Wall Thermostat For Heat Pump Models – Electronic Digital Programmable	17
RAK164D2	Wall Thermostat For Resistance Heat Models – Electronic Digital	16
RAK164P2	Wall Thermostat For Resistance Heat Models – Electronic Digital Programmable	16
RAK201	Sub-Base Cover Plate with Knockouts	44
RAK204D15P	Sub-Base - 208/230-Volt with NEMA 6-20R 15/20 Amp Receptacle – Power Cord and Chaseway included	23
RAK204D20P	Sub-Base - 208/230-Volt with NEMA 6-20R 15/20 Amp Receptacle - Power Cord and Chaseway included	23
RAK204D30P	Sub-Base - 208/230-Volt with NEMA 6-30R 30 Amp Receptacle - Power Cord and Chaseway included	24
RAK204E15	Sub-Base – 265-Volt with NEMA 7-15R 15 Amp Receptacle – Chaseway included	24
RAK204E20	Sub-Base – 265-Volt with NEMA 7-20R 20 Amp Receptacle – Chaseway included Sub-Base – 265-Volt with NEMA 7-20R 20 Amp Receptacle – Chaseway included	24
RAK204E30	Sub-Base – 265-Volt with NEMA 7-30R 30 Amp Receptacle – Chaseway included	24
RAK204U	Sub-Base – non-electrical Chaseway not included	23
RAK205CW	Chaseway for Sub-Base	23
	Universal Power Cord - 4100/6100 series - 15-Amp 230/208 V - 2.40/2.32 kW heat	43
RAK3153A		43
RAK3203A RAK3303A	Universal Power Cord – 4100/6100 – 20-Amp 230/208 V – 3.3/3.2 kW heat Universal Power Cord – 4100/6100 – 30-Amp 230/208 V – 4.7/4.53 kW heat	43
RAK4002A	Direct-Connect Junction Box – 230/208-volt units 4100/6100 Series	43
RAK4002B	Direct-Connect Junction Box – 230/208-volt units 5800 Series	43
RAK4002B		43
	Wiring Harness w/Inline Connector - Adapt Line Cord to Direct Connection	_
RAK4157	208/230V Universal Power Supply, 15 Amp for 2800, 2900, 3800, 3900, 4100, 5500, 5800, 6100, 7500 and 8500 only	43
RAK4207	208/230V Universal Power Supply, 20 Amp for 2800, 2900, 3800, 3900, 4100, 5500, 5800, 6100, 7500 and 8500 only	43
RAK4307	208/230V Universal Power Supply, 30 Amp for 2800, 2900, 3800, 3900, 4100, 5500, 5800, 6100, 7500 and 8500 only	
RAK5157	265V Universal Power Supply, 15 Amp for 2800, 2900, 3800, 3900, 4100, 5500, 5800, 6100, 7500 and 8500 only	53
RAK5207	265V Universal Power Supply, 20 Amp for 2800, 2900, 3800, 3900, 4100, 5500, 5800, 6100, 7500 and 8500 only	53
RAK5307	265V Universal Power Supply, 30 Amp for 2800, 2900, 3800, 3900, 4100, 5500, 5800, 6100, 7500 and 8500 only	53
RAK5172	Universal Connection Kit – 265V – 15 Amp – Use w/RAK204E15 Sub-Base – 2.40 kW heat	53
RAK5202	Universal Connection Kit – 265V – 20 Amp – Use w/RAK204E20 Sub-Base – 3.40 kW heat	53
RAK5302	Universal Connection Kit - 265V - 30 Amp - Use w/RAK204E30 Sub-Base - 4.80 kW heat	53
RAK601	Duct Extension – Insulated – 44" long – includes Register and Trim Flange	38
RAK602	Register and Trim Flange (Included with RAK601)	38
RAK6052	Duct Adapter for New Installation (or older non-GE duct adapter installation)	38
RAK7012	Duct Adapter for replacement of A-B with rounded-front AZ chassis for 2200, 3200, 2500, 3500, 2800, 2900, 3800, 3900, 4100 and 6100 only Duct Transition for replacement of AZC with rounded-front AZ chassis for 2200, 3200,	38
RAK7022	2500, 3500, 2800, 2900, 3800, 3900, 4100 and 6100 only	38
RAK8023	Locking Door Kit	12
RAK806	Control Panel Cover (for use with remote thermostat)	16
RAK901L	Wall Case Insulation Kit	23

GENERAL INSTALLATION SUGGESTIONS

Many times poor or non-existent caulking around the exterior of the wall case results in air infiltration, causing the unit to run excessively. One way to check for air infiltration is to look under and around the unit to the outdoors. If you can see light, there is air infiltration. The first floor of a building is where this problem most frequently occurs since caulking the bottom of the wall case may require lying outside in the dirt while working. This has been the cause of many complaints about the "short cycling" of the unit.

Curtains, furniture or other obstructions interfering with the discharge air circulation will make the unit cycle/turn off too soon since the cooled (or heated) discharge air is pulled back into the unit. This results in a room that is not adequately heated or cooled.

Blocking the discharge air on the unit during the heating operation can result in the air getting hot enough to distort the plastic room front. If you have a property where this may occur we recommend a "tent card" advising room occupants not to put anything on the unit.

Electrical Wiring Installation

Do not allow the installer to drill a hole in the wall case to run the electrical wiring. If this is done, the wiring will have to be run between the chassis and the edge of the wall case so it can be connected to the unit wiring on the room side of the wall case. When the chassis is removed for servicing or cleaning, the insulation on the wires can be cut and can create a safety hazard.

If the electrical connection on a 230-volt or 208-volt installation is to be made by the line cord plugged into a wall-mounted receptacle, the receptacle should be located in the wall under the case or close to the side of the wall case. This installation makes a much neater appearance than a line cord running a foot or more across the floor. The electrician may want to place the receptacle as far from the unit as possible to save a few feet of wiring without considering how the installation may appear.

Central Desk Control and Remote Thermostat Wiring

Do not allow the installer to drill a hole in the wall case to run Central Desk Control wiring or remote thermostat wiring to the unit terminals. CDC and remote thermostat wiring is classified as low-voltage wiring and does not have to be run in conduit unless required by local code. CDC and remote thermostat wiring should be run in the walls and exit the wall under the wall case about 2" from the right-hand side. The base pan is designed with a clearance for the line cord and the low-voltage wiring can also be run to the chassis in this area. Wire molding can be used to hold the wiring close to the bottom of the wall case. If a sub-base is used, the wiring can be run through the sub-base, entering the rear and exiting through one of the front panels. When the room cabinet is in place the CDC or remote thermostat wiring is usually not

visible to someone standing or sitting in the room. Do not run the low-voltage wiring in conduits with line-voltage wiring or near uninsulated line-voltage wiring since induced current can interrupt the low-voltage controls.

Consult the electrical inspector early in the project, especially if the power to the air conditioner is to be 265 volts, to understand what is required to comply with local electrical codes.

Wall Case/Exterior Grille

When making an installation where the exterior grille is flush with the exterior wall, or part of a custom window/louver section, make sure the installer caulks the wall case to the exterior wall, especially the bottom of the case. Many times the air conditioners are run during construction and the building is not closed. This can result in excessive humidity from the warm humid air entering the building, or from the "drying out" of the building materials. Many problems have been caused by condensate water or rainwater running back into the building where proper caulking has not been done.

Capacity Considerations

A unit that has a greater cooling capacity than required will cool the room quickly but will usually not run long enough under normal operation to adequately dehumidify the room. Most musty odors in rooms are due to excess humidity. Using a smaller-capacity unit or using Dry Air 25 units will provide better dehumidification. The largest factor in causing mold and mildew in the room is excess moisture. A smaller unit running longer or a Dry Air 25 model can remove more moisture. Mold behind wall coverings that do not allow water vapor to pass through—vinyl wallpaper or oil-base paints, for example—is not a problem of excessive moisture in the room, but rather is caused by moisture trapped in the walls.

Using a resistance heater larger than required—using a 4.7 kW heater when a 3.3 kW heater would suffice for example—may not cost any more in electrical consumption since the larger heater will operate for less time. The "Demand Charge" portion of the utility bill—which is based on the highest electrical load for a period of time—may be a significant portion of the utility bill. Some customers have reported the demand charge actually being more than the usage charge. In a 100-room property it would be possible for the demand of the 4.7 kW heater versus a 3.3 kW heater to be 140 kW more than the demand charge if the lower wattage heaters were used. Working with the utility companies to understand their method of billing and taking advantage of any rebates they may offer can reduce the utility bill.

Exterior Grilles

When replacing an older unit, the existing outdoor grille may need to be changed or modified. Outdoor airflow patterns have changed and this may dictate the need for outdoor grille replacement or modification.

GENERAL INSTALLATION SUGGESTIONS (cont)

Ducted Installation Comments

New Installations

The GE Zoneline® 4100 and 6100 Series are approved for ducted installation using the GE Duct Adapter model RAK6052 and the GE Duct Extension RAK601. A field-fabricated duct extension with the same interior measurements as the RAK601 may be used with the RAK6052 duct adapter. GE does not allow ducting in more than one direction.

The use of a duct adapter other than the RAK6052 is not approved by GE and may cause problems such as inadequate airflow to the secondary room or the unit shutting off on one of the overload devices.

Failure to allow for adequate air return from the secondary room is often the cause of less than satisfactory performance of a ducted installation.

Replacement Installations

GE offers duct adapters to allow for easy replacements of previous-design chassis in ducted installations where a GE duct adapter was used in the original installation. A duct adapter is available that will align with the duct extension when GE-built components were used in the original installation.

The duct adaptor/extension used from the early 1960s until late 1987 was 8-3/8" high by 6-1/2" wide. If the chassis to be replaced is the flat-top discharge (design until late 1987) the duct adapter model RAK7012 will align with the existing duct extension. This means the duct extension will not have to be changed. However, to keep the cost of the replacement to a minimum there are components that will need to be taken off the existing installation and used on the RAK7012 duct adapter. The wall case mounting brackets, screws, discharge grille, damper and end cap will need to be retained.

If the chassis is a slope-front discharge and the duct dimensions are 8-3/8" high by 6-1/2" wide, then the chassis has already been replaced and the purchase of a new duct adapter is not required. The only piece that needs to be replaced in this installation is the transition piece, model RAK7022, which fits between the chassis and the duct adapter.

If the chassis being replaced has a model number that begins with AZ22, AZ25, AZ28, AZ29, AZ32, AZ35, AZ38 or AZ39, the new 4100 or 6100 Series unit can be installed using the same duct components.

If the existing chassis is a slope-front discharge and the duct dimensions are 7-3/32" high by 6-1/2" wide, only the RAK7022 transition piece is required to install a 4100 or 6100 Series unit in the ducted installation.

There were a number of Zoneline units installed in ducted installations that did not use a GE duct adapter. The easiest way to determine if the existing duct adapter is a GE duct adapter is to compare the duct adapter dimensions to the dimensions above. If the dimensions are different from the dimensions above or if the duct adapter is not made of sheet metal, it is not a GE duct adapter. In such installations, GE recommends the removal of the old duct adapter and duct extension and the installation of a RAK6052 duct adapter and a RAK601 duct extension. Zoneline units installed in installations not using GE duct adapters and an extension with the same cross-section dimensions as the duct adapter may not be covered by the warranty.

ZONELINE WARRANTY*

What is covered

Limited one-year warranty

For one year from the date of the original purchase, GE will repair or replace any part of the air conditioner which fails due to a defect in materials or workmanship. During this limited one-year warranty, GE will provide, free of charge, all labor and related service costs to repair or replace the defective part.

Limited five-year warranty

For five years from the date of the original purchase, GE will repair or replace the Sealed Refrigerating System if any part of the Sealed Refrigerating System (the compressor, condenser, evaporator, and all connecting tubing) should fail due to a defect in materials or workmanship. During this limited five-year warranty, GE will provide, free of charge, all labor and related service costs to repair or replace the defective part.

Limited second-through-fifth-year parts warranty

From the second through the fifth year from the date of the original purchase, GE will replace the Fan Motors, Switches, Thermostat, Heater, Heater Protectors, Compressor Overload, Solenoids, Circuit Boards, Auxiliary Controls, Thermistors, Freeze Sentinel, Frost Controls, ICR Pump, Capacitors, Varistors and Indoor Blower Bearing, if any of these parts should fail due to a defect in materials or workmanship. During this additional four-year limited warranty, you will be responsible for any labor and related service costs.

^{*}See written warranty for details

ALPHABETICAL INDEX

Category	Page No.
Accessory List	56
Application Comments	21
Auxiliary Control Settings	13-14
Case Dimensions	22
Central Desk Control	15
Condensate Disposal Systems	35-37
Ducted Installations	38-40
Dry Air 25	5
Electrical Connection	43
Essential Elements Ordering Overview	44
Exterior Grilles	41-42
Features and Benefits	10-12
Features Table	9
General Installation Suggestions	57-58
Heat Pumps and Energy Savings	19-20
Introduction to Zoneline Units	7
Latent System Capacity	45
Maximum Connected Load	45
Mini Specs 4100	2
Mini Specs 6100	3
Mini Specs Power Connection Kits and Nomenclatur	e 4
Normal Yearly Operating Data	46
Remote Thermostat Control	16-18
Schematics	47-50
Suggested Bid Form Specifications	51-52
Table of Contents	6
Wall Case/Sub-Base Installation	23-34
Warranty	58
Zoneline System	8

EXTERIOR GRILLE COLOR SAMPLES



Beige



Maple



Bittersweet

Colors may vary slightly due to printing process.

GE APPLIANCES

At GE, we're reimagining home to introduce a new world of innovation in appliances. Today, we're even more in sync with the consumer. Listening. Anticipating. Engineering ingenious ways to simplify life with more industry-first exclusives. We're redefining style and functional design across all our products. Expanding our U.S. workforce and transforming manufacturing. Improving quality and efficiency. Helping our partners spread the word of GE solutions—from the sales floor to the national stage—and igniting sales. GE Appliances. We're not just imagining. We're doing.



GEAppliances
Appliance Park
Louisville, KY 40225
geappliances.com