

Recommendation

PUMP-Rec-06 Rev C


## PUMP RECOMMENDATION FOR COPPER-FIN 0402-0752 BOILER


Pump Specifications							
Part No.	HorsePower	Flanges	Valute Material	Flange Material	Vendor	Vendor Product Series	Orientation
ARM3044PBF	1/4	2"	Cast Iron	Cast Iron	Armstrong	LS45	Horizontal


Installation Specifications

Specific Model Number	Maximum Flow Rate	Planned Temperature Rise	Planned Flow Rate	Total System Head Loss
55 GPM				

IMPORTANT: Read the Copper-fin II 399-2070 Installation and Operation Manual. If the planned system exceeds the pump capacity in flow and/or head see "Pump-REC-All Pumps" for alternate pumps and pump curves.









Lochinvar, LLC 300 Maddox Simpson Parkway Lebanon, Tennessee 37090 P: 615-889-8900 / F: 615-547-1000 F: E: M. www.Lochinvar.com



Recommendation

PUMP-Rec-06 Rev C


## PUMP RECOMMENDATION FOR COPPER-FIN II 0992-2072 BOILER

Pump Specifications							
Part No.	HorsePower	Flanges	Valute Material	Flange Material	Vendor	Vendor Product Series	Orientation
ARM3024PBF	1/2	2-1/2"	Cast Iron	Cast Iron	Armstrong	2B1050	Horizontal
	Installation	0					

## Installation Specifications

Specific Model Number	Maximum Flow Rate	Planned Temperature Rise	Planned Flow Rate	Total System Head Loss
	90 GPM			

IMPORTANT: Read the Copper-fin II 399-2070 Installation and Operation Manual. If the planned system exceeds the pump capacity in flow and/or head see "Pump-REC-All Pumps" for alternate pumps and pump curves.



.

