# HVAC GUIDE



- Superheat
- Combustion Analysis
- •Target Evap Exit Temp •CheckMe!®test
- Subcooling
- and NOW with

## Do it Right!





## **Benefits**

- Minimize call-backs
- Easier analysis
- Higher quality job
- More efficient technicians
- Download tests to PC
- Lower your customers' energy bills
- Less reliance on outside tech support
- Print work orders

#### How The HVAC Guide® Works:

The **HVAC Guide**® system analyzer walks the tech step-by-step through each test on the dial. Results with suggested actions are displayed right on the screen.

#### How CheckMe!® Works

Use the CheckMe!® test for advanced diagnostics of an A/C or Heat pump system. Many Utility companies now have CheckMe!® rebate or incentive programs.

- 1) Perform a CheckMe!® test on a system.
- 2) Make appropriate repairs to pass the CheckMe!® test.
- 3) Give test data to Proctor Engineering Group.
- 4) A certificate is sent to the customer.
- 5) The utility issues the rebate or incentive.

To become a CheckMe!® certified technician and learn more about these utility rebate and incentive programs, contact Proctor Engineering Group at (888) 455-5742.

HVAC GUIDE Fieldpiece HG2

Combustion

CheckMel





## The Dial





Determine actual and **target evaporator exit temperature** by taking three temperature measurements.

Determine target and actual **superheat** from indoor wet bulb, outdoor dry bulb, suction line temperature, and suction line pressure.

Determine actual **subcooling** from liquid line temperature and pressure and compare to target subcooling.

Analyze the **combustion** process from flue temperature, %O<sub>2</sub>, CO ppm, and primary temperature.

Advanced **CheckMe!®** test for determining the overall state of an A/C system.

## Example of a CheckMel Test

INPUT FORM

Sus Tupe: AC

Nom Ton: 5.0Ton

INDOOR UNIT

Meter Device: TXV/EXV

ID Volts: 120V 1 phase

Return DB: 68.9°F

Return WB: 59.7°F

Supply DB: 53.2°F

OUTDOOR UNIT

Refrigerant: R-22

Rated Amps: 18.0A

OD Volts: 240V 1 phase

Target Subcool: 15.0°F

SL Pressure: 64.2psig



2. Press Output.

OUTPUT FORM Charge unknown, check charge. Low airflow, increase airflow until actual

airflow until actual temp split matches target temp split. Actual temp split is 15°F and target temp split is 10°F.

Possible overcharge, possibly remove refrigerant.

3. Read the results from the OUTPUT FORM.

## (complete INPUT FORM not pictured)

HG2 Includes

1. Enter data on the INPUT FORM.

ATH4 Dual Temperature Head

Wet Bulb T/C Dry Bulb T/C Padded Case USB Cable PC Software



### Get the Kitl

Approved for CheckMe! Programs Part # HG2KS4

Kit Includes:

PC Software

ASX14 Superheat/Subcool Head ATH4 Dual Temperature Head ATC1 Temp Pipe Clamp ACH4 Amp Clamp Wet Bulb Thermocouple Dry Bulb Thermocouple Padded Case USB Cable



