
## SUBMITTAL INFORMATION

Ball Valve Branch Assembly - (UVB63-xxW-G-NL style)

## GRIP JOINT FOR POLYETHYLENE PIPE (PEP) INLET BY TWO METER SWIVEL NUT OUTLETS



			Components		Assembly		
SERVICE	Meter Size	Неіднт	APPROX.	BRANCH	VALVES	CATALOG	✓ SUBMITTED
SIZE	WEIER SIZE	HEIGHT	WT. LBS.	PIECE	(2)	NUMBER	ltem(s)
3/4"	5/8"	4-5/16"	4.4	U68-33-G-NL	BA13-231W-NL	UVB63-31W-G-NL	
3/4"	5/8" x 3/4" or 3/4"		4.6	U68-33-G-NL	BA13-232W-NL	UVB63-32W-G-NL	
1"	5/8"		4.7	U68-43-G-NL	BA13-231W-NL	UVB63-41W-G-NL	
1"	5/8"		4.5	U68-43-65-G-NL	BA13-231W-NL	*UVB63-41W-65-G-NL	
1"	5/8" x 3/4" or 3/4"		4.9	U68-43-G-NL	BA13-232W-NL	UVB63-42W-G-NL	
1"	5/8" x 3/4" or 3/4"		4.7	U68-43-65-G-NL	BA13-232W-NL	*UVB63-42W-65-G-NL	

\* Available with 6-1/2" spacing between centers of meter valves. **Note:** Ford recommends using insert stiffeners with plastic pipe and tubing.

## FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- · All branch valve assemblies have padlock wings
- · Meter gaskets are furnished with all branch valve assemblies
- Meets high pressure service line requirements of AWWA Standard C800
- Conforms to AWWA C700 for meter threads
- Optional full 360° tee-head rotation. Insert "R" into catalog number. Example: UVB63-31WR-G-NL

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.

www.fordmeterbox.com 01/10/17	FORD	The Ford Meter Box Co P.O. Box 443, Wabash, Indiana U Phone: 260-563-3171 / Fax: 800 Overseas Fax: 260-563-0167 www.fordmeterbox.com	.S.A. 46992-0443 )-826-3487	Submitted By
-------------------------------	------	--	--------------------------------	--------------